


NETWORK PLAN (2024-25)

Inter State Transmission System (ISTS)



**Prepared by
Central Transmission Utility (CTU)**

December 2021

Table of Contents

EXECUTIVE SUMMARY	1
CHAPTER 1: BACKGROUND AND OBJECTIVE.....	5
CHAPTER 2: POWER SUPPLY SCENARIO.....	7
2.1 PRESENT POWER SUPPLY SCENARIO.....	7
2.2 ENVISAGED POWER SUPPLY SCENARIO.....	7
CHAPTER 3: LOAD GENERATION PREPARATION	9
3.1 PARADIGM SHIFT	9
3.2 SCENARIOS ADOPTED	11
3.3 DEMAND	11
3.4 GENERATION	14
3.5 LOAD GENERATION BALANCE.....	15
3.5.1 Monsoon Aug'2024	15
3.5.2 Summer June'2024.....	15
3.5.3 Winter Feb'2025	16
3.6 ENERGY STORAGE REQUIREMENT.....	17
CHAPTER 4: ISTS EXPANSION PLAN UPTO 2024-25.....	19
4.1 SUMMARY OF ISTS NETWORK.....	19
4.2 INTER-REGIONAL (IR) CAPACITY	20
4.3 TTC-ATC	21
CHAPTER 5: RENEWABLE ENERGY INTEGRATION PLAN.....	23
5.1 SUMMARY	23
5.2 NORTHERN REGION	24
5.3 WESTERN REGION	27
5.4 SOUTHERN REGION.....	30
CHAPTER 6: CROSS BORDER INTERCONNECTION.....	33
6.1 INDIA-BANGLADESH.....	33
6.2 INDIA-BHUTAN.....	33
6.3 INDIA-MYANMAR	34
6.4 INDIA-NEPAL.....	34
6.5 INDIA-SRI LANKA	35
CHAPTER 7: STUDY RESULTS.....	37
7.1 INTER-REGIONAL SYSTEM.....	37
7.2 TRANSFORMATION CAPACITY	40
7.3 765kV AND 400kV TRANSMISSION SYSTEM.....	41
7.4 CONTINGENCY STUDIES	42

7.4.1 Transformers.....	43
7.4.2 Transmission Lines.....	45
7.5 REACTIVE COMPENSATION STUDIES.....	47
7.5.1 765 kV Nodes	48
7.5.2 400 kV Nodes	49
7.6 SHORT CIRCUIT STUDIES.....	52
CHAPTER 8: CONCLUSION	55
Annexures.....	57

List of Figures

Figure 3.1-1: Solar Generation curve.....	9
Figure 3.3-1: Summer (June'19) Load Curve.....	12
Figure 3.3-2: Monsoon (Aug'19) Load Curve	12
Figure 3.3-3: Winter (Feb'20) Load Curve	13
Figure 3.3-4: Demand factors considered for 2024-25 study time frame	14
Figure 3.5-1: LGB for Monsoon Aug'2024	15
Figure 3.5-2: LGB for Summer June'2024.....	15
Figure 3.5-3: LGB for Winter Feb'2025	16
Figure 3.6-1: Generation surplus with Tech Min (55%) for Thermal Units.....	18
Figure 3.6-2: Generation surplus with Tech Min (40%) for Thermal Units.....	18
Figure 4.2-1: Growth in IR Capacity (MW)	20
Figure 4.2-1: Inter-Regional Transmission Capacity in 2024-25	20
Figure 5.2-1: Transmission system for RE in Rajasthan, NR.....	25
Figure 5.2-2: Transmission system for Pang RE park, NR.....	26
Figure 5.2-2: Transmission system for Kaza Solar Power Project, NR.....	27
Figure 5.3-1: Transmission system for RE in Gujarat, WR.....	29
Figure 5.3-2: Transmission system for RE in Madhya Pradesh, WR.....	29
Figure 5.3-3: Transmission system for RE in Maharashtra, WR.....	30
Figure 5.4-1: Transmission system for RE in Tamil Nadu, SR	31
Figure 5.4-2: Transmission system for RE in Karnataka, SR.....	32
Figure 5.4-3: Transmission system for RE in Andhra Pradesh, SR.....	32
Figure 6.5-1: Cross-Border interconnections.....	36
Figure 7.1-1: Inter-regional flows in nine scenarios	37
Figure 7.2-1: 765/400kV ICT Loading under base case	40
Figure 7.2-2: 400/220kV ICT loading under Base Case.....	41
Figure 7.3-1: 765kV Tr. line flow > 70% of thermal limit under base case	42
Figure 7.3-2: 400kV Tr. line flow > 70% of thermal limit under base case	42
Figure 7.4-1: 765/400kV ICT loading $\geq$ 90% of MVA rating under N-1 Contingency	43
Figure 7.4-2: 765/400kV ICT loading $\geq$ 100% of MVA rating under N-1 Contingency	43
Figure 7.4-3: 400/220kV ICT loadings $\geq$ 90% of MVA rating under N-1 Contingency.....	44
Figure 7.4-4: 400/220kV ICT loadings $\geq$ 100% of MVA rating under N-1 Contingency.....	44
Figure 7.4-3: 765kV Tr. line loadings > 3000MW under N-1 Contingency	45
Figure 7.4-4: 765kV line loading > 3200 MW under N-1 Contingency.....	45
Figure 7.4-5: 765kV line loading > 3500 MW under N-1 Contingency.....	46
Figure 7.4-6: 400kV line loading > 90% of thermal limit	46
Figure 7.4-7: 400kV line loading > thermal limit under N-1 Contingency	47
Figure 7.5-1: Bus voltages at 765kV and 400kV levels within and outside regulation limits.....	48
Figure 7.5-2: Regions wise bus voltages at 765kV level within and outside regulation limits	48
Figure 7.5-3: Regions wise bus voltages at 400kV level within and outside regulation limits	49
Figure 7.5-1: Compensation in 765kV Lines - Present time frame	50
Figure 7.6-1: 765kV and 400kV buses fault level violations.....	52
Figure 7.6-3: Fault level > Design level of Substations.....	53

List of Tables

Table 2.1-1: All India Installed Capacity and Demand met as on Mar'21	7
Table 2.2-1: All India Installed Capacity and projected demand as on Mar'25	7
Table 3.1-1: Load PLF	9
Table 3.3-1: Demand Factors for 2021-22 as per CEA	11
Table 3.3-2: Data Points selected on Demand Curve	13
Table 3.5-1: Regional Surplus/Deficit summary	16
Table 4.1-1: ckm addition	19
Table 4.1-2: MVA addition	19
Table 4.1-3: Broad estimated cost (in ₹ Cr.)	19
Table 4.3-1: TTC-ATC for Apr 2023	21
Table 5.1-1: Region wise RE potential	23
Table 5.2-1: RE potential in NR	24
Table 5.2-1: RE potential in WR and associated Transmission Plan	28
Table 5.4-1: RE potential in SR	30
Table 6.5-1: Cross-border power transfer capacity	35
Table 7.1-1: IR flow summary	37
Table 7.1-2: Critically loaded IR lines summary	40
Table 7.6-1: Top fault level violations in ISTS and STU	53

Executive Summary

Electricity sector is one of the key enablers for achieving socio-economic development of the country. The Indian electricity grid is one of the largest synchronous power system networks in the world. To combat the emerging environmental issues, especially climate change, there is a paradigm shift globally for sustainable growth. In view of this, all countries across the globe are being actively engaged in climate negotiations on different platforms. Consequently, the world has now started moving towards carbon free energy. India being an active participant globally has started taking initiative towards sustainable development and cleaner environment. In this direction, at the COP26 climate conference in Glasgow, India committed to achieve non-fossil energy capacity to 500 GW by 2030 and to meet 50 per cent of its energy requirement through renewable energy by 2030, which are two of the five major commitments of "Panchamrit" to mitigate climate change. India is now at 5th position globally for overall renewable energy installed capacity, with a share of about 25% in its the total installed generation capacity.

Transmission system is acting as a growth engine of electricity sector and therefore should be planned and developed adequately so as enable seamless integration of generation projects and also facilitate availability of reliable, secure, and affordable power to all the consumers. In this direction, Ministry of Power, Govt. of India vide gazette notification dated 01st Oct 2021, has notified Electricity (Transmission System Planning, Development and Recovery of Inter-State Transmission Charges) Rules, 2021. As per the said rules CTU has to draw up plan for Inter-State Transmission System (ISTS) for upto next five years on rolling basis every year identifying specific transmission projects which are required to be taken up along with their implementation time lines. Accordingly, a procedure has been prepared and published by CTU on 16th Dec 2021 for the purpose of planning and coordination relating to ISTS. The entire process for transmission planning has been decided to be undertaken on continuous basis, involving two cycles i.e. from April to September and October to March. Thus, Network Plan reports would be brought out by CTU on half-yearly basis in the months of September and March in every financial year. In this direction, this ISTS Network Plan report is being brought out wherein transmission system adequacy in ISTS has been assessed for 2024-25 time-frame.

In **Chapter-2**, installed capacity & demand of FY 2020-2021 and projected installed capacity & demand of FY 2024-25 have been presented. All India installed capacity & peak demand are expected to increase from 382 GW & 189 GW respectively in FY 2020-21 to 528 GW & 266 GW respectively in FY 2024-25.

To integrate envisaged generation capacity (primarily RE) and meet the projected demand, comprehensive studies have been performed on All India basis for planning ISTS. To perform the studies, Load Generation Balance (LGB) has been prepared in line with the CEA's Manual on Transmission Planning Criteria considering the diurnal and seasonal variations across the country. Accordingly, nine number of load-generation scenarios have been identified corresponding to Monsoon, Summer and Winter season along with three points on daily load

curve for each season. Maximum and minimum demand of 266 GW and 179 GW have been considered in 2024-25 while working out the LGBs.

Detailed overview of the load generation balance preparation and challenges observed while balancing the same have been brought out in **Chapter-3**. While preparing LGB, merit order economic dispatch of thermal generation and RPO obligations of states have been taken into consideration. The Renewable Energy (RE) due to its intermittent nature will need to be balanced through other generation resources. Solar max and Peak demand are occurring at distinct time in a day which necessitates the requirement of Battery Energy Storage System (BESS) in the grid.

Northern and Southern regions, which have been deficit and are importing power from other regions would actually approach self-sufficiency and even export power during high RE generations during 2024-25. Further, due to high variability of RE generation and due to negligible Solar generation in the Evening peak hours, the Inter-Regional (IR) power flow pattern would change even within a day.

Chapter-4 provides the glimpse of year wise ISTS network expansion plan across the country upto FY 2024-25 along with summary of transmission line (ckm) and transformation capacity (MVA) addition.

Region wise RE integration plan including associated ISTS system along with its schematics are outlined in **Chapter-5**.

India being centrally placed in South Asia is playing a vital role in establishment of interconnections between countries so as to establish a large South Asian electricity grid. In **Chapter-6**, details on existing, under-construction and under discussion cross-border interconnections between India and neighbouring countries have been brought out.

Comprehensive studies at all India level has been carried out in nine scenarios using PSS®E software after considering all the planned and under construction system. Inter-Regional flows along with individual tie-lines flows have been tabulated in **Chapter-7**. Further, base case flow loadings on EHV system (above 400kV) have been analysed and the violations have been highlighted in this chapter. In addition, N-1 contingency analysis on EHV Network has also been simulated and results have been brought out. Inter-Regional corridor capacity is found to be adequate to cater the peak demand of respective regions in 2024-25. Augmentation of the network, if any, considering these violations are under study and the same would be published in the subsequent Network Plan report.

Due to intermittent and variable nature of RE and with high penetration of RE in the Indian Grid, loading pattern on some of the lines is expected to change diurnally. Further, transmission lines associated with thermal and hydro generations would be lightly loaded during high RE scenario. Transmission line and ICT loadings have been analysed and results have been brought out in Chapter-7. Over-Voltage and Under-Voltage levels considering IEGC band for all 765 kV and 400 kV buses in all the scenarios have also been analysed and brought out in the report. Reactive power compensation details in ISTS network i.e. no load reactive power generation by 765kV and 400 kV lines vis-à-vis compensation provided has been analysed for

present and 2024-25 timeframe in this chapter. The Over-Voltage and Under-Voltage issues observed in the study are under review for planning and implementation of suitable shunt compensation devices. Details of the same would be brought out in the subsequent Network Plan reports.

Size of the Indian power system has grown notably over the past years and has become more and more meshed due to synchronous interconnection of various regions. It becomes pertinent to identify the fault level violation at various 765 kV and 400 kV buses from design ratings. Accordingly, Short circuit level has been calculated for all 765 kV and 400 kV buses on pan India basis for all the scenarios. Details about the buses exceeding design fault current limit have also been presented in Chapter-7.

The summary of the studies carried out, remedial measures, way forward etc. have been mentioned in **Chapter-8**.

Page intentionally left blank.

Chapter 1: Background and Objective

India is presently going through a phase of rapid growth. Socio-economic development and growth in electricity demand go hand in hand. The power demand of the country has grown from 136 GW at the end of 2013-14 to 190 GW at the end of 2020-21, a growth of about 40%. This demand is expected to further increase to about 267 GW by 2024-25, which translates to growth by about 41%. To meet this fast growing demand, generation capacity is also being continuously added into the grid. By 2024-25, the installed capacity of India is expected to be about 528 GW, a growth of 38% from 382 GW at end of 2020-21.

To meet the growing energy demand in a sustainable manner, environmental issues are now being given special attention. Towards this India is aiming to have about 500 GW of non-fossil fuel based generation in the total installed capacity by the year 2030, as committed in COP26. By 2024-25, about 210 GW of RE (Solar & Wind) generation is expected to be integrated into the grid. With such a large quantum of RE generation addition, the transmission system should be designed considering techno-economic aspects so as to meet the operational challenges like low Capacity Utilisation Factor (CUF) and intermittency & variability etc. of RE generators. Thus, it can be said that transmission is playing a very vital role not only in integration of RE into the National Grid, but also in meeting the energy security of the country by supplying reliable, secure, and affordable power across the length and breadth of the country.

In this direction, Ministry of Power vide gazette notification dated 01st Oct 2021, has notified Electricity (Transmission System Planning, Development and Recovery of Inter-State Transmission Charges) Rules, 2021. As per the said rules CTU has to draw up plan for Inter-State Transmission System (ISTS) for upto next five years on rolling basis every year identifying specific transmission projects which are required to be taken up along with their implementation time lines. Accordingly, a procedure has been prepared and published by CTU on 16th Dec 2021 for the purpose of planning and coordination relating to ISTS.

As per the said ISTS Planning Procedure, the entire process for transmission planning on rolling basis has been decided to be undertaken on continuous basis, involving two cycles i.e. from April to September and October to March. Thus, Network Plan reports would be brought out by CTU on half-yearly basis in the months of September and March in every financial year. In this direction, this ISTS Network Plan report is being brought out wherein transmission system adequacy in ISTS has been ascertained for 2024-25 time-frame. This report covers year wise ISTS requirement on pan India basis to integrate the RE generation and also to cater to the growing demand. To analyse the same, detailed studies including load flow, contingency analysis, voltage profile (reactive power management), short circuit studies etc. have been carried on all India basis for 2024-25 timeframe for nine perspective load-generation scenarios covering three seasons and three load-generation conditions in each season.

Remedial measures for some of the identified issues in ISTS have been suggested in this report. Further, ISTS planning being a continuous exercise detailed studies are being carried out for the remaining issues and new transmission elements, as required, would be planned to address the issue and the details in this regard would be brought out in the next Network Plan report to be published in Mar 2022.

Chapter 2: Power Supply Scenario

2.1 Present Power Supply Scenario

As on Mar'2021, total Installed Capacity (IC) in India was about 382 GW and the peak demand met was about 190GW. The region-wise breakup is summarised at **Table-2.1-1** below. At present, there is no shortage of power supply in meeting these demands.

Table 2.1-1: All India Installed Capacity and Demand met as on Mar'21

Region	Generation (GW)								Demand (GW)
	Thermal				Nuclear	Hydro	RES	Total	
	Coal	Lignite	Gas	Diesel					
NR	54.83	1.58	5.78	0.00	1.62	20.29	18.59	102.69	68.29
WR	74.32	1.40	10.81	0.00	1.84	7.56	29.25	125.18	61.78
SR	44.90	3.64	6.49	0.43	3.32	11.77	44.60	115.16	58.40
ER	27.85	0.00	0.10	0.00	0.00	4.64	1.59	34.18	24.02
NER	0.77	0.00	1.74	0.04	0.00	1.94	0.37	5	3.29
All India	202.67	6.62	24.92	0.47	6.78	46.21	94.40	382.07	190.20

2.2 Envisaged Power Supply Scenario

As per the 19th EPS, all India peak demand for 2024-25 is expected to increase to about 267 GW. To meet the increase in demand of 77 GW from present, net 147 GW generation is envisaged to be added after considering retirement of 18 GW of thermal generation by 2025 (**Annex-2.2**). Total installed capacity for 2025 shall be about 528GW. Installed capacity and projected demand for 2024-25 are tabulated below:

Table 2.2-1: All India Installed Capacity and projected demand as on Mar'25

Region	Generation (GW)								Demand (GW)
	Thermal			Diesel	Nuclear	Hydro	RES	Total	
	Central	State	IPP						
NR	11.44	39.62	0.00	3.96	4.42	22.58	70.90	152.91	86.70
WR	19.00	35.79	36.99	10.00	3.24	8.17	69.59	182.77	84.50
SR	12.19	29.78	6.64	2.98	3.32	11.92	68.44	135.26	74.60
ER	24.44	12.17	4.50	0.00	0.00	8.18	0.65	49.94	32.30
NER	0.75	0.13	0.00	1.82	0.00	4.82	0.20	7.72	5.70
All India	67.82	117.47	48.13	18.77	10.98	55.66	209.78	528.60	266.80

The region wise growth in demand and fuel type wise increase in installed generation capacity for 2024-25 from present time-frame is tabulated below:

Peak Demand (GW)					Generation IC (GW)				
	<i>2020-21</i>	<i>2024-25</i>	<i>Diff</i>	<i>% increase</i>		<i>Present</i>	<i>2025</i>	<i>Diff</i>	<i>% change</i>
NR	68.20	86.70	18.50	27.13%	Thermal	209.76	233.41	23.65	11.27%
WR	61.70	84.50	22.80	36.95%	Gas	24.92	18.77	-6.16	-24.72%
SR	58.30	74.60	16.30	27.96%	Nuclear	6.78	10.98	4.20	61.95%
ER	24.10	32.30	8.20	34.02%	Hydro	46.21	55.66	9.46	20.47%
NER	3.30	5.70	2.40	72.73%	Solar	40.10	135.55	95.45	238.03%
All India	190.20	266.80	76.60	40.27%	Others	54.30	74.22	19.93	36.70%
					Total	382.07	528.60	146.53	38.35%

Out of about 147 GW of generation addition about 130 GW is based on non-fossil fuels. Major renewable generation is coming up in NR, WR and SR.

Chapter 3: Load Generation Preparation

3.1 Paradigm shift


The planning philosophy has undergone vast changes over time as per the technical and socio-economic requirements. The RE (Solar & Wind) capacity penetration has grown from about 14% at the end of 2013-14 to about 25% at the end of Mar 2021, which has been further growing at fast pace, and by 2025 the RE penetration is expected to be about 40%. With large scale integration of Renewable Energy (RE) based generation (primarily Solar and Wind) the ISTS is now being planned on RE potential basis, which is shift from earlier practice of planning of system mainly based on conventional generation.

Presently, the Plant Load Factor (PLF) of demand is about 80% (**Table 3.1-1**) and major portion of the same is being met by thermal generation having PLF in similar range. However, solar generation has a PLF of about 25-30%. At 30% PLF, 1 MW solar plant would generate about 7.2 MWh of energy in a day. From the **Figure 3.1-1**, it may be observed that a solar plant generates electricity only for 10-12 hours in a day. Therein, for about 4 hours in a day the solar plant generates about 100% of its design capacity (1*4=4 MWh) while for remaining 6-8 hours it generates about 3.2 MWh. Thus, it may be observed that more than 50% of energy from solar plants is generated in a short duration of 4 hours. During these 4 hours energy produced by the thermal power plant has to be either reduced or utilised alternatively.


Table 3.1-1: Load PLF

Year	Peak Demand (MW)	Energy Calculated from Peak Demand (BU)	Actual Energy Consumption (BU)	Calculated Load PLF
2019-20	1,83,804	1610	1291	0.80
2018-19	1,77,022	1550	1274	0.82
2017-18	1,64,066	1437	1213	0.84
2016-17	1,59,542	1397	1143	0.82


Figure 3.1-1: Solar Generation curve



Typical generation pattern for a day with low Solar penetration is given below:



From the above pattern, it may be observed that thermal generation is acting as base load plants, supplying same amount of power almost throughout the day. However, in case of high Solar generation for about 4 hours in a day as shown below, it may be observed that during that time i.e. point A in below schematic the thermal generation may need to be backed down. For meeting the peak load in evening thermal generation shall run at its maximum capacity corresponding to point B. Same number of the thermal units shall be backed down to 55% despatch in the afternoon time to accommodate max Solar generation at point A. However, there is a limited capacity which can be backed down at point A. For example, if 100 GW of thermal generation capacity was on bar at point B and generating 85 GW at that time then during the afternoon period this capacity shall generate 55 GW at 55% of technical minimum, which shall create a margin of about 30 GW, which can accommodate about 30 GW of solar generation. To integrate additional quantum of Solar capacity, surplus energy needs to be utilised alternatively in the grid as the thermal generations cannot be put out of service as they are required to meet the Peak demand conditions during the Evening, and due to technical limitations thermal generations cannot be started or stopped swiftly.



Accordingly, various alternatives are being looked into to store surplus energy, however, the quantum of energy produced in a day should be equal to the quantum of energy consumed within the same day, so that 100% of the storage capacity is available for the next day for reuse. The stored energy during peak Solar generation can be used to supply power during the evening peak load condition along with other thermal generations on bar. This is only one of the factors, however, in reality large number of parameters may need to be taken care of, and accordingly granular analysis is required.

3.2 Scenarios adopted

To replicate and simulate seasonal power requirement variations on annual basis, three load-generation scenarios within a day in three different seasons were chosen as per CEA's Manual on Transmission Planning Criteria. Three points on load curves were identified for each day i.e. Solar max (afternoon), Peak load (evening) and Off-peak load (night). Further, the same was carried out for three seasons viz. Monsoon (August), Summer (June) and Winter (February). Accordingly, load generation has been prepared for following nine number of scenarios:

- Aug'24: Solar max, Evening Peak and Night off-peak
- Jun'24: Solar max, Evening Peak and Night off-peak
- Feb'25: Solar max, Evening Peak and Night off-peak

During afternoon hours solar generation is at its peak and thermal generation requirement is minimal. While in evening, solar generation is zero and the thermal generation requirement is maximum. Details about the selection of points on load curve and generation despatching philosophies are discussed in subsequent sections.

3.3 Demand

As per 19th EPS All India peak demand is expected to be about 267 GW in 2024-25. CEA vide report dated 30.01.2020, published demand factors for the timeframe of 2021-22, which is reproduced in **Table-3.3-1** below. For identifying these demand factors, demand data for the years 2016-17, 2017-18 and 2018-19 was considered.

Table 3.3-1: Demand Factors for 2021-22 as per CEA

Region	February			June			August		
	AN Peak (%)	Eve Peak (%)	Night Off -Peak (%)	AN Peak (%)	Eve Peak (%)	Night Off -Peak (%)	AN Peak (%)	Eve Peak (%)	Night Off -Peak (%)
NR	70	78	48	85	97	67	82	96	72
WR	93	92	67	82	85	66	75	84	60
SR	88	93	66	74	85	60	80	90	60
ER	68	90	55	78	95	66	75	97	70

Region	February			June			August		
	AN Peak (%)	Eve Peak (%)	Night Off -Peak (%)	AN Peak (%)	Eve Peak (%)	Night Off -Peak (%)	AN Peak (%)	Eve Peak (%)	Night Off -Peak (%)
NER	53	91	40	65	97	50	70	99	56
All India	88	95	65	86	95	75	85	96	76

However, due to changing demand pattern throughout the day and shift in agricultural load, it is envisaged to revise these factors based on latest demand data. Considering the impact of COVID epidemic in 2020-21, demand data of year 2019-20 for the three representative months was collected from POSOCO and accordingly three points on the average demand curve of three months corresponding to solar max, evening peak and night off peak were selected, which are depicted in below figures.

Figure 3.3-1: Summer (June'19) Load Curve




Figure 3.3-2: Monsoon (Aug'19) Load Curve





Figure 3.3-3: Winter (Feb'20) Load Curve




Details about these points like time and demand encountered in 2019-20 during the month of June, August and February are tabulated in **Table-3.3-2**.

Table 3.3-2: Data Points selected on Demand Curve

Month	Time	NR	WR	SR	ER	NER	All India
Jun-19	12:00:00	55.51	49.76	39.91	18.78	1.89	165.85
	22:45:00	60.19	49.66	40.62	21.39	2.38	174.23
	5:00:00	54.33	46.21	36.08	18.77	1.81	157.20
Aug-19	12:00:00	51.36	42.89	37.59	18.55	2.06	152.44
	19:50:00	55.64	44.24	38.26	21.75	2.77	162.66
	4:05:00	49.71	38.67	31.68	19.56	2.11	141.74
Feb-20	12:00:00	43.97	55.22	47.77	15.38	1.62	163.96
	9:30:00	48.06	56.34	48.99	16.31	1.78	171.48
	19:00:00	46.50	48.67	43.60	18.29	2.34	159.41
14 th Jun	22:30:00	65.08	49.99	42.86	22.07	2.45	182.45
3 rd Feb	02:05:00	28.50	39.42	35.35	12.20	1.26	116.71
Actual Peak		66.69	59.39	53.47	23.78	3.15	182.61

Above demand data was divided by maximum regional demand of the corresponding year to obtain the demand factors which is tabulated in **Figure-3.3-4** below. The same has been used for calculating regional demand for 2024-25 time-frame.

Figure 3.3-4: Demand factors considered for 2024-25 study time frame



3.4 Generation

To meet the anticipated demand as per 19th EPS, various sources of generations viz. Thermal, Nuclear, Hydro, Gas, RE are available. However, dispatch of these generators shall depend upon the availability of generation especially RE which vary within a day and also seasonally.

For this purpose, region wise load generation balancing philosophy was considered for the study. Primarily the demand was met by RE generation. Since RE has been considered as must-run generators, hence total RE generation has been apportioned as per RE RPO to all regions based on their projected EPS demand. Further, for accounting the availability of solar roof-top generation, equivalent demand was reduced from respective regions. After meeting the demand by RE generation, balance demand was met by other generation resources viz., Nuclear, Gas, Hydro and Thermal.

Evening peak scenario of each month was setup first as the number of thermal units required on bar shall be maximum. Total thermal generation requirement for the evening peak scenario was apportioned between State and Central sector thermal generations as per their installed capacity in each region. Further, state thermal generation requirement was divided among the states as per their maximum demand in respective month of 2019-20. After obtaining state thermal generation requirement, state thermal units were dispatched at technical maximum (85% or 90%) in merit order for each state.

ISGS, CGS & IPP thermal plants with lower variable cost were dispatched at technical maximum (85%) region wise progressively. To meet the demand of any deficit region thermal generation dispatches from other regions considering all India merit order for evening peak scenario was considered.


For night off-peak scenario, on bar thermal units were scaled down proportionately.

3.5 Load Generation Balance

Load Generation Balance (LGB) for above mentioned nine scenarios considered for the study was prepared in consultation with CEA and POSOCO. A meeting in this regard was also held on 11.03.2021 and minutes of the same are attached at **Annex-3.5.1**. Based on the discussion and deliberations LGB scenarios are summarised in below figures and details about the same are attached at **Annex-3.5.2**.


3.5.1 Monsoon Aug'2024

Figure 3.5-1: LGB for Monsoon Aug'2024




3.5.2 Summer June'2024

Figure 3.5-2: LGB for Summer June'2024



3.5.3 Winter Feb'2025

Figure 3.5-3: LGB for Winter Feb'2025



Out of these nine scenarios, Scenario-5 and Scenario-9 corresponds to two extreme cases with respect to demand i.e. highest demand (267 GW) and lowest demand (171 GW) scenarios respectively. In all other scenarios, all India demand is varying between these two demands as per demand factors. Based on LGB, region wise surplus/deficit in these scenarios is summarised in **Table 3.5-1**. Further, both maximum surplus and deficit of each region is highlighted in table below.

Table 3.5-1: Regional Surplus/Deficit summary

Surplus (+) / Deficit (-)	Aug'24 (Monsoon)			Jun'24 (Summer)			Feb'25 (Winter)		
Scenario No. Region	1	2	3	4	5	6	7	8	9
	Solar Max	Peak Load	Off Peak	Solar Max	Peak Load	Off Peak	Solar Max	Peak Load	Off Peak
NR	13019	-14812	-15740	10527	-22693	-16603	25577	-8516	-2624
WR	1492	15529	16082	1228	23044	17013	-4217	13664	12643
SR	770	7748	6215	2901	5868	5357	-13475	-10062	-12632
ER	-13932	-8937	-6959	-14242	-7287	-6648	-4247	5049	3077
NER	-489	472	402	-184	1068	881	-1600	-135	-463

From the above table it may be inferred that:

- NR is importing as well as exporting power in different scenarios. Export of power is taking place in solar max scenarios due to high solar generation in NR, whereas maximum import of power is happening in Summer (June) evening peak load scenario.
- WR generally exports the power with a maximum export of 23 GW in Summer (June) evening peak scenario. Due to low availability of RE during Winter (Feb), WR becomes deficit to the tune of 4 GW.
- SR is importing as well as exporting power under various scenarios. Maximum export of power is 8 GW in Monsoon (August) evening peak scenario due to high wind generation in monsoon season, whereas maximum import of the order of 13.5 GW is taking place in the Winter (February) Solar max case due to very low wind generation at that time.
- ER is mostly importing power in high renewable generation scenarios due to RE RPO requirements of ER which it shall not be able to meet from its own regional RE and it has to import power from neighbouring regions. ER is exporting power during Monsoon (February) evening and night off peak scenarios due to absence of Solar as well as low Wind generation in other regions.
- NER also import as well as export power in different scenarios. Mostly export of power shall take place in the Monsoon (August) and Summer (June) months due to high hydro generation during these seasons, whereas it shall import in Winter (February) scenario due to low hydro and RE RPO obligation.


Considering the above LGB for nine scenarios, load flow cases were prepared for detailed studies incorporating assessment of adequacy of ISTS including inter-regional corridors planned to cater the power transfer requirement across the region in 2024-25 timeframe. Detailed study results have been discussed in subsequent chapters.

3.6 Energy Storage requirement

While preparing the present LGB for Solar max scenario, some plants were switched off to balance the load generation while running all the on-bar thermal plants at technical minimum of 55%. Accordingly, thermal plants with higher cost (on merit order basis) were switched off region wise progressively till the LGB is balanced.

Accordingly, it is observed that in the Solar max scenario there is surplus power available in the grid. It is due to availability of peak solar generation and lesser demand in the noon. This surplus is on account of keeping the same number of thermal plants operating at technical minimum (55%) in Solar max scenario which are required to meet evening peak demand. Even after considering the flexibility exhibited by gas and hydro generation between the evening peak and Solar max scenario the surplus generation in terms of MW dispatches is given below.


Figure 3.6-1: Generation surplus with Tech Min (55%) for Thermal Units



It may be observed that surplus generation is 49 GW, 45 GW, and 13 GW during Solar max in Monsoon, Summer, and Winter scenario respectively which need to be stored using BESS and used in other times during the same day.

A sensitivity analysis is done to see the quantum of surplus generation, if technical minimum of thermal units is reduced at 40% and the corresponding results are given below:

Figure 3.6-2: Generation surplus with Tech Min (40%) for Thermal Units



Even after operating thermal units at technical minimum of 40%, surplus generation of the order of 29 GW and 15 GW are observed during Solar max in Monsoon and Summer seasons respectively. Thus, BESS of about 29 GW capacity may be required to be installed in the grid to facilitate integration of about 210 GW of RE. In case, BESS is not adequately installed and if the number of on bar thermal units are to be kept same throughout the day during 2024-25, then thermal unit may need to be despatched to 27% and 28% during Solar max scenario in Monsoon and Summer respectively, which may not be practically feasible.

Chapter 4: ISTS Expansion plan upto 2024-25

4.1 Summary of ISTS network

Region and year wise ISTS network expansion plan across the country upto FY 2024-2025 is enclosed in **Annex-4.1**. Summary of ckm addition, MVA addition and the broad estimated cost are tabulated below in Table 4.1-1, 4.1-2 and 4.1-3 respectively.

Table 4.1-1: ckm addition

FY	WR	SR	NR	ER	NER	Total
2021-22	1,721	0	659	112	79	2,571
2022-23	495	1,453	4,123	50	793	6,914
2023-24	3,798	550	0	265	340	4,953
2024-25	292	1,520	5,475	0	150	7,437
Total	6,306	3,523	10,257	427	1,362	21,875

Table 4.1-2: MVA addition

FY	WR	SR	NR	ER	NER	Total
2021-22	10,500	500	9,950	2,915	390	24,255
2022-23	3,000	5,000	15,185	0	100	23,285
2023-24	40,000	10,500	0	1,000	320	51,820
2024-25	3,000	34,500	42,080	0	320	79,900
Total	56,500	50,500	67,215	3,915	1,130	179,260


Table 4.1-3: Broad estimated cost (in ₹ Cr.)

FY	WR	SR	NR	ER	NER	Total
2021-22	5,168	129	2,950	585	290	9,122
2022-23	794	5,698	11,960	775	1,545	20,772
2023-24	12,343	1,773	0	325	0	15,126
2024-25	395	6,652	16,015	0	130	22,507
Total	18,700	14,252	30,925	1,685	1,965	67,527

4.2 Inter-Regional (IR) Capacity


The progressive growth in Inter-Regional (IR) transmission capacity and till 2024-25 is given below:

Figure 4.2-1: Growth in IR Capacity (MW)



Details of Inter Regional corridor capacity are attached at **Annex 4.2** for 2024-25 and the schematic of the same is given below.

Figure 4.2-2: Inter-Regional Transmission Capacity in 2024-25



4.3 TTC-ATC

The Total Transfer Capability (TTC), Available Transfer Capability (ATC) and Transmission Reliability Margin (TRM) are defined as under:

“Total Transfer Capability (TTC)” means the amount of electric power that can be transferred reliably over the inter-control area transmission system under a given set of operating conditions considering the effect of occurrence of the worst credible contingency.

“Transmission Reliability Margin (TRM)” means the amount of margin kept in the total transfer capability necessary to ensure that the interconnected transmission network is secure under a reasonable range of uncertainties in system conditions.

“Available Transfer Capability (ATC)” means the transfer capability of the inter-control area transmission system available for scheduling commercial transactions through access requests in a specific direction, considering the network security. Mathematically ATC is the TTC less TRM.”

TTC is generally less than aggregated transmission capacity between regions. This is owing to the fact that the transmission capacity of regional corridor is arrived by adding the ratings of all transmission lines connecting two regions and it is a fixed parameter, whereas transfer capability is the measure of the ability of the corridor, as a whole, for reliable transfer of power from one region to another which depends upon network topology, load generation balance and strength of the weakest link in the corridor, downstream network etc. The delay and deferment of transmission elements/load/generation greatly affects the value of the transmission capability. Therefore, TTC may vary widely with respect to transmission capacity. Further, looking into the uncertainties in implementation of various generation projects and transmission elements, declaration of TTC for upcoming few years ahead may not be accurate.

As on date TTC/ATC has been declared by CTU for Apr 2023 time-frame for various critical inter-regional corridors and the same is as given below:

Table 4.3-1: TTC-ATC for Apr 2023

Corridor	Total Transfer Capability (TTC)	Transmission Reliability Margin (TRM)	Available Transfer Capability (ATC)
WR-NR	25000	500	24500
ER-NR	6900	300	6600
WR-SR	16000	500	15500
ER-SR	5450	250	5200
ER-NER	2000	40	1960

Page intentionally left blank.

Chapter 5: Renewable Energy Integration plan

5.1 Summary

Govt. of India has set a target of establishing 500 GW of generation installed capacity from non-fossil fuel based energy resources. Towards this, about 157 GW of generation capacity [RES: 104GW, Large Hydro: 46.5GW & Nuclear: 6.78GW] through non-fossil fuel based resources is already commissioned, which is being evacuated through existing Inter-state Transmission System (ISTS) and Intra-state Transmission System (In-STS). Thus, about 343GW of additional installed capacity of non-fossil fuel based generation resources need to be integrated till 2030. The status of transmission system already planned under ISTS for upcoming non-fossil fuel based generation capacity is given below:

Table 5.1-1: Region wise RE potential

Sl. No.	Scheme	Potential (in GW)	Region-wise Breakup
1	Transmission schemes planned for 66.5GW REZ	66.5	NR: 20GW WR: 28GW (Incl. 10.5GW in Khavda area) SR: 18.5GW
2	Transmission Schemes planned / under planning beyond identified 66.5 GW REZ	52	NR: 30.88GW • Rajasthan: 20GW • Ladakh: 10GW • Kaza (Spiti): 0.88GW WR: 21.2GW • Khavda: 17.2GW • Dholera: 4GW
3	Transmission Schemes planned / under planning for future Large Hydro Projects	13.8	NR: 8.4GW ER: 5.4GW
4	Margins for injection in existing ISTS System	42	NR: 15GW WR: 9.1GW SR: 4.7GW ER: 13.2GW
Total Capacity (Planned/Under Planning)		174.3*	

* 2.5GW RE generation already commissioned as part of 66.5GW REZ (as on Nov-21)

For achievement of balance 166GW capacity [343-174.3-2.5], SECI has identified 179GW potential RE zones in various states in SR, WR, and NR viz. Andhra Pradesh, Karnataka, Telangana, Rajasthan, Maharashtra and Madhya Pradesh with various Hybrid & Solar locations planned with storage such that total evacuation system requirement in terms of transmission infrastructure shall be required for about 102GW only (to ensure minimum transmission system utilization to at least 50%).

By 2024-25, RE capacity to the tune of 210 GW is expected to be commissioned which includes 121 GW Solar, 70 GW Wind, 14 GW Solar Rooftop and 4 GW other RES.

Region wise brief on power evacuation schemes along with the schematics is given below and the detailed scope of each of the scheme is at **Annex 5.1**.

5.2 Northern Region

In Northern Region, RE potential is mainly concentrated in Rajasthan (that too mainly solar potential). Accordingly, potential Solar Energy Zones (SEZs) of 20GW in Ramgarh/Kuchheri & Fatehgarh (Jaisalmer distt), Phalodi (Jodhpur distt), Kolayat /Pugal (Bikaner distt) were identified in western Rajasthan. Out of this, 17GW potential zones are to be developed in Phase-I (8.9GW) & Phase-II (8.1GW) under ISTS and balance 3GW are to be developed under intra-state by RVPNL. The potential of 17GW is to be materialized in phase wise manner i.e. 8.9GW in Phase-I and 8.1GW in Phase-II. The details are as below:

Table 5.2-1: RE potential in NR


Location	Potential (GW)		Total (GW)
	Phase-I	Phase-II	
Ramgarh	0	1.9	1.9
Fatehgarh	3.5	2.2	5.7
Bhadla	3.55	1.05	4.6
Bikaner	1.85	2.95	4.8
Total	8.9	8.1	17

Accordingly, to evacuate power from above solar energy zones, transmission system has been identified and is currently under various stages of implementation. Transmission System for evacuation of power under Phase-I i.e. Transmission System for Solar Energy Zones in Rajasthan (8.9GW) under Phase-I has been commissioned. Further, Transmission System for Solar Energy Zones in Rajasthan (8.1GW) under Phase-II is envisaged progressively from Dec 2022.

In addition to above, additional 20GW SEZs (Fatehgarh: 9.1 GW, Bhadla: 8GW, Ramgarh: 2.9 GW) were also envisaged in Rajasthan by SECI. In order to integrate and evacuate power from additional 20 GW SEZs, hybrid (EHVAC & HVDC) transmission system comprising EHV AC (765kV) & HVDC corridors for 6GW towards Delhi & Southern UP has been planned & agreed for evacuation of power from additional 20 GW SEZs in Rajasthan (Phase-III). However, HVDC corridors for 6GW has been deferred and currently under review due to non-visibility of RE projects as well as option of emerging Battery Energy Storage System (BESS) so as to enhance the utilization of existing system and minimize the requirement of HVDC lines.

A schematic of planned transmission system for RE in Rajasthan is given below:

Figure 5.2-1: Transmission system for RE in Rajasthan, NR




Transmission system for evacuation of power from renewable energy parks in Leh

Based on the directions of MoP, the possibility of developing and evacuating 10GW of renewable energy from Leh has been explored. Two locations have been identified for pooling of renewable energy in Leh i.e. Nyoma and Pang with a capacity of 5GW each. Power from above locations is proposed to be evacuated through VSC based HVDC system upto Kaithal and Kashipur respectively. Beyond Kaithal & Kashipur, it is to be integrated with National Grid through 765kV line as well as 400kV lines. However, in a meeting held on 22.06.2021 under the chairmanship of Secretary, Ministry of Power, the issue of wild life sanctuary involvement in Nyoma-Kashipur section was highlighted. It was also suggested that integration of 12 GWh of BESS at Pang may reduce the overall transmission capacity to 5 GW and accordingly, one of the planned ISTS links from Ladakh can be completely eliminated. With BESS, superior power supply and higher capacity utilization of the lines from Leh can be achieved.

After deliberations, it was decided that the transmission system for evacuation of 10 GW RE generation would comprise 5 GW transmission link from Pang to Kaithal along with 12 GWh BESS under Phase-I. It is also to mention that by integrating 12 GWh of BESS at Pang, one transmission system corridor of 5 GW from Pang to Kaithal shall be sufficient to cater to the

evacuation up to 13 GW (9 GW Solar + 4 GW Wind) RE capacity. BESS will increase the utilization of the transmission corridor, besides ensuring superior power supply. As capacity addition of RE generation i.e., hybrid of Solar and Wind is expected to be built up gradually over a period of time, implementation of BESS can be taken up at the later stage of Phase-I of transmission system, which would help in optimizing the cost of BESS. A schematic of the proposed transmission system is given below.

Figure 5.2-2: Transmission system for Pang RE park, NR



Transmission System for Evacuation of Power from Kaza Solar Park (880 MW)

To provide connectivity for proposed Kaza solar park being developed by SJVN Ltd., establishment of 1x315 MVA, 400/132kV substation at Kaza along with Kaza – Wangtoo (HPPTCL) 400 kV D/c line is agreed to be implemented under ISTS. Subsequently, availability of additional RE potential in Kinnaur area in proximity to Kaza was confirmed by HIMURJA. Accordingly, considering RE potential in contiguous area of Kaza complex as well as severe RoW limitations in Kaza-Wangtoo corridor, the line capacity of Kaza – Wangtoo 400 kV D/c line was decided to be developed with high capacity conductor capable of carrying about 2500 MVA per circuit at nominal voltage. This high capacity line shall also help in evacuating power from envisaged hydro potential in that area. Further, for transfer of power beyond Wangtoo,

Table 5.3-1: RE potential in WR and associated Transmission Plan

Location of REZ	REZ Potential (GW)	Transmission Plan
Bhuj	2	Transmission System under implementation and expected by Mar'22.
Dwarka (Jam Khambaliya)	1.5	
Lakadia	2	
Khavda	8	Transmission System for Khavda Phase-A (Ph-I) (3GW) is under tendering process and award is expected shortly with implementation time-frame of Dec '23. Transmission System for Khavda Phase-A (Ph-II) (5GW) is under tendering stage with implementation schedule of 24 months from SPV transfer.
Khavda	2.5	The potential is part of Khavda REZ Phase-B (7GW) and associated transmission System is yet to be taken up for implementation due to no visibility of RE generation.
Gujarat	16	
Rajgarh	2.5	Transmission System for Rajgarh (1.5GW) is under tendering process and award is expected shortly with implementation time-frame of Jun '23. Transmission System for balance 1GW REZ is yet to be taken up for implementation due to no visibility of RE generation beyond 1.5GW at Rajgarh.
Neemuch	1	Transmission System is under tendering stage with implementation schedule of 18 months from SPV transfer.
Chattarpur	1.5	Transmission System is under tendering stage with implementation schedule of 18 months from SPV transfer.
Madhya Pradesh	5	
Sholapur	2.5	Transmission System is yet to be taken up for implementation due to no visibility of RE generation
Wardha	2.5	
Osmanabad	1 (ISTS) + 1 (Intra-state)	Transmission System is under tendering process and award is expected shortly with implementation time-frame of Jun '23
Maharashtra	7*	
Grand Total	28*	

*With 1 GW is under intra-state

The transmission system for evacuation of power from cumulative 7 GW REZ in Khavda area under Phase-B (including 2.5GW potential under 66.5GW REZ) as well as for Dholera UMSP (Phase-I: 2GW) have also been planned. However, the schemes have been deferred as per details given below:

- Khavda Phase-B (7GW) to be studied again with consideration of BESS at Khavda RE park.
- Dholera scheme to be deliberated based on outcome of the RE potential studies for Dholera Solar Park as well as clarity on various clearances for the park.

The schematics of the proposed transmission system for 28 GW REZ projects in Gujarat, Madhya Pradesh, and Maharashtra are given below:

Figure 5.3-1: Transmission system for RE in Gujarat, WR




Figure 5.3-2: Transmission system for RE in Madhya Pradesh, WR





Figure 5.3-3: Transmission system for RE in Maharashtra, WR



5.4 Southern Region

A number of potential renewable energy zones were identified in the states of Karnataka, Andhra Pradesh and Tamil Nadu by MNRE/SECI having potential of 18.5 GW. The details of the same as per the area and phases are as below:

Table 5.4-1: RE potential in SR

Region	Wind	Solar	Total
Tirunelveli (TN)	0.5		0.5
Koppal (Kar)	2.5		2.5
Karur (TN)	2.5		2.5
Gadag (Kar)		2.5	2.5
Bidar (Kar)		2.5	2.5
Kurnool (AP)	3.0	2.5	5.5
Anantapur (AP)		2.5	2.5
Total	8.5	10.0	18.5

Transmission system for the integration and immediate evacuation of power from these potential REZ in Southern Region was evolved in consultation with CEA, POSOCO and SR

constituents in the 2nd SRSCT and 1st SRPC(TP) held on 10.06.2019 and 16.12.2019 respectively. The proposed transmission system was agreed to be implemented as ISTS in phased manner as per the visibility of generation in these potential areas.

Based on the progress of generation in the identified REZ, transmission system for 8 GW of REZ in Koppal, Gadag, Karur and Tuticorin REZ is already under implementation. Further, transmission system for integration and immediate evacuation of balance 10.5 GW of REZ in Bidar, Kurnool and Anantapur districts is on-hold and the same shall be implemented as per the visibility of the generation projects in these areas.

It is pertinent to mention that since a huge potential of REZ has been identified in Southern Region and more and more power is expected to be injected into ISTS as per the latest assessment done by MNRE/SECI, Southern Region is expected to export surplus power in high RE scenario in the months of May to October. In such a scenario, constraints are likely to be observed for export of this surplus power to beneficiaries in other regions particularly beyond Kolhapur in Western Region. It may be mentioned that looking into the requirement of export of surplus power, Raigarh-Pugalur HVDC link planned for facilitating import of power to Southern Region has been designed with reverse power flow provision upto 3000 MW and may be used for export of surplus RE power from Southern Region. Moreover, ISTS network expansion scheme between Western Region & Southern Region for export of surplus power during high RE is being planned by CTU in consultation with various stakeholders. The schematics of the proposed transmission system are given below.

Figure 5.4-1: Transmission system for RE in Tamil Nadu, SR




Figure 5.4-2: Transmission system for RE in Karnataka, SR





Figure 5.4-3: Transmission system for RE in Andhra Pradesh, SR



Chapter 6: Cross Border Interconnection

Due to geographical location, India shares its boundaries with many South Asian countries and can play an important role in exchange of power to these countries for optimal utilisation of resources in particular and development of economy in general. Transmission of power is economical than transportation of fuel. Towards this, it is important to establish electrical interconnections with neighbouring countries which would be beneficial in meeting growing power demand, sharing of various types of energy resources, decreasing operational cost through better resource management, utilizing renewable energy resources and deferring investment by optimizing spinning reserve.

The details of existing, under-construction and under-discussion interconnections with the neighbouring countries viz. Bangladesh, Bhutan, Myanmar and Nepal with Indian grid to facilitate transfer of power for the benefit of both sides is given below:

6.1 India-Bangladesh

(i) Present interconnection

- 1160MW is being transferred to Bangladesh through following two links:
 - *1000MW through Baharampur (India) – Bheramara (Bangladesh) 400kV 2xD/c line along with 2x500MW HVDC Back-to-Back terminal at Bheramara.*
 - *160MW through Surajmaninagar (Tripura) – North Comilla (Bangladesh) – South Comilla 400kV D/c radial interconnection (operated at 132kV).*

(ii) Planned interconnection

- Katihar (Bihar) – Parbotipur (Bangladesh) – Bornagar (Assam) 765kV D/c line: India is going ahead with the financing and construction of the entire cross border link. The Bangladesh side may synchronize through this link at Parbotipur at an appropriate time for drawl of power.

6.2 India-Bhutan

(i) Present interconnection

- 2070MW is being transferred from Bhutan to India through following lines in synchronous mode of operation
 - *Kurichu HEP – Geylephu (Bhutan) – Salakati 132kV S/c*
 - *Deothang/Motonga – Rangia 132kV S/c*
 - *Chukha HEP – Birpara 220kV (3 circuits)*
 - *Tala HEP – Siliguri 400kV 2xD/c*
 - *Mangdechhu HEP – Alipurduar (via Punatsangchhu) 400kV D/c (Quad) line*

- *Jigmeling (Bhutan) – Alipurduar 400kV D/c (Quad) line*

(ii) Under Construction interconnection

- With the commissioning of Punatsangchu-I and II generation by 2024-25, the power transfer capacity would increase to about 4290MW.

6.3 India-Myanmar

(i) Present interconnection

- About 2-3 MW power is being supplied to Tamu (Myanmar) from Moreh (Manipur) 33/11kV, 5MVA substation through 11kV line in radial mode.

(ii) Planned interconnection

- Imphal (India) - Tamu (Myanmar) high capacity AC line along with 2x500MW HVDC back-to-back
- Nampong (Arunachal Pradesh, India) - Pansong (Myanmar) 11kV S/c radial line
- Behiang (Manipur, India) - Cikha (Myanmar) 11kV S/c radial line
- Zokhawthar (Mizoram, India) - Rikhawdar (Myanmar) 11kV S/c radial line
- Various 11kV S/c lines from Nagaland, India to Myanmar

6.4 India-Nepal

(i) Present interconnection

- 1000MW can be transferred from India to Nepal through following links in radial mode of operation:
 - *About 350MW through 132kV & below radial lines*
 - *About 650MW of power through the first high-capacity link i.e., 400kV D/c Dhalkebar (Nepal) – Muzaffarpur (India) line.*

(ii) Under Construction interconnection

- Additional 1800MW can be transferred from Nepal to India through following links:
 - Sitamarhi (POWERGRID) – Dhalkebar (Nepal) 400kV D/c (Quad) line (associated with Arun-3 HEP, Nepal): Expected by Apr 2023.
 - Gorakhpur (India) – New Butwal (Nepal) 400kV D/c (Quad) line: Requisite approvals are being obtained to take up implementation.

(iii) Planned interconnection

- New Purnea (India) - New Duhabi (Nepal) 400kV (Quad) D/c line

- Bareilly New (India) - Lumki (Nepal) 400kV (Quad) D/c line
- Lucknow (India) – Kohalpur (Nepal) 400kV (Quad) D/c line
- 2nd circuit stringing of Raxaul (India) - Parwanipur (Nepal) 132kV S/c on D/c line
- 2nd circuit stringing of Kataiya (India) - Kusaha (Nepal) 132kV S/c on D/c line
- Nanpara (India) - Kohlapur (Nepal) 132kV D/c line
- New Nautanwa (India) - Mainhiya (Nepal) 132kV D/c line

6.5 India-Sri Lanka

(i) Planned interconnection

- New Madurai – New Habarana 1000MW HVDC Bipole line


The cross-border transmission capacity of India with neighbouring countries in present time-frame and through under construction interconnections is summarized below:

Table 6.5-1: Cross-border power transfer capacity

Country	Existing (MW)	Under Construction (MW)	Planned (MW)	Total (MW)
India-Bangladesh	1160	0	1000	2160
India-Bhutan	2070	2220	0	4290
India-Myanmar	3	0	1000	1003
India-Nepal	1000	1800	4670	7470
India-Sri Lanka	0	0	1000	1000
Total	4233	4020	7670	15923

A schematic of the existing, under-construction and proposed cross-border interconnections is given below:

Figure 6.5-1: Cross-Border interconnections



Chapter 7: Study Results

Based on the load-generation balance scenarios, studies have been carried in PSSE for identification of power flow patterns across various regions as per the various generations available to meet the load in the identified scenarios. Detailed analysis is explained in section below.


7.1 Inter-Regional system





Inter-regional flows across various regions based on simulation studies are shown below in schematics at Figure 7.1-1 and the same are also summarised at Table 7.1-1 for all the nine scenarios. Max and Min flows in each IR corridor are highlighted in table below.


Table 7.1-1: IR flow summary

IR Flows	Aug'24			Jun'24			Feb'25		
Scenario No.	1	2	3	4	5	6	7	8	9
Corridor	Solar Max	Peak Load	Off Peak	Solar Max	Peak Load	Off Peak	Solar Max	Peak Load	Off Peak
WR-NR	-2161	16217	15585	-2175	20143	15527	-18209	4124	209
ER-NR	-8817	-2963	-1362	-7529	1028	-665	-5165	2254	1109
ER-WR	-6329	-6862	-6793	-7646	-6351	-8200	-3850	-3556	-3687
ER-SR	2030	592	852	1826	1554	1504	5208	3978	4368
WR-SR	-2997	-8560	-7276	-5008	-6964	-7126	8602	5177	8100
NER-ER	-229	69	-286	-40	-2288	19	-754	-300	-678

Figure 7.1-1: Inter-regional flows in nine scenarios







From the above it can be observed that:

- Power on WR-NR corridor is flowing in both directions in different scenarios. Maximum power of the order of 20 GW is flowing from WR to NR in June evening peak scenario whereas maximum power flow of the order of 18 GW is flowing from NR to WR in February solar max scenario.
- Power on ER-NR corridor is flowing from NR to ER in solar max scenarios with maximum power of about 9 GW.

- Power on ER-WR corridor is always flowing from WR to ER with maximum flow of 8 GW and minimum flow of 3.5 GW.
- Power on ER-SR corridor is also flowing towards SR in all the scenarios with maximum flow of 5 GW and minimum flow of 0.6 GW.
- Power on WR-SR is flowing towards WR in Monsoon and summer season with a maximum flow of 8 GW whereas in winter season power is flowing towards SR with maximum flow of 8 GW.

Each IR corridor comprises of multiple 765 kV, 400 kV, 220 kV, HVDC transmission System between the regions and each tie line has power flow limit. Critical loading patterns of these tie lines under various scenarios are indicated in **Annex-7.1.1** Further to analyse the power flow violation on these tie lines two power ratings were considered. Power flow exceeding the thermal limit are highlighted in yellow in the said annexure. It is observed that the most of these ties are loaded well within their design limit except for few 400kV and 220kV lines emanating from Rajasthan towards Western Region which are critically loaded and the same are listed below. Detailed studies are being carried out to mitigate the same.


Table 7.1-2: Critically loaded IR lines summary

400kV	220kV
Bhinmal - Zerda S/c	Modak - Bhanpura S/c
Kankroli - Zerda S/c	Sakatpur - Bhanpura S/c
RAPS - Shujalpur D/c	Sahupuri - Pausuali D/c

7.2 Transformation Capacity

In the time frame under study, there would be about 300 nos. of 765/400 kV transformer at 108 nos. of 765/400 kV substations. From simulation studies loading patterns of these transformers are tabulated and loading more than 80% of their rating in any scenarios are highlighted in **Annex-7.2**. Number of ICT's along with substation locations of above analysis are depicted in figure 7.2-1.


Figure 7.2-1: 765/400kV ICT Loading under base case



Maximum number of transformers loaded above 80% of MVA rating are in solar max scenarios i.e. 1, 4 and 7 with 21, 22 and 16 transformers respectively located at 6 nos. of different substations.

Similar analysis was carried out for 400/220 kV transformers. There are 1841 nos. of transformer located at about 663 nos. of 400/220kV stations.

Figure 7.2-2: 400/220kV ICT loading under Base Case



Under solar max scenarios viz. Scenarios 1, 4 and 7 about 53, 50 and 55 transformers respectively located at 11-12 nos. of different substations are loaded above 80% of MVA rating. The need for augmentation would depend upon the number of transformers, parallel paths availability etc. Hence simulation with contingencies is discussed in subsequent sections.

7.3 765kV and 400kV Transmission System

All the ISTS and Intra-state 765 kV and 400 kV lines were monitored for any possible overloading in the base case prepared for nine number of scenarios. There are about 275 nos. of 765 kV lines and about 2217 nos. of 400 kV lines. Line flow pattern of these lines in all scenarios are tabulated and flows exceeding the 70% of thermal limit are highlighted at **Annex-7.3**. Summary of the results is shown below:

Figure 7.3-1: 765kV Tr. line flow > 70% of thermal limit under base case





Figure 7.3-2: 400kV Tr. line flow > 70% of thermal limit under base case



Power flow on two nos. of 765kV lines viz. Narela – Meerut and Sikar (New) – Bhadla-3 are greater than 70% of thermal limit in base case itself. About 30, 36 and 34 nos. of 400 kV lines in Scenarios-1, 4, and 7 (Solar max scenarios) respectively are loaded above 70% of the thermal limit. Accordingly, detailed contingency studies have been carried out in subsequent section.

7.4 Contingency Studies

N-1 Contingency analysis has been performed on all the 765 kV & 400kV transmission lines, and 765/400 kV & 400/220 kV transformers. Major observations are discussed below:

7.4.1 Transformers

Number of substations where ICTs are loaded above 90% and 100% of MVA rating under N-1 contingency are depicted below. Detailed results are attached at **Annex-7.4.1**.

Figure 7.4-1: 765/400kV ICT loading $\geq 90\%$ of MVA rating under N-1 Contingency







Figure 7.4-2: 765/400kV ICT loading $\geq 100\%$ of MVA rating under N-1 Contingency



Maximum number of transformers exceeding the loading greater than MVA rating under N-1 contingency in each of the seasons are corresponding to Solar max scenarios viz. Scenarios-1, 4 and 7. Majority of these substations are RE pooling stations where ICTs have been planned considering N-0, as per Manual on Transmission Planning Criteria. The 13 locations corresponding to Scenario-4 where ICT loading violations have been observed are Narendra (New), Bhiwani (PG), Adoni, Fatehgarh-II & III, Khavda-I, II & III, Kolhapur (PG), Sikar (New), Jeerat (New), Moga (PG), Narela. Thus, detailed studies are being carried out to plan for remedial measures.

Figure 7.4-3: 400/220kV ICT loadings $\geq 90\%$ of MVA rating under N-1 ContingencyFigure 7.4-4: 400/220kV ICT loadings $\geq 100\%$ of MVA rating under N-1 Contingency

Maximum number of transformers exceeding the loading greater than MVA rating under N-1 contingency in each of the seasons are corresponding to Solar max scenarios viz. Scenarios-1, 4 and 7. Majority of these substations are RE pooling stations where ICTs have been planned considering N-0, as per Manual on Transmission Planning Criteria. Thus, some 38 no. of substations requires ICT augmentation, which are being studied.

7.4.2 Transmission Lines

765kV line loadings beyond 3000 MW under N-1 was assessed first. Thereafter, to carry out a sensitivity analysis, number of lines loaded beyond 3200 MW and 3500 MW under N-1 contingency were also identified. The list of such lines is at **Annex- 7.4.2** and the same has been summarise below.

Figure 7.4-5: 765kV Tr. line loadings>3000MW under N-1 Contingency




Figure 7.4-6: 765kV line loading > 3200 MW under N-1 Contingency





Figure 7.4-7: 765kV line loading > 3500 MW under N-1 Contingency



Max no. of 765kV lines on which loadings exceed limits of 3000 MW, 3200 MW and 3500 MW are 8, 6 and 4 respectively, which are Solar max scenarios. The most critical 765kV lines are Bhuj Pool – Khavda-I, Khavda-II – Lakadia, Jhatikara – Khetri, Bhadla-3 – Sikar New, which are being looked into in the further studies.

Further, for 400kV transmission lines, loading greater than 90% and 100% of thermal limit under N-1 Contingency has been assessed the results are at **Annex-7.4.2**. The results are summarised below.

Figure 7.4-8: 400kV line loading > 90% of thermal limit





Figure 7.4-9: 400kV line loading > thermal limit under N-1 Contingency




Max no. of 400kV lines on which loadings exceeds 90% and 100% of thermal limit are 56 and 38 respectively in Solar max scenarios. Further, detailed analysis and studies are being carried to plan additional systems, if any.

7.5 Reactive Compensation Studies

Injection of high quantum of RE into the grid is a challenge. It is expected that within the same day power flow on number of lines would change directions. Transmission lines associated with thermal and hydro generations would be generally lightly loaded during Solar max scenarios. Even though adequate reactive compensation is planned in the form of switchable line reactors, bus reactors, STATCOMs, SVCs at the time of inception of transmission projects, impact of various shunt devices on voltages at all EHV nodes in all the scenarios have been analysed.

Voltages of all the 765 kV and 400 kV buses were observed in all the 9 scenarios. Maximum and minimum voltages of each node was identified from nine voltages observed from nine number of study scenarios. Voltage violation have been reported considering voltage regulation limit of ± 0.05 p.u. from nominal voltage. Maximum and minimum voltage for each bus among all nine scenarios was identified. If the maximum voltage was found to be ≥ 1 p.u., the maximum voltage of the bus has been considered for that bus. For remaining buses, minimum voltage has been considered. Results of the analysis is plotted below:

Figure 7.5-1: Bus voltages at 765kV and 400kV levels within and outside regulation limits




From the above voltage plots it can be observed that bus voltages at around 70-80% of the buses at 765 kV as well as at 400 kV levels are in the range of 0.95 to 1.05 p.u. on all India basis considering all the scenarios. There are around 35 nodes at 765 kV level and 199 nodes at 400 kV level having bus voltage beyond 1.05 p.u. in any one of the scenarios. Voltages under various study scenarios are at **Annex-7.5**.

7.5.1 765 kV Nodes

The above violations have further been analysed regions and the results are plotted below:

Figure 7.5-2: Regions wise bus voltages at 765kV level within and outside regulation limits




From the above 765kV regional voltage plots it can be observed that voltage of majority of buses are within 0.95 to 1.05 p.u. range. However, few buses viz. 22, 5, 3 and 4 nos. located in NR, WR, SR, and ER respectively are having bus voltages beyond 1.05 p.u. in any one of the scenarios. Similarly, around 14, 7, and 2 nos. buses located in NR, WR, and ER respectively are having voltages lower than 0.95 p.u. in any one of the scenarios.

7.5.2 400 kV Nodes

The above violations have further been analysed regions and the results are plotted below:

Figure 7.5-3: Regions wise bus voltages at 400kV level within and outside regulation limits



From the above 400kV regional voltage plots it can be observed that around 38% (71 nos.) buses are facing high voltage issue in ER followed by 31% (15 nos.) buses in NER.

About 75 to 80% of bus voltages are found to be within the range and with the opening of transmission lines emanating from non-generating power stations and few of the grid lines on case to case basis, the voltage control may be managed.

Based on the above, detailed analysis has been carried to ascertain the degree of reactive power compensation in the ISTS and identify the need for augmentation of the same, if any. In this regard, no load MVar generated by 400kV and 765kV ISTS lines along with the compensation provided for present and for 2024-25 timeframe has been assessed region wise and the same is plotted at Figure 7.5-1 to 7.5-4 below:

Figure 7.5-4: Compensation in 765kV Lines - Present time frame




Figure 7.5-2: Reactive Compensation in 765kV ISTS lines - 2024-25 time frame




Figure 7.5-3: Compensation in 400kV Lines - Present Time Frame





Figure 7.5-4: Reactive Compensation in 400kV ISTS lines 2024-25 Time Frame




From the above, it may be observed that both in present and 2024-25 time-frame the degree of compensation in 765kV ISTS is beyond 85% in all regions, and even more than 100% in NR. At 400kV level, the degree of compensation in ISTS is more than 80-85% both in present and in 2024-25 time-frame in NR, WR, and ER, whereas the same in SR is about 60-65%. Accordingly, further studies are being carried out to plan additional reactive compensation, if any.

Similar analysis needs to be carried out for the EHV network of STUs as the ISTS and STU networks are integrated and affect each other.

7.6 Short Circuit Studies


Short circuit level was calculated for all the 765 kV and 400 kV buses on all India basis. For conducting the short circuit studies, sub transient reactance (X_d'') has been used for all thermal and hydro machines. Fault contribution from solar PV plants is limited to 1 p.u. as per various inverter capabilities during the studies. After finding the fault current for all buses comparison with design fault current level was done. The figures below show the number of 765 kV and 400 kV buses exceeding the design fault current rating under different scenarios. The details about the buses exceeding design fault current limit under various scenarios are attached at **Annex-7.6.1**.

Figure 7.6-1: 765kV and 400kV buses fault level violations



From the above charts it may be observed that number of fault level violations are highest in February (Winter) scenario i.e. Scenario-7, 8, and 9. While identifying the reason for the same it has been observed that number of thermal machines on bar are maximum in February scenario, hence fault contribution from these machines shall be maximum under these scenarios. Accordingly, Scenario-8 of February is chosen to identify the number of violation taking place at ISTS/STU/Gen buses and same is represented below:

Figure 7.6-2: Fault level > Design level of Substations



It may be observed that designed fault level is being violated at 6 and 44 number of 765kV and 400kV ISTS buses respectively. Details in this regard are attached at **Annex.7.6.2**.

Generally, the switchgears in Indian power system at EHV level are rated for 40kA, 50kA, and 63kA. ISTS and STU buses experiencing highest fault level among 40kA, 50kA, and 63kA rated systems are tabulated below:

Table 7.6-1: Top fault level violations in ISTS and STU

		ISTS	STU
765kV	40kA	Bilaspur, WR: 44kA	Jaipur, NR: 41kA
	50kA	Jabalpur Pool, WR: 51kA	-
400kV	40kA	Meerut, NR: 63kA	Kudus, WR: 55kA
	50kA	Padge GIS, WR: 53kA	Maheshwaram, SR: 63kA
	63kA	Maheshwaram, SR: 63kA	-

Page intentionally left blank.

Chapter 8: Conclusion

Power scenario of the country is continuously changing as more and more RE is getting integrated into the grid. It is envisaged that RE is going to be the major source of energy in future. Govt of India is envisaging installed capacity of 500GW of non-fossil fuel based generations by 2030. Towards this, large RE complexes are expected to be established in Northern, Western, and Southern regions by 2024-25 timeframe. The transmission system for integrating the same into the grid has already been planned. In particular, large RE complexes are anticipated to be come up in two states viz. Rajasthan (20 GW) and Gujarat (15 GW).

As substantial RE generation addition has been envisaged in Rajasthan, this has resulted in NR becoming exporter of power during the afternoon Solar max period and importer during the evening peak demand period. Similar situations are also observed for other regions as well. To study such seasonal and diurnal variations of RE generations and demand, load generation balance was prepared for three seasons (Monsoon, Summer, and Winter) in a year with three points (Solar max, Evening peak demand, and Night off-peak demand) on daily load curve for each season. Maximum and minimum all India demand of 266 GW and 179 GW have been considered while working out the LGBs. Out of these nine scenarios, three scenarios viz. highest RE generation (Scenario-1), highest all India demand (Scenario-5) and lowest all India demand (Scenario-9) are the most critical ones from transmission planning point of view.

While preparing the LGB it was observed that to dispatch maximum RE generation during the noon time, on bar thermal units are required to meet evening peak demand are to be operated below the present technical minimum of 55%. As per the analysis it was found that technical minimum of 27% and 28% during Monsoon and Summer seasons respectively is required for keeping the same number of thermal units on bar throughout the day. If Thermal units are to be operated at 55% of technical minimum during the Solar max period, then 49 GW, 45 GW and 13 GW of surplus thermal generation would be available in Monsoon, Summer and Winter season respectively after meeting the all India demand in 2024-25 time-frame. If technical minimum of thermal units is reduced to 40%, then surplus generation reduces to 29 GW and 19 GW in Monsoon and Summer seasons respectively. This study also highlights the need for about 29 GW of energy storage in the grid to facilitate the RE integration of the order of 210 GW by 2024-25.

Presently, quantum of energy and peak demand met by RE as compared to total requirement is quite less. As the quantum of RE generation increases, the contribution of RE energy to total requirement would increase. However, with integration of large RE the challenge of operating the thermal units at lower technical minimum would also come to forefront. Solar PV generation shall reduce the energy output of thermal generation and during Solar max period thermal generation may be required to be used alternatively or plants may need to be run at low despatch. In order to absorb surplus energy in the grid during Solar max scenario, BESS would be required for grid operation.

Load flow including N-1 contingency studies have been conducted for all scenarios to check and analyse the power flow pattern on EHV transmission lines and transformers. During the studies it was observed that most of the transmission lines and transformers loading are within limits except for few cases which are highlighted in report and are being taken care of in subsequent transmission planning exercise.

Bus voltages at 765kV and 400kV have also been analysed for all the scenarios and voltages beyond the permissible limits are highlighted in the report. About 75 to 80% of bus voltages are found to be within the range and with the opening of transmission lines emanating from non-generating power stations and few of the grid lines on case to case basis, the voltage control may be managed. Nevertheless, more reactive power management devices are also being planned for installation in high voltage areas.

Short circuit studies at 765kV and 400kV have also been performed on all the scenarios and fault MVA violations beyond the design rating are also highlighted in the report. Fault level at many of the 400 kV buses including the STU and generating station buses are beyond the limits. Measures like bus split and incorporating series reactor to control the fault MVA level is under planning at ISTS buses. However, same also needs to be taken up at STU and generating station level by respective utilities.

In summary, existing and planned transmission network is found to be adequate for meeting the demand and integrating anticipated generation to be commissioned by 2024-25 timeframe. Further, basic health network parameters of the Indian grid are within their operating limits except for few cases which are being studied in detail and necessary augmentation plan will be published in the subsequent Network Plan report.

Annexures

Page intentionally left blank.

Annex-2.1

Retirement of Installed Capacity by 2025

Sl. No.	Region	State	Fuel	Project Name	Unit	IC (MW)	To be Retired Capacity (MW)	Status (Ex/UC)	Utility
1	WR	MP	T	Satpura-II	1x200+1x210	410	410	Ex	State
2	WR	Chhattisgarh	T	Korba (E)	4x50+2x120	440	200	Ex	State
3	WR	Chhattisgarh	T	Korba (W)	4x210+1x500	1340	840	Ex	State
4	WR	Maharashtra	T	Koradi	2x210	420	420	Ex	State
5	WR	Maharashtra	T	Gupta Energy Ltd	2x60	120	120	Ex	State
6	ER	Odisha	T	IBEUL U-1	(2x350)	700	700	Ex	IPP
7	ER	Bihar	T	Barauni	(2x110)	220	220	Ex	State
8	ER	Bihar	T	Muzaffarpur	(2x110)	220	220	Ex	State
9	ER	Jharkhand	T	Tenughat	(2x210)	420	420	Ex	State
10	ER	Jharkhand	T	Bokaro'B'	(1x210)	210	210	Ex	Central
11	ER	West Bengal	T	Bandel	(4x82.5+1x210)	540	540	Ex	State
12	ER	West Bengal	T	Bakreshwar	(5x210)	1050	1050	Ex	State
13	ER	West Bengal	T	Titagarh	(4x60)	240	240	Ex	State
14	SR	Andhra Pradesh	T	Vijayawada	6 X 210	1260	1260	Ex	State
15	SR	Telangana	T	Kothagudem A B C	4 X 60 + 4 X 120	720	720	Ex	State
16	SR	Telangana	T	Kothagudem D (V Stage)	2 X 250	500	500	Ex	State
17	SR	Telangana	T	Ramagundam B	1 X 62.5	62.5	63	Ex	State
18	SR	Karnataka	T	Raichur	7 X 210 + 1 x 250	1720	1720	Ex	State
19	SR	Tamil Nadu	T	Tuticorin	5 X 210	1050	1050	Ex	State
20	SR	Tamil Nadu	T	Mettur	4 X 210	840	840	Ex	State
21	SR	Tamil Nadu	T	Neyveli -I NLC	6x50 + 3X100	600	600	Ex	State
22	SR	Tamil Nadu	T	Neyveli Zero (STCMS)	1 X 250	250	250	Ex	State
23	SR	Tamil Nadu	T	North Chennai	3x210 + 2 x 600	1830	630	Ex	State
24	SR	Tamil Nadu	T	NLC TPS-I Exp.	2X210	420	420	Ex	Central
25	NR	UP	T	Tanda TPS	4x110	440	440	Ex	Central

Sl. No.	Region	State	Fuel	Project Name	Unit	IC (MW)	To be Retired Capacity (MW)	Status (Ex/UC)	Utility
26	NR	Haryana	T	Panipat	2x210+2x250	920	420	Ex	State
27	NR	Punjab	T	Guru Gobind Singh TPS Ropar	6x210	1260	1260	Ex	State
28	NR	Punjab	T	Lehra Mohabbat TPS	2x210+2x250	920	420	Ex	State
29	NR	Rajasthan	T	Kota TPS	2x110+3x210+2x195	1240	850	Ex	State
30	NR	UP	T	Obra A	2x50+1X94	194	194	Ex	State
31	NR	UP	T	Harduaganj - B	1x60+1x105	165	165	Ex	State
32	NR	UP	T	Paricha - A,B,C	2x110+2x210+2x250	1140	220	Ex	State
					Total	21862	17612		

Annex-2.1

Load Generation Balance (LGB)

Monsoon (Aug'24)

Installed Capacity	Regional	Central	State	Private	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total	EPS Peak	Peak Demand	LTA	
	NR	11440	39616	0	51056	22576	4420	58641	4500	6401	1360	0	3956	152910	86778	81520	0	
	WR	19000	35785	36985	91770	8168	3240	34022	4500	31068	0	0	10004	182772	84502	79382	0	
	SR	11000	29775	6640	47415	11922	3320	28541	4500	32532	2864	1185	2985	135263	74666	70142	0	
	ER	24440	12165	4500	41105	8182	0	250	400	0	0	0	0	49937	32319	30361	0	
	NER	750	133	0	883	4816	0	100	100	0	0	0	0	1821	7720	5439	0	
		66630	117474	48125	232229	55663	10980	121554	14000	70001	4224	1185	18765	528601	266844	266844		
		232229						209778							284055		114755	
Scenario 1 : Solar Max Aug 2024	Available	Central	State	IPP	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas		National	Regional	DF	
	NR	25%	9%	0%	16%	70%	80%	90%	50%	50%	0%	0%	0%		82%	77%		
	WR	30%	3%	18%	13%	40%	80%	80%	50%	55%	0%	0%	0%		76%	72%		
	SR	21%	2%	45%	15%	40%	80%	80%	50%	55%	0%	0%	0%		74%	70%		
	ER	13%	14%	42%	9%	70%	80%	80%	50%	0%	0%	0%	0%		83%	78%		
	NER	0%	0%	0%	0%	70%	80%	80%	50%	0%	0%	0%	0%		69%	65%		
		21%	6%	24%	14%										83%	221481		
	Available	Central	State	IPP	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE PPO	Diesel	Gas	Total available	Demand	Surplus/	Net Available	Net Demand
	NR	2888	3408	0	8334	15803	3536	52777	2250	3201	43170	0	0	83862	70843	13019	81612	68593
	WR	5687	1238	6659	12207	3267	2592	27218	2250	17087	46440	0	0	65998	64506	1492	63748	62256
	SR	2255	537	2992	7137	4769	2656	22832	2250	17893	40852	0	0	56184	55414	770	53934	53164
	ER	3080	1690	1898	3793	5727	0	200	200	0	15612	0	0	12795	26727	-13932	12595	26527
	NER	0	0	0	0	3371	0	80	50	0	2213	0	0	3501	3990	-489	3451	3940
	Total	13910	6873	11549	31471	32938	8784	103107	7000	38181	148288	0	0	370628	221481	860	215340	214481
			32331						148287							208899		
		21% State	Th															
Scenario 2 : Peak load Aug 2024	Available	Central	State	IPP	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas		National	Regional	DF	
	NR	69%	53%	0%	65%	95%	80%	0%	0%	70%	0%	0%	85%		88%	83%		
	WR	59%	37%	50%	37%	70%	80%	0%	0%	75%	0%	0%	85%		80%	75%		
	SR	21%	73%	45%	62%	70%	80%	0%	0%	75%	0%	0%	85%		76%	72%		
	ER	18%	62%	67%	42%	90%	80%	0%	0%	0%	0%	0%	85%		97%	91%		
	NER	0%	0%	0%	0%	90%	80%	0%	0%	0%	0%	0%	85%		93%	88%		
		39%	54%	51%	49%										89%	237491		
	Available	Central	State	IPP	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE PPO	Diesel	Gas	all available	Demand	Surplus/	Net Available	Net Demand
	NR	7867	20972	0	32941	21447	3536	0	0	4481	15191	0	3363	61666	76477	-14812	61666	76477
	WR	11175	13161	18372	34139	5717	2592	0	0	23301	16342	0	8503	82822	67294	15529	82822	67294
	SR	2255	21646	2992	29168	8345	2656	0	0	24399	14375	0	2537	64830	57082	7748	64830	57082
	ER	4367	7535	3026	17120	7364	0	0	0	0	5494	0	0	22291	31228	-8937	22291	31228
	NER	0	0	0	0	4334	0	0	0	0	779	0	1548	5882	5410	472	5882	5410
	Total	25664	63314	24389	113368	47208	8784	0	0	52181	52181	0	15950	237491	237491	0	237491	237491
			113368						52181							223667		
		56% State	Th															
Scenario 3 : off peak load Aug 2024	Available	Central	State	IPP	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas		National	Regional	DF	
	NR	73%	50%	0%	68%	70%	80%	0%	0%	60%	0%	0%	65%		80%	75%		
	WR	63%	33%	50%	35%	40%	80%	0%	0%	65%	0%	0%	65%		70%	65%		
	SR	25%	55%	58%	53%	40%	80%	0%	0%	65%	0%	0%	65%		63%	59%		
	ER	28%	48%	67%	41%	70%	80%	0%	0%	0%	0%	0%	65%		88%	82%		
	NER	0%	0%	0%	0%	70%	80%	0%	0%	0%	0%	0%	65%		72%	67%		
		45%	46%	52%	47%										78%	208138		
	Available	Central	State	IPP	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE PPO	Diesel	Gas	all available	Demand	Surplus/	Net Available	Net Demand
	NR	8329	19848	0	34604	15803	3536	0	0	3841	13153	0	2571	53928	69667	-15740	53928	69667
	WR	11991	11959	18372	32284	3267	2592	0	0	20194	14149	0	6502	74877	58795	16082	74877	58795
	SR	2705	16287	3867	25344	4769	2656	0	0	21146	12447	0	1940	53370	47156	6215	53370	47156
	ER	6829	5827	3026	16807	5727	0	0	0	0	4757	0	0	21409	28368	-6959	21409	28368
	NER	0	0	0	0	3371	0	0	0	0	674	0	1183	4555	4153	402	4555	4153
	Total	29854	53920	25264	109039	32938	8784	0	0	45181	45181	0	12197	208138	208138	0	208138	208138
			109039						45181							194444		
		49% State	Th															

Summer (Jun'24)

Installed Capacity	Regional	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total	EPS Peak	Peak Demand	LTA		
	NR	11440	39616	0	51056	22576	4420	58641	4500	6401	1360	0	3956	152910	86778	81520		0		
	WR	19000	35785	36985	91770	8168	3240	34022	4500	31068	0	0	10004	182772	84502	79382		0		
	SR	11000	29775	6640	47415	11922	3320	28541	4500	32532	2864	1185	2985	135263	74666	70142		0		
	ER	24440	12165	4500	41105	8182	0	250	400	0	0	0	0	49937	32319	30361		0		
	NER	750	133	0	883	4816	0	100	100	0	0	0	0	1821	7720	5790	5439		0	
		66630	117474	48125	232229	55663	10980	121554	14000	70001	4224	1185	18765	528601	266844	266844				
	232229							209778							284055		114755			
Scenario 4 : Solar Max Jun 2024	Availability	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total available	National Demand	Regional Demand	DF		
	NR	26%	16%	0%	25%	70%	80%	90%	60%	50%	0%	0%	0%	0%		88%	83%			
	WR	40%	4%	36%	24%	40%	80%	85%	60%	55%	0%	0%	0%	0%		89%	84%			
	SR	49%	4%	55%	21%	40%	80%	85%	60%	55%	0%	0%	0%	0%		80%	75%			
	ER	13%	15%	42%	8%	70%	80%	85%	60%	0%	0%	0%	0%	0%		84%	79%			
	NER	0%	0%	0%	0%	70%	80%	85%	60%	0%	0%	0%	0%	0%		64%	60%			
		29%	9%	39%	21%											91%	242828			
	Availability	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE RPO	Diesel	Gas	Total available	Demand	Surplus/Deficit	Net Availability	Net Demand	
	NR	3029	6188	0	12873	15803	3536	52777	2700	3201	44494		0	0	87233	76706	10527	84533	74006	
	WR	7568	1409	13280	21871	3267	2592	28919	2700	17087	47863		0	0	76822	75594	1228	74122	72894	
	SR	5367	1243	3652	10109	4769	2656	24260	2700	17893	42104		0	0	62539	59638	2901	59839	56938	
	ER	3080	1792	1898	3420	5727	0	213	240	0	16091		0	0	12949	27191	-14242	12709	26951	
	NER	0	0	0	0	3371	0	85	60	0	2281		0	0	3516	3700	-184	3456	3640	
	Total	19044	10631	18829	48273	32938	8784	106253	8400	38181	152833		0	0	243059	242828	231	234659	234428	
	48505							152833							228013					
	22% State Thermal																			
Scenario 5 : Peak Load Jun 2024	Availability	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total available	National Demand	Regional Demand	DF		
	NR	73%	68%	0%	92%	95%	80%	0%	0%	70%	0%	0%	0%	85%		104%	98%			
	WR	71%	52%	72%	46%	70%	80%	0%	0%	75%	0%	0%	0%	85%		90%	84%			
	SR	55%	72%	62%	75%	70%	80%	0%	0%	75%	0%	0%	0%	85%		85%	80%			
	ER	28%	62%	67%	42%	90%	80%	0%	0%	0%	0%	0%	0%	85%		99%	93%			
	NER	0%	0%	0%	0%	90%	80%	0%	0%	0%	0%	0%	0%	85%		83%	78%			
		52%	63%	70%	61%											100%	266844			
	Availability	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE RPO	Diesel	Gas	Total available	Demand	Surplus/Deficit	Net Availability	Net Demand	
	NR	8329	26804	0	47116	21447	3536		0	0	4481	15191		0	3363	67960	90653	-22693	67960	90653
	WR	13431	18505	26658	42510	5717	2592		0	0	23301	16342		0	8503	98708	75664	23044	98708	75664
	SR	6050	21440	4114	35760	8345	2656		0	0	24399	14375		0	2537	69541	63673	5868	69541	63673
	ER	6829	7535	3026	17335	7364		0	0	0	5494		0	0	24753	32040	-7287	24753	32040	
	NER	0	0	0	0	4334		0	0	0	779		0	1548	5882	4814	1068	5882	4814	
	Total	34639	74284	33798	142721	47208	8784		0	0	52181	52181		0	15950	266844	266844	0	266844	266844
	142721							52181							250330					
	52% State Thermal																			
Scenario 6 : Off peak Load Jun 2024	Availability	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total available	National Demand	Regional Demand	DF		
	NR	69%	63%	0%	79%	70%	80%	0%	0%	60%	0%	0%	0%	60%		86%	81%			
	WR	68%	47%	69%	48%	40%	80%	0%	0%	65%	0%	0%	0%	60%		83%	78%			
	SR	55%	61%	62%	67%	40%	80%	0%	0%	65%	0%	0%	0%	60%		71%	67%			
	ER	27%	43%	67%	37%	70%	80%	0%	0%	0%	0%	0%	0%	60%		84%	79%			
	NER	0%	0%	0%	0%	70%	80%	0%	0%	0%	0%	0%	0%	60%		62%	58%			
		50%	56%	68%	57%											86%	229486			
	Availability	Central	Thermal	State Thermal	Private Thermal	Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE RPO	Diesel	Gas	Total available	Demand	Surplus/Deficit	Net Availability	Net Demand	
	NR	7867	24961	0	40119	15803	3536		0	0	3841	13153		0	2374	58382	74985	-16603	58382	74985
	WR	12871	16829	25572	44303	3267	2592		0	0	20194	14149		0	6002	87327	70314	17013	87327	70314
	SR	6050	18199	4114	31705	4769	2656		0	0	21146	12447		0	1791	58724	53367	5357	58724	53367
	ER	6577	5259	3026	15198	5727		0	0	0	4757		0	0	20589	27237	-6648	20589	27237	
	NER	0	0	0		3371		0	0	0	674		0	1092	4464	3582	881	4464	3582	
	Total	33365	65248	32711	131325	32938	8784		0	0	45181	45181		0	11259	229486	229486	0	229486	229486
	131325							45181							215118					
	50% State Thermal																			

Winter (Feb'25)

Installed Capacity	Reg	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar Rooftop	Wind	Other Renewable	Diesel	Gas	Total	EPS Peak	Peak Demand	LTA	
	NR	11440	39616	0	51056	22576	4420	58641	4500	6401	1360	0	3956	152910	86778	81520	0		
	WR	19000	35785	36985	91770	8168	3240	34022	4500	31068	0	0	10004	182772	84502	79382	0		
	SR	11000	29775	6640	47415	11922	3320	28541	4500	32532	2864	1185	2985	135263	74666	70142	0		
	ER	24440	12165	4500	41105	8182	0	250	400	0	0	0	0	49937	32319	30361	0		
	NER	750	133	0	883	4816	0	100	100	0	0	0	1821	7720	5790	5439	0		
		66630	117474	48125	232229	55663	10980	121554	14000	70001	4224	1185	18765	528601	266844	266844			
		232229						209778							284055		114755		
Scenario 7 : Solar max Feb 2025	Avail	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total available	National Demand	Regional Demand	DF	
	NR	32%	34%	0%	28%	30%	80%	95%	60%	60%	10%	0%	0%	0%		70%	66%		
	WR	44%	29%	53%	44%	20%	80%	90%	60%	60%	10%	0%	0%	0%		99%	93%		
	SR	55%	47%	55%	66%	20%	80%	90%	60%	0%	0%	0%	0%	0%		94%	89%		
	ER	41%	26%	42%	16%	30%	80%	90%	60%	0%	0%	0%	0%	0%		69%	65%		
	NER	0%	0%	0%	0%	30%	80%	90%	60%	0%	0%	0%	0%	0%		55%	52%		
		42%	35%	52%	40%											90%	240160		
	Avail	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE RPO	Diesel	Gas	Total available	National Demand	Surplus/	Net Avail	Net Demand
	NR	3614	13379	0	14225	6773	3536	55709	2700	640	36239	0	0	0	86350	60773	25577	83650	58073
	WR	8448	10455	19616	40180	1634	2592	30620	2700	3107	38983	0	0	0	79171	83388	-4217	76471	80688
	SR	6050	13909	3652	31180	2384	2656	25687	2700	0	34293	0	0	0	57038	70513	-13475	54338	67813
	ER	10120	3107	1898	6623	2455	0	225	240	0	13105	0	0	0	18044	22291	-4247	17804	22051
	NER	0	0	0	0	1445	0	90	60	0	1858	0	0	0	1595	3195	-1600	1535	3135
	Total	28232	40850	25165	92208	14690	8784	112330	8400	3747	124477	0	0	0	242198	240160	2038	233798	231760
		94247						124477								226331			
	43%	State Thermal																	
Scenario 8 : Peak Load Feb 2025	Avail	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total available	National Demand	Regional Demand	DF	
	NR	73%	62%	0%	77%	60%	80%	0%	0%	0%	35%	0%	0%	85%		74%	70%		
	WR	71%	59%	85%	59%	40%	80%	0%	0%	0%	20%	0%	0%	85%		86%	82%		
	SR	59%	89%	76%	106%	40%	80%	0%	0%	0%	20%	0%	0%	85%		86%	82%		
	ER	65%	62%	67%	48%	60%	80%	0%	0%	0%	0%	0%	0%	85%		81%	77%		
	NER	0%	0%	0%	0%	60%	80%	0%	0%	0%	0%	0%	0%	85%		79%	75%		
		66%	68%	82%	70%											87%	232154		
	Avail	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE RPO	Diesel	Gas	Total available	National Demand	Surplus/	Net Avail	Net Demand
	NR	8329	24428	0	39158	13545	3536	0	0	2240	4355	0	0	3363	55442	63958	-8516	55442	63958
	WR	13431	21198	31416	53910	3267	2592	0	0	6214	4685	0	0	8503	86621	72957	13664	86621	72957
	SR	6500	26379	5056	50382	4769	2656	0	0	6506	4121	0	0	2537	54403	64465	-10062	54403	64465
	ER	15782	7535	3026	19630	4909	0	0	0	0	1575	0	0	0	31251	26202	5049	31251	26202
	NER	0	0	0	0	2890	0	0	0	0	223	0	0	1548	4437	4572	-135	4437	4572
	Total	44042	79540	39497	163079	29380	8784	0	0	14960	14960	0	0	15950	232154	232154	0	232154	232154
		163079						14960								220490			
	49%	State Thermal																	
Scenario 9 : Off peak Load Feb 2025	Avail	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	Other Renewable	Diesel	Gas	Total available	National Demand	Regional Demand	DF	
	NR	69%	43%	0%	51%	30%	80%	0%	0%	0%	10%	0%	0%	30%		46%	43%		
	WR	68%	53%	72%	54%	20%	80%	0%	0%	0%	20%	0%	0%	30%		70%	66%		
	SR	55%	80%	55%	94%	20%	80%	0%	0%	0%	0%	0%	0%	30%		70%	66%		
	ER	41%	41%	67%	36%	30%	80%	0%	0%	0%	0%	0%	0%	30%		54%	51%		
	NER	0%	0%	0%	0%	30%	80%	0%	0%	0%	0%	0%	0%	30%		42%	40%		
		55%	55%	69%	58%											64%	170780		
	Avail	Thermal	Central Thermal	Small Thermal	Small Private	Wind Thermal	Hydro	Nuclear	Solar	Solar rooftop	Wind	RE RPO	Diesel	Gas	Total available	National Demand	Surplus/	Net Avail	Net Demand
	NR	7867	16914	0	26050	6773	3536	0	0	640	1995	0	0	1187	36917	39541	-2624	36917	39541
	WR	12871	18937	26493	49726	1634	2592	0	0	6214	2146	0	0	3001	71742	59099	12643	71742	59099
	SR	6050	23950	3652	44396	2384	2656	0	0	0	1888	0	0	895	39588	52220	-12632	39588	52220
	ER	10120	4943	3026	14651	2455	0	0	0	0	722	0	0	20543	17466	3077	20543	17466	
	NER	0	0	0	0	1445	0	0	0	0	102	0	0	546	1991	2454	-463	1991	2454
	Total	36908	64744	33171	134823	14690	8784	0	0	6854	6854	0	0	5630	170780	170780	0	170780	170780
		134823						6854								161164			
	48%	State Thermal																	

Page intentionally left blank.

Annex 4.2

Inter-Regional Transmission Capacity (MW)

Transmission Line	Present	Capacity at the End Of 13th Plan
EAST - NORTH		
Dehri/Sasaram - Sahupuri 220kV S/c	130	130
Sasaram HVDC back-to-back	500	500
Muzaffarpur - Gorakhpur 400kV D/c (with Series Comp.+TCSC)	2000	2000
Patna - Balia 400kV D/c (Quad)	1600	1600
Biharshariff - Balia 400kV D/c (Quad)	1600	1600
Barh/Patna - Balia 400kV D/c (Quad)	1600	1600
Gaya - Balia 765kV S/c	2100	2100
Sasaram bypassing (additional capacity)	500	500
Sasaram - Fatehpur 765kV S/c	2100	2100
Barh-II/Motihari - Gorakhpur 400kV D/c (Quad)	1600	1600
Gaya-Varanasi 765kV 2xS/c	4200	4200
Biharsharif-Varanasi 400kV D/c (Quad)	1600	1600
LILO of Biswanath Chariali - Agra ± 800 kV HVDC Bipole at new pooling station in Alipurduar and addition of 3000MW module	3000	3000
Sub-total	22,530	22,530
EAST - WEST		
Budhipadar-Korba 220kV S/c	130	130
Budhipadar-Korba 220kV D/c	260	260
Rourkela/Jharsuguda - Raigarh/Raipur 400kV D/c (with Series Comp.+TCSC)	1400	1400
Ranchi - Sipat 400 kV D/c with series comp.	1200	1200
Rourkela/Jharsuguda - Raigarh/Raipur 400kV (2nd) D/c (with Series Comp.)	1400	1400
Ranchi - Dharamjayagarh/WR Pooling Station 765kV S/c	2100	2100
Ranchi - Dharamjayagarh 765kV (2nd) S/c	2100	2100
Jharsuguda - Dharamjayagarh 765kV D/c	4200	4200
Jharsuguda - Dharamjayagarh 765kV (2nd) D/c	4200	4200
Jharsuguda - Raipur Pool 765kV D/c	4200	4200
Sub-total	21,190	21,190

Transmission Line	Present	Capacity at the End Of 13th Plan
EAST - SOUTH		
Balimela - Upper Sileru 220kV S/c	130	130
Gazuwaka HVDC back-to-back	1000	1000
Talcher - Kolar HVDC bipole	2000	2000
Upgradation of Talcher-Kolar HVDC Bipole	500	500
Angul - Srikakulum 765kV D/c	4200	4200
Sub-total	7,830	7,830
EAST - NORTH EAST		
Birpara/Alipurduar - Salakati 220kV D/c	260	350
Siliguri - Bongaigaon 400kV D/c	1000	1600
Siliguri/Alipurduar - Bongaigaon 400kV D/c (Quad)	1600	1600
Sub-total	2,860	3,550
NORTH EAST - NORTH		
Biswanath Chariali - Agra ± 800 kV HVDC Bipole with 3000MW converter	3000	3000
Sub-total	3,000	3,000
WEST - NORTH		
Auriya - Malanpur 220kV D/c	260	260
Kota - Ujjain 220kV D/c	260	260
Vindhyachal HVDC back-to-back	500	500
Gwalier - Agra 765kV 2xS/c	4200	4200
Zerda - Kankroli 400kV D/c	1000	1000
Gwalior - Jaipur 765kV 2xS/c	4200	4200
Adani (Mundra) - Mahendranagar ± 500 kV HVDC bipole	2500	2500
RAPP - Sujalpur 400kV D/c	1000	1000
Champa Pool - Kurukshetra ± 800 kV HVDC Bipole	4500	4500
Jabalpur - Orai 765kV D/c	4200	4200
LILO of Satna - Gwalior 765kV S/c line at Orai	4200	4200
Upgradation of Champa Pool - Kurukshetra ± 800 kV HVDC Bipole	1500	1500
Banaskantha - Chittorgarh 765kV D/c	4200	4200
Vindhyachal - Varanasi 765kV D/c	4200	4200
Sub-total	36,720	36,720

Transmission Line	Present	Capacity at the End Of 13th Plan
WEST - SOUTH		
Chandrapur HVDC back-to-back	1000	1000
Kolhapur - Belgaum 220kV D/c	260	260
Ponda - Nagajhari 220kV D/c	260	260
Raichur - Sholapur 765kV S/c	2100	2100
Raichur - Sholapur 765kV (2nd) S/c	2100	2100
Narendra - Kolhapur 765kV D/c (operated at 400kV)	2200	2200
Wardha - Nizamabad 765kV D/c	4200	4200
Warora Pool - Warangal (New) 765kV D/c	-	4200
Raigarh - Pugulur ± 800 kV HVDC Bipole	6000	6000
LILO of Narendra - Narendra (New) 400kV (Quad) line at Xeldam (Goa)	-	1600
Sub-total	18,120	23,920
TOTAL	112,250	118,740
* Barsur (WR) – L. Sileru (SR) 220kV HVDC Monopole of 200MW capacity is currently not in operation.		

Page intentionally left blank.

Annex 4.1

ISTS Network Expansion Plan upto 2024-25

Transmission lines

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
1.	2021-22	WR	Bhuj PS – Lakadia PS 765 kV D/c line (215ckm)	765	D/c	214		
2.	2021-22	WR	LILO of Bhachau – EPGL 400 kV D/c (triple) line at Lakadia PS (40ckm)	400	D/c	76		
3.	2021-22	WR	Lakadia – Vadodara 765 kV D/c line (658ckm)	765	D/c	658	330	330
4.	2021-22	WR	Lakadia PS – Banaskantha PS 765 kV D/c line (352ckm)	765	D/c	352		240
5.	2021-22	WR	Reconfiguration of Bhuj PS – Lakadia PS 765 kV D/c line so as to establish Bhuj II – Lakadia 765 kV D/C line as well as Bhuj – Bhuj II 765 kV D/C line (80 ckm)	765	D/c	212	240	
6.	2021-22	WR	Extension of Essar – Lakadia / Bhachau 400 kV D/c (triple snowbird) line upto Jam Khambhaliya PS (80 ckm)	400	D/c	38	63	63
7.	2021-22	WR	Navsari (PG) – Bhestan 220 kV D/C line (with minimum capacity of 400MVA per circuit) (17ckm)	220	D/c	34		
8.	2021-22	WR	Dharamjaygarh Pool section B - Raigarh (Tamnar) Pool 765kV D/c line (140ckm)	765	D/c	137		
9.	2021-22	NR	LILO of both circuits of Bawana –Mandola 400kV D/c line at Maharanibagh on M/c tower with Twin HTLS conductor	400	M/c	120		
10.	2021-22	NR	LILO of one circuit of Bamnauli - Jattikalan 400kV line at Dwarka-I with Twin HTLS conductor	400	M/c	17		
11.	2021-22	NR	Mohindergarh – Bhiwani 400kV D/c Line	400	D/c	122		
12.	2021-22	NR	220kV D/c line from UT Chandigarh to 400/220kV Panchkula(PG) substati	220	D/c	50		
13.	2021-22	NR	LILO of both ckt. of 400 kV Dhauliganga-Bareilly (PGCIL) line (presently charged at 220 kV) at 400kV Jauljivi	400	D/c	6		
14.	2021-22	NR	Diversion of Dhauliganga-Bareilly 400kV D/c line (operated at 220kV) at Bareilly end from CB Ganj to Bareilly (PGCIL)	400	D/c	16		

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
15.	2021-22	NR	Disconnection of 220kV LILO arrangement of Dhauliganga-Bareilly at Pithoragarh and connecting it to Jauljivi 400/220kV S/s	220	D/c	24		
16.	2021-22	NR	Koteshwar Pooling Station - Rishikesh 400kV D/C (twin) line	400	D/c	83		
17.	2021-22	NR	Babai (RRVNL) – Bhiwani (PG) 400kV D/C line	400	D/c	221		
18.	2021-22	NER	Roing (POWERGRID) – Chapakhowa (AEGCL) 132kV D/c line along with associated bays	132	D/c	67		
19.	2021-22	NER	LILO of Palatana – Surajmaninagar (ISTS) 400kV D/c line at 400/132kV Surajmaninagar (TSECL) S/ s along with associated 4 no. 400kV line bays – In matching timeframe of upgradation of 400/132kV Surajmaninagar (TSECL) substation	400	D/c	12		
20.	2021-22	ER	LILO of 2nd circuit of Teesta III – Kishanganj 400kV D/c (Quad) line at Rangpo (24ckm)	400	D/c	24		
21.	2021-22	ER	LILO of both circuits of Kishanganj (POWERGRID) – Darbhanga (DMTCL) 400kV D/c (Quad) line at Saharsa-New (POWERGRID) – 41 km	400	D/c	82		
22.	2021-22	ER	Bypassing of Farakka – Kahalgaon (ckt-3 & ckt-4) and Farakka – Durgapur 400kV D/c lines of POWERGRID so as to form Kahalgaon – Durgapur 400kV D/c line – 3.17 km	400	D/c	6		
23.	2022-23	WR	Warora pool (Maharashtra) – Warangal(New) (Telangana) 765 kV D/c line	765	D/c	664		
24.	2022-23	WR	LILO of one ckt. of Narendra (existing) – Narendra (New) 400kV D/c quad line at Xeldem - 240ckm	400	D/c	187.35		
25.	2022-23	WR	Xeldem – Mapusa 400kV D/c (quad) line -80ckm	400	D/c	109.6		
26.	2022-23	WR	Xeldem (existing) - Xeldem (new) 220kV D/c line	220	D/c	40		
27.	2022-23	WR	LILO of the second circuit of Zerda – Ranchodpura 400 kV D/c line at Banaskantha (PG) PS	400	D/c	34.4		
28.	2022-23	WR	Re-conductoring of Kolhapur (PG)– Kolhapur 400 kV D/c line with conductor of minimum capacity of 2100 MVA/Ckt at	400	D/c	120		

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
			nominal voltage along with bay up-gradation work at Kolhapur (MSETCL). -60KM					
29.	2022-23	WR	LILO of Apta – Kalwa/Taloja 220kV D/c line (i.e. Apta – Kalwa and Apta – Taloja 220kV lines) at Navi Mumbai (PG)-2km	220	2xD/c	4		
30.	2022-23	SR	Re-conductoring of the NP Kunta – Kolar 400 kV S/c line (twin Moose) section with high capacity conductors (like twin HTLS equivalent or Quad Moose).	400	S/c	131		
31.	2022-23	SR	Mangalore (Udupi PCL) – Kasargode 400kV (Quad) D/c line	400	D/c	231		
32.	2022-23	SR	Warangal (New) –Hyderabad 765 kV D/c line	765	D/c	268	240	240
33.	2022-23	SR	Warangal (New) – Warangal (Existing) 400 kV (quad) D/c line	400	D/c	96		
34.	2022-23	SR	Hyderabad – Kurnool 765 kV D/c line.	765	D/c	337	240	240
35.	2022-23	SR	Warangal (New) – Chilakaluripeta 765kV D/c line	765	D/c	390	240	240
36.	2022-23	NR	Removal of LILO of one circuit of Bhadla-Bikaner (RVPN) 400kV D/C line at Bikaner (PG) & Extension of this LILO section from Bikaner (PG) to Bikaner-II PS to form Bikaner-II PS-Bikaner (PG) 400kV D/C line	400	D/c	64		
37.	2022-23	NR	Removal of LILO of Bawana – Mandola 400kV D/c (Quad) line at Maharani Bagh /Gopalpur S/s. Extension of above LILO section from Maharani Bagh/ Gopalpur upto Narela S/s so as to form Maharani Bagh – Narela 400kV D/c(Quad) and Maharani Bagh-Gopalpur-Narela 400kV D/c (Quad) lines	400	D/c	28		
38.	2022-23	NR	Fatehgarh-III - Fatehgarh-II 400kV D/c line (Twin HTLS)	400	D/c	88		
39.	2022-23	NR	Fatehgarh-III - Jaisalmer-II (RVPNL) 400kV D/c line (Twin HTLS)	400	D/c	100		
40.	2022-23	NR	Bikaner-II PS – Khetri 400kV 2xD/c line (Twin HTLS line on M/c tower)	400	D/c	1088	80	
41.	2022-23	NR	Khetri - Bhiwadi 400kV D/c line (Twin HTLS)	400	D/c	236		
42.	2022-23	NR	Fatehgarh II - Bhadla II 765kV D/C Line (2nd)	765	D/c	375	240	240

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
43.	2022-23	NR	Bhadla II - Sikar II 765 kV D/C line	765	D/c	612	240	330
44.	2022-23	NR	Sikar II - Neemrana 400kV D/c line (Twin HTLS)	400	D/c	274		
45.	2022-23	NR	Sikar-II - Aligarh 765kV D/C Line	765	D/c	408	330	330
46.	2022-23	NR	Bhadla II - Sikar II 765 kV D/C line (2nd)	765	D/c	620	240	330
47.	2022-23	NR	Khetri – Narela 765 kV D/c line	765	D/c	180		330
48.	2022-23	NR	LILo of 765 kV MeerutBhiwani S/c line at Narela	765	D/c	50		
49.	2022-23	NER	Installation of 400kV, 2x63MVA switchable line reactors, one in each circuit of Silchar (POWERGRID) – Imphal (POWERGRID) 400kV D/c line at Imphal end	400				126
50.	2022-23	NER	Lower Subansiri – Biswanath Chariyali 400kV 2 x D/c (Twin Lapwing) line (341.5km): Matching with Lower Subansiri (2000MW) HEP	400	D/c	683		
51.	2022-23	NER	Pare HEP (NEEPCO, Ar. Pradesh) – North Lakhimpur (AEGCL) 132kV D/c line with one circuit via Nirjuli (POWERGRID) (with ACSR Zebra conductor) – (55km)	132	D/c	110		
52.	2022-23	ER	NKSTPP – Jharkhand Pool 400kV D/c (quad) line (50ckm)	400	D/c	50		
53.	2023-24	WR	Khavda PS 1(GIS) – Bhuj PS 765 kV D/c line (120ckm)	765	D/c	120		
54.	2023-24	WR	LILo of one ckt. of KPS1- Bhuj PS 765 kV D/c line at KPS2	765	D/c	2		
55.	2023-24	WR	KPS3- KPS2 765 kV D/c line - 20km	765	D/c	40		
56.	2023-24	WR	KPS1-Khavda PS GIS (KPS2) 765 kV D/C line (to be established with bypassing of LILo of one ckt. of KPS1-Bhuj at KPS2 and utilisation of LILo section) -20Km	765	D/c	40		
57.	2023-24	WR	KPS2 (GIS) – Lakadia 765 kV D/C line with 330 MVA switchable line reactors at KPS2 end - 159KM	765	D/c	320	330	
58.	2023-24	WR	Banaskantha – Ahmedabad 765 kV D/c line (~200 km length) with 330MVA, 765 kV Switchable line reactor on each ckt at Ahmedabad S/s end.	765	D/c	400		330
59.	2023-24	WR	Ahmedabad – South Gujarat/Navsari (new) 765 kV	765	D/c	440	240	240

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
			D/c line with 240 MVAR switchable line reactor at both ends (~line length 220 km)					
60.	2023-24	WR	Lakadia PS – Ahmedabad 765kV D/c line with 240 MVAR switchable line reactors on both ends (500ckm)	765	D/c	500	240	240
61.	2023-24	WR	LILO of Pirana (PG) – Pirana (T) 400kV D/c line at Ahmedabad S/s with twin HTLS along with reconductoring of Pirana (PG) – Pirana(T) line with twin HTLS conductor	400	D/c	88		
62.	2023-24	WR	Neemuch PS – Chhittorgarh (PG) S/s 400 kV D/C line (conductor with minimum capacity of 2100 MVA/Ckt at nominal voltage)	400	D/c	260		
63.	2023-24	WR	Neemuch PS- Mandsaur S/stn 400 kV D/c line (conductor with minimum capacity of 2100 MVA/Ckt at nominal voltage)	400	D/c	240		
64.	2023-24	WR	Pachora SEZ PP -Bhopal (Sterlite) 400 kV D/c line (Quad/HTLS) (320ckm) (with minimum capacity of 2100 MVA/ckt at nominal voltage) along with 80MVAR switchable line reactors on each circuit at Pachora end	400	D/c	320	80	
65.	2023-24	WR	LILO of both circuits of Parli (PG) – Pune (GIS) 400kV D/c line at Kallam PS (40ckm)	400	2xD/c	40		
66.	2023-24	WR	Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line	400			50	
67.	2023-24	WR	Conversion of 50MVAR fixed Line Reactors on each ckt of Parli (PG) – Pune (GIS) 400kV D/c line at Parli (PG) end into switchable.	400			50	
68.	2023-24	WR	Navsari (New) (South Gujarat) (GIS) - Kala (GIS) 400 kV D/c line (conductor with minimum capacity of 2100 MVA/Ckt at nominal voltage) (~110 km length) with 63MVAR switchable line reactor on each ckt at Kala (GIS) end	400	D/c	220		63
69.	2023-24	WR	Navsari (New) (South Gujarat) (GIS) – Magarwada (GIS) 400 kV D/c line (conductor with minimum capacity of 2100	400	D/c	160		

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
			MVA/Ckt at nominal voltage) (~80 km length)					
70.	2023-24	WR	Navsari (New) (South Gujarat) (GIS) – Padghe (GIS) 765 kV D/c line (~200 km length) with 330 MVA _r , 765 kV Switchable line reactor on each ckt. at Navsari (New) (South Gujarat) end.	765	D/c	400	330	
71.	2023-24	WR	LILO of KAPP – Vapi 400kV D/c line at Vapi-II	400	2xD/c	24		
72.	2023-24	WR	Vapi II – Sayali 220kV D/c line	220	D/c	44		
73.	2023-24	WR	Padghe (PG) – Kharghar 400kV D/c (quad) line to be terminated into one ckt. of Kharghar – Ghatkopar 400kV D/c (quad) line (thus forming Padghe (PG) – Kharghar 400kV S/c (quad) line, Padghe (PG) – Ghatkopar 400kV S/c (quad) line) - 60km	400	D/c	120		
74.	2023-24	WR	LILO of Padghe (PG) – Ghatkopar 400kV S/c line at Navi Mumbai GIS (PG) (with quad conductor) - 10km	400	D/c	20		
75.	2023-24	SR	Pooling station (near Munirabad /suitable location in Koppal distt.) - Narendra (New) GIS 400 kV D/c Line (with Quad Moose ACSR conductor)	400	D/c	250		
76.	2023-24	SR	Gadag PS - Narendra (New) PS 400 kV (high capacity equivalent to quad moose) D/C Line	400	D/c	200		
77.	2023-24	SR	LILO of both circuits of Pugalur – Pugalur (HVDC) 400 kV D/c line (with Quad Moose ACSR Conductor) at Karur PS	400	D/c	100		
78.	2023-24	NER	Bongaigaon (POWERGRID) – Nangalbibra 400kV D/c line (initially operated at 220kV) – 280ckm	400	D/c	280		
79.	2023-24	NER	Hatsinghmari (Assam) – Ampati (Meghalaya) 132kV D/c line – 60 ckm	132	D/c	60		
80.	2023-24	ER	Sitamarhi (POWERGRID) - Dhalkebar (Nepal) 400kV D/c (Quad) line (Indian portion) – 80ckm	400	D/c	80		
81.	2023-24	ER	NKSTPP – Gaya 400kV D/c (quad) line (185ckm)	400	D/c	185		

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
82.	2024-25	WR	LILO of Satna - Bina 400 kV (1st) D/c line at Chhatarpur PS*~60 km *out of Satna – Bina 2xD/c lines, one circuit of 2nd D/c line has been LILOed at Sagar (MPPTCL) substation. The proposed LILO is to be made on the other (1st) D/c line between Satna & Bina.	400	2xD/c	240		
83.	2024-25	WR	Banaskantha – Sankhari 400 kV 2 nd D/c line (~26 km length)	400	D/c	52		
84.	2024-25	SR	Kurnool-III Pooling station - Kurnool (new) 765 kV D/c Line	765	D/c	200		
85.	2024-25	SR	Kurnool-III Pooling station - Maheshwaram(PG) 765 kV D/c Line	765	D/c	500	240	240
86.	2024-25	SR	Upgradation/charging of Narendra (new) - Kolhapur PG 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVar switchable Line Reactor at Kolhapur end on both end of each circuit	765	D/c		330	
87.	2024-25	SR	Bidar PS – Maheshwaram (PG) 765kV D/C line	765	D/c	320		
88.	2024-25	SR	Ananthapuram PS - Kurnool-III PS 400 kV (High capacity equivalent to quad moose) D/c Line	400	D/c	200		
89.	2024-25	SR	Anantapuram PS - Cuddapah 400 kV (High capacity equivalent to quad moose) D/c Line with 80 MVar switchable line reactor on Ananthapuram PS end of each circuit	400	D/c	300		
90.	2024-25	SR	Upgradation/charging of Tuticorin PS - Dharmapuri (Salem New) 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVar switchable Line Reactor on both end of each circuit	765	D/c		330	330
91.	2024-25	SR	Upgradation/charging of Dharmapuri (Salem New) - Madhugiri (Tumkur) 765 kV 2xS/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVar switchable Line Reactor on Dharmapuri (Salem New) end of both ckts	765	D/c		330	

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
92.	2024-25	SR	Upgradation/charging of Tuticorin PS - Dharmapuri (Salem New) 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVar switchable Line Reactor on both end of each circuit	765	D/c		330	330
93.	2024-25	SR	Upgradation/charging of Madhugiri (Tumkur) - Narendra New 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVar switchable Line Reactor on both end of each circuit	765	D/c		330	330
94.	2024-25	NR	LILO of one circuit of Kishenpur – Dulhasti 400kV D/c (Quad) line	400	D/c	20		
95.	2024-25	NR	Stringing of 2 nd circuit of Kishenpur – Dulhasti 400kV D/c line (Kishtwar – Kishenpur Section)	400	D/c	130		
96.	2024-25	NR	LILO of both 400 kV D/c Amargarh - Samba line at 400/220 kV Siot S/s	400	D/c	30		
97.	2024-25	NR	400 kV D/c Khandukhal(Srinagar)-Rampura (Kashipur) line	400	D/c	390		80
98.	2024-25	NR	Nange GIS Pooling Station – Koldam 400 kV D/c line	400	D/c	100		
99.	2024-25	NR	Laying of cable about 15km provided between Minamarg and Zojila Top section of Alusteng – Drass 220kV section	220	S/c	15		
100.	2024-25	NR	Fatehgarh-4- Fatehgarh-3 400 kV D/c twin HLTS line	400	D/c	100		
101.	2024-25	NR	Fatehgarh 3- Bhadla-3 400kV D/c line(Quad)	400	D/c	400	50	50
102.	2024-25	NR	Fatehgarh-2 – Bhadla-3 400kV D/c line (Quad)	400	D/c	400	50	50
103.	2024-25	NR	Bhadla-3 – Sikar-II 765 kV D/c line	765	D/c	760	330	330
104.	2024-25	NR	Ramgarh – Bhadla-3 765kV D/c line	765	D/c	360	240	
105.	2024-25	NR	Sikar-II – Khetri 765 kV D/c line	765	D/c	180		
106.	2024-25	NR	Sikar-II – Narela 765 kV D/c line	765	D/c	520	240	340
107.	2024-25	NR	Jhatikara – Dwarka 400kV D/c line	400	D/c	40		
108.	2024-25	NR	LILO of both circuit of Ajmer-Chittorgarh 765 kV D/c at Beawar	765	D/c	180		

Sl. No.	Time Frame	Region	Transmission Line	Voltage level (kV)	S/c, D/c or M/c	Total line length (ckm)	From end reactor	To end reactor
109.	2024-25	NR	LILO of 400kV Kota –Merta line at Beawar	400	S/c	40		
110.	2024-25	NR	Fatehgarh-3– Beawar 765 kV D/c	765	D/c	350	330	330
111.	2024-25	NR	Fatehgarh-3– Beawar 765 kV D/c(2nd)	765	D/c	700	330	330
112.	2024-25	NR	LILO of both circuits of Jaipur (Phagi)- Gwalior 765 kV D/c at Dausa	765	D/c	160		240
113.	2024-25	NR	LILO of both circuits of Agra – Jaipur (South) 400kV D/c at Dausa	400	D/c	120		50
114.	2024-25	NR	Beawar – Dausa 765 kV D/c line	765	D/c	480	240	240
115.	2024-25	NER	Kathalguri (NEEPCO) – Namsai (POWERGRID) 220kV D/c line	220	D/c	150		

Transformers

Sl. No.	Time Frame	Region	Transformers	Voltage ratio (kV)	Nos.	MVA Rating	Total MVA Capacity
1	2021-22	WR	Establishment of 2x1500MVA, 765/400 kV Lakadia PS	765/400	2	1500	3000
2	2021-22	WR	Establishment of 2x1500 MVA (765/400 kV) Bhuj-II PS (GIS)	765/400	2	1500	3000
3	2021-22	WR	Establishment of 4x500 MVA (400/220 kV) Bhuj-II PS (GIS)	400/220	4	500	2000
4	2021-22	WR	Establishment of 4x500MVA, 400/220kV Jam Khambhaliya PS (GIS)	400/220	4	500	2000
5	2021-22	WR	1x500 MVA, 400/220 ICT at CGPL Mundra switchyard	400/220	1	500	500
6	2021-22	SR	Augmentation of transformation capacity by 1X500 MVA, 3rd 400/230kV ICT along with associated 400kV GIS and 230kV GIS bays at Tuticorin-II (GIS) S/s	400/230	1	500	500
7	2021-22	NER	Kopili HEP 220/132kV : 60MVA replacement by 1x160MVA ICT	220/132	1	100	100
8	2021-22	NER	Installation of 3rd 220/132kV ICT of 30MVA (3x10MVA) single phase units at Mokochung S/s along with associated bays	220/132	3	10	30
9	2021-22	NER	Replacement of existing 4x33.33MVA, 220/132kV Single phase unit transformers by 2x160 MVA, 220/132kV 3-phase unit at Dimapur Substation for capacity enhancement. Thus, the final transformation capacity would be 220/132kV, 1x100MVA + 2x160MVA	220/132	1	100	100
10	2021-22	NER	Replacement of existing 4x33.33MVA, 220/132kV Single phase unit transformers by 2x160 MVA, 220/132kV 3-phase unit at Dimapur Substation for capacity enhancement. Thus, the final transformation capacity would be 220/132kV, 1x100MVA + 2x160MVA	220/133	1	160	160
11	2021-22	ER	Farakka: Augmentation of 2nd 400/220kV 315MVA ICT	400/220	1	315	1000
12	2021-22	ER	Replacement of 2x315MVA with 2x500MVA ICT at 400/220kV Malda S/s	400/220	2	500	1000
13	2021-22	ER	Installation of 315MVA (3rd) ICT at 400/220kV New Siliguri S/s	400/220	1	315	315
14	2021-22	ER	Extension at Muzaffarpur (POWERGRID) 400/220kV S/s: 500MVA, 400/220kV transformer (4th ICT) along with ICT bays	400/220	1	500	500
15	2021-22	ER	Rangpo: 220/132kV, 4th 100MVA ICT	220/132	1	100	100
16	2021-22	ER	Shifting of 400kV side of 400/220kV, 315MVA ICT-I from Durgapur-A section to Durgapur-B section without physical shifting of ICT such that all three ICTs are on same 400kV bus section (if required, GIS bus duct could be used)	400/220	0	0	0
17	2022-23	WR	Establishment of 2x500MVA, 400/220kV substation at Xeldem	400/220	2	500	1000

Sl. No.	Time Frame	Region	Transformers	Voltage ratio (kV)	Nos.	MVA Rating	Total MVA Capacity
18	2022-23	WR	Augmentation of transformation capacity at Vadodara 765/400/220kV S/s by 1x1500MVA, 765/400kV ICT (3 rd) along with associated 765kV ICT bay* *Out of the 2 nos. 400kV line bays already constructed by POWERGRID for DGEN – Vadodara line, 1no. line bay to be utilized for 765/400kV ICT (3 rd) at Vadodara	765/400	1	1500	1500
19	2022-23	WR	1x500MVA, 400/220kV ICT (3 rd) at Indore S/s along with associated ICT bays (400kV AIS & 220kV Hybrid/MTS) with 220kV ICT bay on extended bus.	400/220	1	500	500
20	2022-23	SR	Augmentation of transformation capacity at Hiriya and Kochi by 1x500 MVA, 400/220 kV ICT	400/220	2	500	1000
21	2022-23	SR	Establishment of 2x500MVA, 400/220 kV GIS substation at Kasargode	400/220	2	500	1000
22	2022-23	SR	Establishment of 765/400kV substations at Warangal (New) with 2x1500 MVA transformers	765/400	2	1500	3000
23	2022-23	NER	Installation of 1x100MVA, 220/132kV ICT (3 rd) at Salakati alongwith associated bays at both levels	220/132	1	100	100
24	2023-24	WR	Establishment of Khavda PS1 (KPS1) 765/400, 3x1500MVA PS (GIS)	765/400	3	1500	4500
25	2023-24	WR	Establishment of 765/400 kV, 4x1500MVA, KPS2 (GIS)	765/400	4	1500	6000
26	2023-24	WR	Establishment of 765/400 kV, 3x1500 MVA, KPS3 (GIS) with 1x330 MVAR 765 kV bus reactor and 1x125 MVAR 400 kV bus reactor.	765/400	3	1500	4500
27	2023-24	WR	Augmentation of Khavda PS1 by 765/400 kV transformation capacity * (max. upto 4x1500 MVA)	765/400	4	1500	6000
28	2023-24	WR	Augmentation of transformation capacity at Navsari (New) (South Gujarat) 765/400 kV S/s by 1x1500 MVA ICT. along with corresponding bay, 765kV Bays at Banaskantha and Ahmedabad for Banaskantha – Ahmedabad 765 kV D/c line.	765/400	1	1500	1500
29	2023-24	WR	Establishment of 3x1500 MVA, 765/400 kV Ahmedabad S/s	765/400	3	1500	4500
30	2023-24	WR	Establishment of 2x500 MVA, 400/220 kV Pooling Station (AIS) at Neemuch	400/220	2	500	1000
31	2023-24	WR	Establishment of 400/220 kV, 3X500 MVA at Pachora SEZ PP	400/220	3	500	1500
32	2023-24	WR	Augmentation of Shujalpur S/s by 400/220kV, 1x500MVA ICT (3 rd)	400/220	1	1500	1500
33	2023-24	WR	Establishment of 4x500MVA, 400/220kV at Kallam PS along with 4 nos. 220kV line bays at Kallam PS	400/220	4	500	2000
34	2023-24	WR	Establishment of 2x1500 MVA, 765/400 kV Navsari (New) (South Gujarat) S/s (GIS) with 1x500 MVA, 765/400 kV single phase spare transformer].	765/400	2	1500	3000

Sl. No.	Time Frame	Region	Transformers	Voltage ratio (kV)	Nos.	MVA Rating	Total MVA Capacity
35	2023-24	WR	Establishment of 3x500 MVA, 400/220 kV at Navsari (New) (South Gujarat) S/s (GIS)	400/220	3	500	1500
36	2023-24	WR	Augmentation of transformation capacity at Padghe (GIS) 765/400 kV substation by 1x1500 MVA ICT.	765/400	1	1500	1500
37	2023-24	WR	Establishment of 2x500MVA, 400/220kV GIS S/s near Vapi / Ambheti (Vapi-II)	400/220	2	500	1000
38	2023-24	SR	Addition of 1x500 MVA, 400/230kV ICTs (4th) at Tuticorin-II GIS sub-station.	400/230	1	500	500
39	2023-24	SR	Establishment of 5x500 MVA, 400/220 kV pooling station near Munirabad /suitable location in Koppal distt	400/220	5	500	2500
40	2023-24	SR	Establishment of 400/220 kV, 2x500 MVA Gadag Pooling Station	400/220	2	500	1000
41	2023-24	SR	Augmentation of 400/220 kV, 3x500 MVA Gadag Pooling Station	400/220	3	500	1500
42	2023-24	SR	Establishment of 2x500 MVA, 400/230 kV Karur Pooling Station	400/230	2	500	1000
43	2023-24	SR	Augmentation of 3x500 MVA, 400/230 kV at Karur PS	400/230	3	500	1500
44	2023-24	SR	Augmentation with 400/220kV, 1x500 MVA Transformer (3rd) at Palakkad (PG) (2x 315 MVA already existing)	400/220	1	500	500
45	2023-24	SR	Augmentation with 400/220 kV, 1x500 MVA Transformer (3rd) at Kolar (PG) (2x 500 MVA already existing)	400/220	1	500	500
46	2023-24	SR	Augmentation with 765/400 kV, 1x1500 MVA Transformer (3rd) at Nizamabad (PG) (2x 1500 MVA already existing)	765/400	1	1500	1500
47	2023-24	NER	Establishment of new 220/132kV, 2x160MVA substation at Nangalbibra	220/132	2	160	320
48	2023-24	ER	400/220kV, 2x500MVA ICTs along with associated bays (220kV bays in GIS and 400kV bays in AIS)	400/220	2	500	1000
49	2024-25	WR	Establishment of 3x500 MVA, 400/220 kV Pooling Station at Chhatarpur	400/220	3	500	1500
50	2024-25	WR	Augmentation of transformation capacity at Banaskantha 765/400 kV S/s by 1x1500 MVA ICT along with corresponding bays and associated bays for Banaskantha – Sankhari 400 kV 2nd D/c line at Banaskantha and Sankhari.	765/400	1	1500	1500
51	2024-25	SR	Establishment of 2x1500 MVA, 765/400 KV Pooling station at suitable location in Kurnool Distt. (Kurnool-III)	765/400	2	1500	3000
52	2024-25	SR	Establishment of 5x500 MVA 400/220kV Pooling station at suitable location in Kurnool Distt. (Kurnool-III)	400/220	5	500	2500
53	2024-25	SR	Augmentation of transformation capacity by 1x1500 MVA, 765/400 KV at Kurnool-III Pooling Station (in matching time frame of Kurnool Part-B)	765/400	1	1500	1500
54	2024-25	SR	Augmentation of transformation capacity by 4x500 MVA 400/220kV at Kurnool-III Pooling Station (in matching time frame of Kurnool Part-B)	765/400	1	1500	1500

Sl. No.	Time Frame	Region	Transformers	Voltage ratio (kV)	Nos.	MVA Rating	Total MVA Capacity
55	2024-25	SR	Upgradation of Narendra New to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x330 MVar Bus Reactor	765/400	2	1500	3000
56	2024-25	SR	Upgradation of Kolhapur (PG) to its rated voltage of 765kV level alongwith 2x1500 MVA transformer and 1x330 MVar Bus Reactor	765/400	2	1500	3000
57	2024-25	SR	Establishment of 3x1500MVA (765/400kV) Bidar PS	765/400	3	1500	4500
58	2024-25	SR	Establishment of 5x500MVA (400/220kV) Bidar PS	400/220	5	500	2500
59	2024-25	SR	Establishment of 400/220 kV, 7x500 MVA, Ananthpuram pooling station at suitable border location between Anantapur & Kurnool Distt	400/220	7	500	3500
60	2024-25	SR	Upgradation of Tuticorin PS to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x330 MVar Bus Reactor	765/400	2	1500	3000
61	2024-25	SR	Upgradation of Dharmapuri (Salem New) to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x240 MVar Bus Reactor	765/400	2	1500	3000
62	2024-25	SR	Upgradation of Madhugiri (Tumkur) to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x240 MVar Bus Reactor	765/400	2	1500	3000
63	2024-25	NER	Upgradation of existing 132kV Namsai (POWERGRID) S/s to 220kV (with 220kV side as GIS)	220/132	2	160	320
64	2025-26	WR	Establishment of 4x500MVA, 400/220kV ICTs at Lakadia (GIS) PS	400/220	4	500	2000
65	2025-26	WR	Additional 1x500MVA 400/220kV (9th) ICT, for injection from any additional RE project (other than 4000MW injection under SECI bids upto Tranche IV) in existing Bhuj PS with associated 400 kV GIS bay and 220kV AIS bay.	400/220	1	500	500
66	2025-26	WR	400/220 kV, 2x500 MVA ICT augmentation at Pachora PS	400/220	2	500	1000
67	2025-26	WR	Establishment of 400/220 kV, 3x500 MVA at Solapur PP (near Mohol)	400/220	3	500	1500
68	2025-26	WR	Establishment of 400/220 kV, 5X500 MVA at Wardha SEZ PP	400/220	5	500	2500
69	2025-26	WR	Establishment of 3x1500MVA, 765/400kV at Dholera PS	765/400	3	500	1500
70	2021-22	NR	Augmentation with 765/400kV, 1x1500MVA transformer (4th) at Fatehgarh-II PS (1500MVA)	765/400	1	1500	1500
71	2021-22	NR	Installation of 400/220kV, 1x500MVA transformers at Fatehgarh-II PS (500MVA)	400/220	1	500	500
72	2021-22	NR	Augmentation with 765/400kV, 1x1500MVA transformer (3rd) at Bhadla-II PS (1500MVA)	765/400	1	1500	1500
73	2021-22	NR	Creation of 220 kV level at Bhadla-II PS with Installation of 400/220kV, 5x500MVA transformers at Bhadla-II PS (2500MVA)	400/220	5	500	2500
74	2021-22	NR	Creation of 220 kV level at Bikaner (PG) with Installation of 400/220kV, 1x500MVA transformers at Bikaner (PG) (1000MVA)	400/220	1	500	500

Sl. No.	Time Frame	Region	Transformers	Voltage ratio (kV)	Nos.	MVA Rating	Total MVA Capacity
75	2021-22	NR	400/220kV ICT Augmentation at Sonepat (PG) along with 2 nos. of 220kV bays and 2 nos. of 220kV bays at Abdullapur	400/220	1	500	500
76	2021-22	NR	4x500MVA, 400/220kV GIS at Dwarka-I (2000MVA)	400/220	4	500	2000
77	2021-22	NR	Creation of 2x160MVA, 220/66 kV GIS S/s at UT Chandigarh (320MVA)	220/66	2	160	320
78	2021-22	NR	Creation of 400/220kV, 2X315MVA GIS Substation in Jauljivi (630MVA)	400/220	2	315	630
79	2022-23	NR	Augmentation with 765/400 kV, 1x1500 MVA Transformer (5th) at Fatehgarh-II PS (1500MVA)	765/400	1	1500	1500
80	2022-23	NR	Augmentation with 765/400 kV, 1x1500 MVA Transformer (6th) at Fatehgarh-II PS (1500MVA)	765/400	1	1500	1500
81	2022-23	NR	Augmentation with 400/220 kV, 4x500 MVA Transformer (6th to 9th) at Fatehgarh-II PS with suitable Bus sectionalisation at 400 and 220 kV level and 7 nos. of 220 kV line bays (2000MVA)	400/220	4	500	2000
82	2022-23	NR	Augmentation with 400/220kV, 3x500MVA Transformer (6th to 8th) at Bhadla-II PS with suitable Bus sectionalisation at 400 and 220 kV level and 5 nos. of 220 line bays (1500MVA)	400/220	3	500	1500
83	2022-23	NR	Augmentation with 765/400 kV, 1x1500 MVA transformer (4th) at Bhadla-II PS (1500MVA)	765/400	1	1500	1500
84	2022-23	NR	Establishment of 400/220 kV, 4x500 MVA at Ramgarh – II PS	400/220	4	500	2000
85	2022-23	NR	Establishment of 765/400 kV, 2x1500 MVA at Sikar – II	765/400	2	1500	3000
86	2022-23	NR	2x500MVA, 400/220kV ICTs at Bikaner-II PS along with 4 nos. of 220kV line bays	400/220	2	500	1000
87	2022-23	NR	Replacement of 1x315 MVA, 400/220 kV ICT by 1x500 MVA, 400/220kV ICT at Ludhiana (PG) S/s	400/220	1	185	185
88	2022-23	NR	1x 500 MVA, 400/220 kV ICT at Kurukshetra (PG) S/s	400/220	1	500	500
89	2022-23	NR	1x 500 MVA, 400/220 kV ICT at Patiala (PG) S/s	400/220	1	500	500
90	2024-25	NR	Implementation of 2x200 MVA, 400/132 kV transformer at Kishtwar Pooling Station along with 4 no. of 132 kV line bays	400/132	2	200	400
91	2024-25	NR	Establishment of 2x315MVA, 400/220kV Siot(Rajouri) S/s with 1x125 MVAR (420 kV) bus reactors	400/220	2	315	630
92	2024-25	NR	Augmentation with 400/220kV, 1x315MVA Transformer (3rd) at Amargarh, J&K	400/220	1	315	315
93	2024-25	NR	Establishment of 7x105 MVA, 400/220kV Nange GIS Pooling Station	400/220	7	105	735
94	2024-25	NR	Augmentation with 400/220kV, 1x500 MVA Transformer (3rd) at Sohawal (PG)	400/220	1	500	500
95	2024-25	NR	Establishment of 2x500 MVA 400/220 kV pooling station at Fatehgarh-4 along with 2x125 MVAR Bus Reactor	400/220	2	500	1000

Sl. No.	Time Frame	Region	Transformers	Voltage ratio (kV)	Nos.	MVA Rating	Total MVA Capacity
96	2024-25	NR	Augmentation of 3x500 MVA 400/220 kV pooling station at Fatehgarh-4	400/220	3	500	1500
97	2024-25	NR	Establishment of 2x1500 MVA 765/400kV at Bhadla-3	765/400	2	1500	3000
98	2024-25	NR	3x500 MVA 400/220 kV pooling station at Bhadla-3	400/220	3	500	1500
99	2024-25	NR	Augmentation of 7x500 MVA 400/220 kV transformation capacity at Bhadla-3	400/220	7	500	3500
100	2024-25	NR	Establishment of 2x1500 MVA 765/400kV at Ramgarh	765/400	2	1500	3000
101	2024-25	NR	2x500 MVA 400/220 kV pooling station at Ramgarh	400/220	2	500	1000
102	2024-25	NR	Augmentation of 1x1500 MVA 765/400kV at Ramgarh PS	765/400	1	1500	1500
103	2024-25	NR	Establishment of 3x1500 MVA 765/400kV at Fatehgarh-3(new section)	765/400	3	1500	4500
104	2024-25	NR	3x500 MVA 400/220 kV pooling station at Fatehgarh-3(new section)	400/220	3	500	1500
105	2024-25	NR	Augmentation of 3x1500 MVA 765/400kV at Fatehgarh-3(new section)	765/400	3	1500	4500
106	2024-25	NR	2x500 MVA 400/220 kV pooling station at Fatehgarh-3(new section)	400/220	2	500	1000
107	2024-25	NR	Establishment of 2x1500MVA 765/400kV Substation at suitable location near Beawar	765/400	2	1500	3000
108	2024-25	NR	Establishment of 2x1500 MVA 765/400kV substation at suitable location near Dausa	765/400	2	1500	3000
109	2024-25	NR	Augmentation with 400/220kV, 1x500MVA Transformer (10th) at Fatehgarh-2 PS	765/400	1	1500	1500
110	2024-25	NR	Augmentation with 765/400kV, 1x1500MVA Transformer (5th) at Bhadla-2 PS	765/400	1	1500	1500
111	2024-25	NR	Augmentation with 765/400kV, 1x1500MVA Transformer (3rd) at Bikaner (PG)	765/400	1	1500	1500
112	2024-25	NR	Augmentation of 1x1500 MVA ICT (3rd), 765/400kV ICT at Jhatikara Substation (Bamnoli/Dwarka section)	765/400	1	1500	1500

Bus Reactors

Sl. No.	Time Frame	Region	Bus Reactors	No of reactors	Rating of reactor	Total reactive compensation (MVAR)
1	2021-22	WR	Establishment of 765kV 330MVAR Bus Reactor at Lakadia PS	1	330	330
2	2021-22	WR	Establishment of 400kV 125MVAR Bus Reactor at Lakadia PS	1	125	125
3	2021-22	WR	Establishment of 765kV 330MVAR Bus Reactor at Lakadia PS	1	330	330
4	2021-22	WR	Establishment of 400kV 125MVAR Bus Reactor at Lakadia PS	1	125	125
5	2021-22	WR	Establishment of 400kV 125MVAR Bus Reactor at Jam Khambhaliya PS	1	125	125
6	2021-22	NR	4x500MVA, 400/220kV GIS at Dwarka-I (2000MVA)	1	125	125
7	2021-22	NR	500 MVar TCR at Kurushetra	1	500	500
8	2022-23	WR	Establishment of 1x125MVAR Bus Reactor at Xeldem S/s	1	125	125
9	2022-23	SR	2 nos. of bus reactors at Udupi Ss	2	63	126
10	2022-23	SR	Establishment of 765/400kV substations at Warangal (New) with 2x1500 MVA transformers	2	240	480
11	2022-23	NR	± 600 MVar STATCOM at Fatehgarh-II substation with 4x125 MVar MSC, 2x125 MVar MSR	2	125	250
12	2022-23	NR	± 600 MVar STATCOM at Bhadla-II substation with 4x125 MVar MSC, 2x125 MVar MSR	2	125	250
13	2022-23	NR	Establishment of 400/220 kV, 4x500 MVA at Ramgarh – II PS	2	125	250
14	2022-23	NR	Establishment of 400kV Pooling Station at Biakner-II	2	125	250
15	2022-23	NR	1x125 MVar(400 kV) Bus Reactor at Sikar-II	1	125	125
16	2022-23	NR	2x330 MVar(765 kV) Bus Reactor at Sikar-II	2	330	660
17	2022-23	NR	2x330 MVar(765 kV) Bus Reactor at Narela	2	330	660
18	2022-23	NR	1x125 MVar(400 kV) Bus Reactor at Narela	1	125	125
19	2023-24	WR	Establishment of 765kV 1x330MVAR Bus Reactor at Khavda PS1 (KPS1)	1	330	330
20	2023-24	WR	Establishment of 400kV 1x125MVAR Bus Reactor at Khavda PS1 (KPS1)	1	125	125
21	2023-24	WR	Establishment of 2x330 MVAR 765 kV bus reactor at KPS2	2	330	660
22	2023-24	WR	Establishment of 2x125 MVAR 400 kV bus reactor. at KPS2	2	125	250
23	2023-24	WR	Establishment of 1x330 MVAR 765 kV bus reactor at KPS3(GIS)	1	330	330
24	2023-24	WR	Establishment of 1x125 MVAR 400 kV bus reactor at KPS3(GIS)	1	125	125
25	2023-24	WR	Augmentation of Khavda PS1 with 1x330 MVAR 765 kV bus reactor on 2nd 765 kV bus section	1	330	330
26	2023-24	WR	Augmentation of Khavda PS1 with 1x125 MVAR 420 kV bus reactor on 2nd 400 kV bus section	1	125	125

Sl. No.	Time Frame	Region	Bus Reactors	No of reactors	Rating of reactor	Total reactive compensation (MVAR)
27	2023-24	WR	Establishment of 1x330 MVAR 765 kV bus reactor at Ahmedabad S/s	1	330	330
28	2023-24	WR	Establishment of 1x125 MVAR 400 kV bus reactor at Ahmedabad S/s	1	400	400
29	2023-24	WR	Establishment of 1x125 MVAR Bus Reactor at Neemuch PS	1	125	125
30	2023-24	WR	Establishment of 420kV 125 MVAR bus at reactor at Pachora SEZ PP	1	125	125
31	2023-24	WR	Establishment of 1x125MVAR bus reactor at Kallam PS	1	125	125
32	2023-24	WR	Establishment of 2x330 MVAR 765 kV Bus reactor. [with 110 MVAR 765 kV single phase reactor units (spare units for bus/line reactor)]	2	330	660
33	2023-24	WR	Establishment of 1x125 MVAR 400 kV Bus reactor at Navsari (New) (South Gujarat) S/s (GIS)	1	125	125
34	2023-24	WR	Establishment of 125MVAR Bus reactor at Vapi / Ambheti (Vapi-II)	1	125	125
35	2023-24	SR	2x125 MVAR, 400 kV bus reactor at Pooling station (near Munirabad /suitable location in Koppal Distt.)	2	125	250
36	2023-24	SR	1x125 MVAR (400 kV) bus reactor at Gadag PS	1	125	125
37	2023-24	SR	2x125 MVAR, 400 kV Bus reactors at Karur PS	2	125	250
38	2023-24	NER	2 nos 31.5MVAR Bus reactor at Nangalbibra	2	32	63
39	2024-25	WR	Establishment of 1X125 MVAR, 420 kV bus reactor at Chhatarpur PS	1	125	125
40	2024-25	SR	1x330 MVAR (765kV) bus reactor at Kurnool-III PS	1	330	330
41	2024-25	SR	1x125MVAR (400kV) bus reactor at Kurnool-III PS	1	125	125
42	2024-25	SR	1x330 MVAR Bus Reactor at Narendra New	1	330	330
43	2024-25	SR	1x330 MVAR Bus Reactor at Kolhapur (PG)	1	330	330
44	2024-25	SR	1x240 MVAR Bus Reactor at Bidar	1	240	240
45	2024-25	SR	1x125 MVAR Bus Reactor at Bidar	1	125	125
46	2024-25	SR	2x125 MVAR (400kV) bus reactor at Anantapur PS	2	125	250
47	2024-25	SR	1x330 MVAR Bus Reactor at Tuticorin PS	1	330	330
48	2024-25	SR	1x240 MVAR Bus Reactor at Dharmapuri (Salem New)	1	240	240
49	2024-25	SR	1x240 MVAR Bus Reactor at Madhugiri (Tumkur)	1	240	240
50	2024-25	NR	Implementation of 2x200 MVA, 400/132 kV transformer at Kishtwar Pooling Station along with 4 no. of 132 kV line bays	1	125	125
51	2024-25	NR	Establishment of 2x315MVA, 400/220kV Siot(Rajouri) S/s with 1x125 MVAR (420 kV) bus reactors	1	80	80
52	2024-25	NR	2x25 MVAR, 220kV bus reactors at 220/66kV Drass S/s	2	25	50
53	2024-25	NR	1x25 MVAR, 220kV bus reactors at 220/66kV Aulsteng S/s	1	25	25
54	2024-25	NR	Establishment of 2x500 MVA 400/220 kV pooling station at Fatehgarh-4 along with 2x125 MVAR Bus Reactor	2	125	250

Sl. No.	Time Frame	Region	Bus Reactors	No of reactors	Rating of reactor	Total reactive compensation (MVAR)
55	2024-25	NR	2x330 MVar (765 kV) Bus Reactor at Bhadla-3	2	330	660
56	2024-25	NR	2x125 MVar(400 kV) Bus Reactor at Bhadla-3	2	125	250
57	2024-25	NR	2x240 MVar(765 kV) Bus Reactor at Ramgarh	2	240	480
58	2024-25	NR	2x125 MVar(400 kV) Bus Reactor at Ramgarh	2	125	250
59	2024-25	NR	STATCOM at Ramgarh S/s: $\pm$ 2x300 MVar, 4x125 MVar MSC, 2x125 MVar MSR	2	125	250
60	2024-25	NR	STATCOM : $\pm$ 2x300 MVar, 4x125 MVar MSC, 2x125 MVar MSR at Fatehgarh-III	2	125	250
61	2024-25	NR	2x330 MVar(765 kV) Bus Reactor at Beawar	2	330	660
62	2024-25	NR	2x125 MVar(400 kV) Bus Reactor at Beawar	2	125	250
63	2024-25	NR	2x330 MVar(765 kV) Bus Reactor at Dausa	2	330	660
64	2024-25	NR	2x125 MVar(400 kV) Bus Reactor at Dausa	2	125	250
65	2024-25	NER	1 no 50MVar Bus reactor at Namsai	1	50	50

Annex-5.1

Renewable Energy Integration plan

Northern Region

Transmission System for integration of 17GW REZ in NR

Transmission System for evacuation of power from 8.9GW REZ in Western Rajasthan in Northern Region has been commissioned.

Transmission system strengthening scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II- Details of major elements which are under implementation are as follows:

Cost- Rs. 11920Cr.

Part A

- Establishment of 400/220 kV, 4x500 MVA at Ramgarh – II PS with 420kV (2x125 MVAR) bus reactor
- Fatehgarh-III - Fatehgarh-II 400kV D/c line (Twin HTLS)
- Fatehgarh-III - Jaisalmer-II (RVPNL) 400kV D/c line (Twin HTLS)

Part- A1

- Augmentation with 765/400 kV, 1x1500 MVA Transformer (5th) at Fatehgarh-II PS (1500MVA)

Part B

- Fatehgarh II - Bhadla II 765kV D/C Line (2nd)

Part- B1

- Augmentation with 765/400 kV, 1x1500 MVA Transformer (6th) at Fatehgarh-II PS (1500MVA)
- Augmentation with 400/220 kV, 4x500 MVA Transformer (6th to 9th) at Fatehgarh-II PS with suitable Bus sectionalisation at 400 and 220 kV level and 7 nos. of 220 kV line bays (2000MVA)
- Augmentation with 400/220kV, 3x500MVA Transformer (6th to 8th) at Bhadla-II PS with suitable Bus sectionalisation at 400 and 220 kV level and 5 nos. of 220 line bays (1500MVA)
- Augmentation with 765/400 kV, 1x1500 MVA transformer (4th) at Bhadla-II PS (1500MVA)
- ± 600 MVAR STATCOM at Fatehgarh-II substation with 4x125 MVAR MSC, 2x125 MVAR MSR
- ± 600 MVAR STATCOM at Bhadla-II substation with 4x125 MVAR MSC, 2x125 MVAR MSR

Part C

- Establishment of 765/400 kV, 2x1500 MVA at Sikar – II
- Bhadla II - Sikar II 765 kV D/C line
- Sikar II - Neemrana 400kV D/c line (Twin HTLS)

Part D

- Sikar-II - Aligarh 765kV D/C Line

Part E

- Bhadla II - Sikar II 765 kV D/C line (2nd).

Part F

- Establishment of 400kV Pooling Station at Biakner-II
- Bikaner-II PS – Khetri 400kV 2xD/c line (Twin HTLS* line on M/c tower)
- Khetri - Bhiwadi 400kV D/c line (Twin HTLS)

Part F1

- Removal of LILO of one circuit of Bhadla - Bikaner (RVPN) 400kV D/C line at Bikaner (PG) & Extension of this LILO section from Bikaner (PG) to Bikaner-II PS to form Bikaner-II PS-Bikaner (PG) 400kV D/C line

Part G

- Establishment of 765/400 kV, 3X1500 MVA GIS substation at Narela
- Khetri – Narela 765 kV D/c line along with 1x330MVA Switchable line reactor for each circuit at Narela end of Khetri – Narela 765kV D/c line
- LILO of 765 kV Meerut Bhiwani S/c line at Narela.

Part G1

- Removal of LILO of Bawana – Mandola 400kV D/c (Quad) line at Maharani Bagh /Gopalpur S/s. Extension of above LILO section from Maharani Bagh/ Gopalpur upto Narela S/s so as to form Maharani Bagh – Narela 400kV D/c(Quad) and Maharani Bagh-Gopalpur-Narela 400 kV D/c (Quad) lines.
- 2 no of line bays at Narela each for Maharani Bagh – Narela 400 kV D/c (Quad) and Maharani Bagh –Gopalpur-Narela 400 kV D/c (Quad) lines formed after removal of LILO of Bawana – Mandola 400kV D/c(Quad) line at Maharani Bagh/Gopalpur S/s and Extension of above LILO section from Maharani Bagh/Gopalpur uptoNarela S/s (2800ckm)
- Power reversal on ± 500 KV, 2500 Balia- Bhiwadi HVDC line upto 2000 MW from Bhiwadi to Balia.

Implementation of 220 kV bays for RE generators and 400/220kV ICTs at Bikaner-II PS

Cost: Rs. 70cr.

- 2x500MVA, 400/220 kV ICT at Bikaner-II PS
- 4 nos. 220 kV line bays

Transmission system for evacuation of power from REZ in Rajasthan (14GW) under Phase-III

Cost: Rs. 28130cr.

Part A1

- Establishment of 2x500 MVA 400/220 kV pooling station at Fatehgarh-4 along with 2x125 MVA Bus Reactor
- Fatehgarh-4- Fatehgarh-3 400 kV D/c twin HLTS* line (50 km)

Part A2

- Augmentation of 3 x500 MVA400/220 kV pooling station at Fatehgarh-4

Part A3

- Fatehgarh 3- Bhadla-3 400kV D/c line(Quad) along with 50 MVA Switchable line reactor for each circuit at both ends of Fatehgarh 3- Bhadla3 400kV D/c line (200 km)

Part B1

- Establishment of 2x1500 MVA 765/400kV & 3x500 MVA 400/220 kV pooling station at Bhadla-3 along with 2x330 MVA (765kV) Bus Reactor & 2x125 MVA (420kV) Bus Reactor
- Fatehgarh-2 – Bhadla-3 400kV D/c line (Quad) along with 50 MVA Switchable line reactor for each circuit at both ends of Fatehgarh 2- Bhadla3 400kV D/c line (200 km)
- Bhadla-3 – Sikar-II 765 kV D/c line along with 330 MVA Switchable line reactor for each circuit at each end of Bhadla-3 – Sikar-II 765 kV D/c line

Part B2

- Augmentation of 7x500 MVA 400/220 kV transformation capacity at Bhadla-3

Part C1

- Establishment of 2x1500 MVA 765/400kV & 2x500 MVA 400/220 kV pooling station at Ramgarh along with 2x240 MVA (765kV) Bus Reactor & 2x125 MVA (420kV) Bus reactor
- Ramgarh – Bhadla-3 765kV D/c line(180 km) along with 240 MVA switchable line reactor at each circuit at Ramgarh end of Ramgarh – Bhadla-3 765kV D/c line

Part C2

- Augmentation of 1x1500 MVA 765/400kV at Ramgarh PS

Part C3

- STATCOM at Ramgarh S/s: $\pm$ 2x300 MVA, 4x125 MVA MSC, 2x125 MVA MSR

Part D

- Sikar-II – Khetri 765 kV D/c line
- Sikar-II – Narela 765 kV D/c line along with 240 MVA Switchable line reactor for each circuit at each end of Sikar-II – Narela 765 kV D/c line
- Jhatikara – Dwarka 400kV D/c line (Quad)

Part E1

- Establishment of 3x1500 MVA 765/400kV & 3x500 MVA 400/220 kV pooling station at Fatehgarh-3 (new section*) (In addition to 4x500 MVA ICT proposed under Rajasthan SEZ Ph-II-of Section-1) along with 2x330 MVA,765kV & 2x125 MVA, 420kV Bus Reactors

Part E2

- Augmentation of 3x1500 MVA 765/400kV & 2x500 MVA 400/220 kV pooling station at Fatehgarh-3 (new section)

Part E3

- Fatehgarh – III S/s : STATCOM : $\pm$ 2x300 MVar, 4x125 MVar MSC, 2x125 MVar MSR

Part F

- Establishment of 2x1500MVA 765/400kV Substation at suitable location near Beawar along with 2x330 MVar 765kV Bus Reactor & 2x125 MVar 420kV Bus Reactor
- LILO of both circuit of Ajmer-Chittorgarh 765 kV D/c at Beawar Length – 45km
- LILO of 400kV Kota –Merta line at Beawar Length – 20km
- Fatehgarh-3– Beawar 765 kV D/c along with 330 MVar Switchable line reactor for each circuit at each end of Fatehgarh-3– Beawar 765 kV D/c line Length – 350km

Part G

- Fatehgarh-3– Beawar 765 kV D/c(2nd) along with 330 MVar Switchable line reactor for each circuit at each end of Fatehgarh-3– Beawar 765 kV D/c line

Part H

- Establishment of 2x1500 MVA 765/400kV substation at suitable location near Dausa along with 2x330 MVar, 765 kV Bus Reactor & 2x125 MVar, 420 kV bus Reactor
- LILO of both circuits of Jaipur (Phagi)- Gwalior 765 kV D/c at Dausa along with 240 MVar Switchable line reactor for each circuit at Dausa end of Dausa – Gwalior 765 kV D/c line Length – 40km
- LILO of both circuits of Agra – Jaipur (South) 400kV D/c at Dausa along with 50 MVar Switchable line reactor for each circuit at Dausa end of Dausa – Agra 400kV D/c line Length – 30km
- Beawar – Dausa 765 kV D/c line (240 km) along with 240 MVar Switchable line reactor for each circuit at each end

Part J

- Augmentation with 400/220kV, 1x500MVA Transformer (10th) at Fatehgarh-2 PS
- Augmentation with 765/400kV, 1x1500MVA Transformer (5th) at Bhadla-2 PS
- Augmentation with 765/400kV, 1x1500MVA Transformer (3rd) at Bikaner (PG)
- Augmentation of 1x1500 MVA ICT (3rd), 765/400kV ICT at Jhatikara Substation (Bamnoli/Dwarka section)

Connectivity System for the Proposed Kaza Solar Park (880 MW)

Cost: 721 Cr.

- Establishment of 1x315 MVA (4x105 MVA single phase units including one spare), 400/132kV substation at Kaza
- Kaza– Wangtoo (HPPTCL) 400 kV D/c line along with the associated 400 kV bays at both ends (Line capacity shall be 2500 MVA per circuit at nominal voltage)
- 1x80 MVAR switchable line reactor on each circuit at Kaza end of Kaza – Wangtoo 400 kV D/c line
- 1x125 MVar (420kV) Bus Reactor at Kaza

Transfer of Power from Kaza Solar Park (880 MW)- under ISTS

Cost: 751 Cr.

- Augmentation of 2x315 MVA (6x105 MVA single phase units) 400/132 kV ICT at Kaza PS
- Wangtoo (HPPTCL) -Dehradun (PG) 400 kV D/c Line (Twin HTLS*) along with 80 MVA_r switchable line reactor at Dehradun end at each circuit-220 Km
** with minimum capacity of 2100 MVA on each circuit at nominal voltage*

Power Evacuation from proposed Renewable Energy Park in Pang (Ladakh)

Cost : Rs 26,967 Cr

- **ISTS system for RE interconnection at Pang along with BESS (1GWh)**
 - 400kV PS-1 - Pang D/c (quad moose) line - 7km
 - 400kV PS-2 -Pang D/c (quad moose) line – 27km
 - 400kV PS-3 -Pang D/c (quad moose) line - 41km
 - 220kV line bay (1 no) for BESS (ISTS) interconnection at Pang
 - 220kV Pang – Leh (Phyang) S/c line (Deer conductor) (S/c line on D/c tower)*-151 km+7km cable
 - BESS at Pang (1GWh)

***Note:** 400kV GIS line bays (2 nos) each at PS-1, PS-2 & PS-3 -under developer scope*

HVDC System

- Pooling point in Pang (Leh): ±350 kV, 2 nos. of 2500 MW HVDC terminal
- Future provisions: Space for
 - 400 kV line bays : 6 nos.
 - 400/220 kV ICTs along with bays: 2 nos.
 - 220 kV line bays : 4 nos
- Pooling point in Kaithal (Haryana): ±350 kV, 2 nos. of 2500 MW HVDC terminal
 Future provisions: Space for
 - 765/400kV ICTs along with bays: 1 no.
 - 765kV line bays along with switchable line reactor: 2 nos.
 - 400kV line bays along with switchable line reactor: 4 nos.
 - 400/220 kV ICTs along with bays: 2 nos.
 - 220 kV line bay: 4 nos.
- 4 Nos. of 400 kV converter (VSC) bays at Pang
- 4 Nos. of 400 kV converter (VSC) bays at Kaithal
- 2 Nos. of 400/220/33 kV, 315 MVA Transformers along with associated Bays at Pang
- 3 Nos. of 765/400/33 kV, 1500 MVA Transformers along with associated bays at Kaithal

DC GIS/ AIS

- DC GIS / AIS at Pang and DC AIS at Kaithal
- 4 nos. of transition stations with DC GIS/ AIS

HVDC Line (OHL and UG Cable)

- 480 kms of ± 350 kV HVDC line between Pang & Kaithal PS (combination of 465 km overhead line (Quad) and 15 km underground cable).

EHVAC System beyond Kaithal

- Kaithal – Bahadurgarh (PG) 400 kV D/c Line (Twin HTLS) (conductor with minimum capacity of 2100 MVA/Ckt at nominal voltage) -170 km.
- Kaithal- Modipuram (Meerut) (UPPTCL) 765 kV D/c Line along with 1x240MVAR switchable line reactor on each ckt at Kaithal end -210 km.
- Augmentation of 765/400kV, 1500 MVA transformer of Bhiwani S/s (one section has 2x1000MVA ICT wherein 1500MVA augmentation will take place, whereas other has 1x1000MVA ICT split through series reactor) incl. 500MVA spare transformer unit (1-Phase).

Western Region

I. Transmission system for integration of 28 GW REZ in WR

Gujarat:

Western Region Strengthening Scheme-21 (WRSS-21) Part A - Transmission System strengthening for relieving over loadings observed in Gujarat Intra-state system due to RE injections in Bhuj PS

- Establishment of 2x1500MVA, 765/400kV Lakadia PS with 765kV (1x330MVAR) & 400kV (125 MVAR) bus reactor
- LILO of Bhachau – EPGL 400kV D/c (triple) line at Lakadia PS
- Bhuj PS – Lakadia PS 765kV D/c line

Cost: Rs. 856 Cr.

Western Region Strengthening Scheme-21 (WRSS-21) Part B - Transmission System strengthening for relieving over loadings observed in Gujarat Intra-state system due to RE injections in Bhuj PS

- Lakadia – Vadodara 765kV D/c line along with 330MVAR switchable line reactors at both ends of Lakadia – Vadodara 765kV D/c line

Cost: Rs. 1865 Cr.

Transmission System for providing connectivity to RE projects at Bhuj II (2000 MW) in Gujarat

- Establishment of 2x1500MVA (765/400kV), 4x500MVA (400/220kV) Bhuj-II PS (GIS) with 765kV (1x330MVAR) and 400kV (125 MVAR) bus reactor
- Reconfiguration of Bhuj PS – Lakadia PS 765kV D/c line so as to establish Bhuj-II –Lakadia 765 kV D/C line as well as Bhuj-Bhuj-II 765kV D/C line
- 1X240MVAR switchable Line reactor for each circuit at Bhuj II PS end of Bhuj-II – Lakadia 765 kV D/c line

Cost: Rs. 645 Cr.

Transmission System for Jam Khambaliya Pooling Station and Interconnection of Jam Khambaliya Pooling Station for Providing Connectivity to RE Projects (1500 MW) in Dwarka (Gujarat)

- Establishment of 4x500MVA, 400/220kV Jam Khambhaliya PS (GIS) along with 1x125MVA, 420kV Bus reactor at Jam Khabhaliya PS along with reactor bay
- 2 nos. of 400 kV line bays at Jam Khambhaliya PS for termination of Jam Khambhaliya PS-Lakadia 400kV D/c (triple) line
- 63MVA switchable Line Reactor at both ends of Lakadia - Jam Khambhaliya 400kV D/c line
- Extension of Essar-Lakadia/Bhachau 400kV D/c (triple) line upto Jam Khambhaliya PS
- 1x500MVA, 400/220kV ICT at CGPL Mundra switchyard

Cost: Rs. 435 Cr.

Transmission system associated with RE generations at Bhuj –II, Dwarka & Lakadia

- Lakadia PS – Banaskantha PS 765kV D/c line
- 765kV Bays at Lakadia and Banaskantha for Lakadia PS – Banaskantha PS 765kV D/c line
- 240MVA switchable Line reactor at Banaskantha end of Lakadia PS – Banaskantha PS

Cost: Rs. 1075 Cr.

Transmission Scheme for evacuation of 3.0 GW RE injection at Khavda pooling station under Phase-I

- Establishment of Khavda PS1 (KPS1) 765/400, 3x1500MVA, 400/220kV, 2x500MVA PS (GIS)
- Khavda PS 1(GIS) – Bhuj PS 765 kV D/c line (120ckm)

Cost: Rs. 755 Cr.

Establishment of Khavda Pooling Station-2 (KPS2) in Khavda RE Park for evacuation of power from RE Projects in Khavda area

- Establishment of 765/400 kV, 4x1500MVA, KPS2 (GIS) with 2x330 MVAR 765 kV bus reactor and 2x125 MVAR 400 kV bus reactor.
- LILO of one ckt. of KPS1- Bhuj PS 765 kV D/c line at KPS2

Cost: Rs. 789 Cr.

Establishment of Khavda Pooling Station-3 (KPS3) in Khavda RE Park

- Establishment of 765/400 kV, 3x1500 MVA, KPS3 (GIS) with 1x330 MVAR 765 kV bus reactor and 1x125 MVAR 400 kV bus reactor.
- KPS3- KPS2 765 kV D/c line - 20km
- 2 no. of 765 kV line bays at KPS2 765 kV S/s for KPS3-KPS2 765 kV D/c line

Cost: Rs. 665 Cr.

Transmission scheme for injection beyond 3 GW RE power at Khavda PS1 (KPS1) for evacuation of power from RE Projects in Khavda area

- Augmentation of Khavda PS1 by 765/400 kV transformation capacity * (max. upto 4x1500 MVA) with 1x330 MVAR 765 kV bus reactor and 1x125 MVAR 420 kV bus reactor on 2nd 765 kV and 400 kV bus section respectively
- KPS1-Khavda PS GIS (KPS2) 765 kV D/C line (to be established with bypassing of LILO of one ckt. of KPS1-Bhuj at KPS2 and utilisation of LILO section) -20Km

Cost: Rs. 780 Cr.

Transmission scheme for evacuation of 4.5 GW RE injection at Khavda P.S. under Phase-II – Part A

- KPS2 (GIS) – Lakadia 765 kV D/C line with 330 MVAR switchable line reactors at KPS2 end - 159KM
- 330 MVAR switchable line reactors at KPS2 end of KPS2 (GIS) – Lakadia 765 kV D/C line
- 2 nos. of 765 kV line bays each at Lakadia PS & KPS2 (GIS) for Khavda PS2 (GIS) – Lakadia PS 765 kV D/c line

Cost: Rs. 862 Cr.

Transmission scheme for evacuation of 4.5 GW RE injection at Khavda P.S. under Phase-II – Part B

- Lakadia PS – Ahmedabad 765kV D/c line with 240 MVAR switchable line reactors on both ends (500ckm)

Cost: Rs. 1232 Cr.

Transmission scheme for evacuation of 4.5 GW RE injection at Khavda P.S. under Phase-II – Part C

- Establishment of 3x1500 MVA, 765/400 kV Ahmedabad S/s with 1x330 MVAR 765 kV bus reactor and 1x125 MVAR 420 kV bus reactor.
- Ahmedabad – South Gujarat/Navsari (new) 765 kV D/c line with 240 MVAR switchable line reactor at both ends (~line length 220 km)
- 2 nos. of 765 kV line bays at South Gujarat /Navsari (new) end for Ahmedabad – South Gujarat/Navsari (new) 765 kV D/c line
- 240 MVAR switchable line reactor at both ends of Ahmedabad – South Gujarat /Navsari (new) 765 kV D/c line

Cost: Rs. 1440 Cr.

Transmission scheme for evacuation of 4.5 GW RE injection at Khavda P.S. under Phase-II – Part D

- LILO of Pirana (PG) – Pirana (T) 400kV D/c line at Ahmedabad S/s with twin HTLS along with reconductoring of Pirana (PG) – Pirana(T) line with twin HTLS conductor
- Bay upgradation work at Pirana(PG) & Pirana(T)

Cost: Rs. 118 Cr.

Transmission Network Expansion in Gujarat associated with integration of RE projects from Khavda potential RE zone (Matching with Khavda Phase-A (Ph-II) (5GW) scheme)

- Banaskantha – Ahmedabad 765 kV D/c line (~200 km length) with 330MVAR, 765 kV Switchable line reactor on each ckt at Ahmedabad S/s end.
- Augmentation of transformation capacity at Navsari (New) (South Gujarat) 765/400 kV S/s by 1x1500 MVA ICT. along with corresponding bay, 765kV Bays at Banaskantha and Ahmedabad for Banaskantha – Ahmedabad 765 kV D/c line.

Cost: Rs. 1207 Cr.

Transmission System for providing connectivity to RE projects in Gujarat [Lakadia (2000MW)]

- Establishment of 4x500MVA, 400/220kV ICTs at Lakadia (GIS) PS

Cost: Rs. 196 Cr.

Additional (9th) 400/220kV ICT at Bhuj PS (other than 4000MW injection under SECI bids upto Tranche-IV)

- Additional 1x500MVA 400/220kV (9th) ICT, for injection from any additional RE project (other than 4000MW injection under SECI bids upto Tranche IV) in existing Bhuj PS with associated 400 kV GIS bay and 220kV AIS bay.

Cost: Rs. 37 Cr.

Madhya Pradesh:

Transmission system for evacuation of power from RE projects in Rajgarh (2500 MW) SEZ in Madhya Pradesh - Phase-I: 1500

- Establishment of 400/220 kV, 3X500 MVA at Pachora SEZ PP with 420kV (125 MVAR) bus reactor
- Pachora SEZ PP -Bhopal (Sterlite) 400 kV D/c line (Quad/HTLS) (320ckm) (with minimum capacity of 2100 MVA/ckt at nominal voltage) along with 80MVA switchable line reactors on each circuit at Pachora end
- 2 no. of 400 kV line bays at Bhopal (Sterlite) for Pachora SEZ PP -Bhopal (Sterlite) 400 kV D/c line (Quad/HTLS) (with minimum capacity of 2100 MVA/ckt at nominal voltage)

Cost: Rs. 387 Cr.

Planned Under Transmission system for evacuation of power from RE projects in Rajgarh (2500 MW) SEZ in Madhya Pradesh - Phase-II: 1000

- 400/220 kV, 2x500 MVA ICT augmentation at Pachora PS
- Pachora SEZ PP – Shujalpur 400 kV D/c line (Quad/HTLS) (with minimum capacity of 2100 MVA/ckt at nominal voltage)- 80km
- 2 no. of 400 kV line bays at Shujalpur for Pachora – Shujalpur 400kV D/c line (Quad/ HTLS) (with minimum capacity of 2100 MVA/ckt at nominal voltage)

Cost: Rs. 252.64 Cr.

ICT augmentation at 2x315MVA 400/220kV Shujalpur (PG) Substation

- Augmentation of Shujalpur S/s by 400/220kV, 1x500MVA ICT (3rd)

Cost: Rs. 32.75 Cr.

Transmission system for evacuation of power from Neemuch SEZ scheme

- Establishment of 2x500 MVA, 400/220 kV Pooling Station (AIS) at Neemuch with 1x125 MVA Bus Reactor
- Neemuch PS- Mandsaur S/stn 400 kV D/c line (conductor with minimum capacity of 2100 MVA/Ckt at nominal voltage)

Cost: Rs. 547 Cr.

Transmission system for evacuation of power from RE projects in Chhatarpur (1500 MW) in Madhya Pradesh

- Establishment of 3x500 MVA, 400/220 kV Pooling Station at Chhatarpur along with 1X125 MVAR, 420 kV bus reactor at Chhatarpur PS
- LILO of Satna - Bina 400 kV (1st) D/c line at Chhatarpur PS*~ 60 km
**out of Satna – Bina 2xD/c lines, one circuit of 2nd D/c line has been LILOed at Sagar (MPPTCL) substation. The proposed LILO is to be made on the other (1st) D/c line between Satna & Bina.*

Cost: Rs. 238.37 Cr.

Maharashtra

Transmission system for evacuation of power from RE projects in Osmanabad area (1 GW) in Maharashtra.

- Establishment of 4x500MVA, 400/220kV at Kallam PS along with 4 nos. 220kV line bays & 1x125MVar bus reactor at Kallam PS
- LILO of both circuits of Parli (PG) – Pune (GIS) 400kV D/c line at Kallam PS (40ckm)
- Provision of new 50MVar switchable line reactor at Kallam PS end of Kallam – Pune (GIS) 400kV D/c line
- Conversion of 50MVar fixed Line Reactors on each ckt of Parli (PG) – Pune (GIS) 400kV D/c line at Parli (PG) end into switchable.

Cost: Rs. 301 Cr.

400 kV line bay at Solapur PS for St-II connectivity to M/s Toramba (Solapur: S: 1000 MW)

- 1 number of 400kV bay at Solapur (PG) for St-II connectivity to M/s Toramba

Cost: Rs. 10 Cr.

Transmission system for evacuation of power from RE projects in Solapur (1000 MW under Ph-I+ 500 MW under Ph-II) SEZ in Maharashtra.

- Establishment of 400/220 kV, 3x500 MVA at Solapur PP (near Mohol) along with 125MVAR, 420kV Bus Reactor
- Solapur pooling point - Solapur (PG) 400 kV D/c line (twin HTLS) (with minimum capacity of 2100 MVA/ckt at nominal voltage) - 50KM

Cost: Rs. 253 Cr.

Transmission system for evacuation of power from RE projects in Wardha (2500 MW) SEZ in Maharashtra

- Establishment of 400/220 kV, 5X500 MVA at Wardha SEZ PP with 420kV 125 MVAR bus reactor
- LILO of Wardha - Warora Pool 400 kV D/c (Quad) line at Wardha SEZ PP - 85KM

Cost: Rs. 466.84 Cr.

II. Transmission system for evacuation of 11 GW from potential REZ's in Gujarat i.e. 7 GW from Khavda & 4 GW from Dholera

Transmission scheme for evacuation of power from Dholera UMSP (2GW in Phase-I)

- Establishment of 3x1500MVA, 765/400kV Dholera PS with 1x330MVar, 765kV Bus reactor & 1x125 MVar 400kV Bus reactor
- Dholera PS – Vataman switching station 765 kV D/C line – 40 km.
- 400kV line bays for termination of lines for solar park

Cost: Rs. 747 Cr.

Transmission System for evacuation of additional 7 GW RE power from Khavda RE Park - Phase -B

- Establishment of 765 kV Halvad switching station with 765 kV, 2x330 MVar bus reactors (with 110 MVar & 80 MVar 765kV single phase reactor (spare unit for bus/line reactors at Halvad)
- KPS2- Halvad 765 kV D/c line (~220 km length) with 240 MVar switchable line reactor at both ends and 80 MVar single phase spare reactor unit at KPS2 end.
- LILO of Lakadia – Ahmedabad 765 kV D/c line at Halvad (LILO length~50 km)

- 240 MVA 765 kV switchable line reactor on each ckt at Halvad end of Halvad – Ahmedabad 765 kV D/c line (~220 km length)
- Halvad – Vataman 765 kV D/c line (~170 km length) with 1x330 MVA switchable line reactor at Vatman end on each ckt
- Establishment of 765 kV switching station near Vataman with 2x330MVA, 765 kV bus reactor (with 110 MVA 765 kV single phase reactor (spare unit for bus/line reactor)
- LILO of Lakadia – Vadodara 765 kV D/c line at Vataman 765 kV switching station (~10 km LILO length).
- Vataman switching station – Kosamba 765 kV D/c line (~200 km length) with 330 MVA switchable line reactors on each ckt at Kosamba end.
- Conversion of 240 MVA 765 kV switchable line reactor on each ckt at Lakadia end of Lakadia – Ahmedabad 765 kV D/c line (being LILOed at Halvad) into bus reactors with NGR bypassing arrangement
- Conversion of 330 MVA 765 kV switchable line reactor on each ckt at Vadodara end of Lakadia – Vadodara 765 kV D/c line (being LILOed at Vataman) into bus reactors with NGR bypassing arrangement.

Cost: Rs. 4080 Cr.

Southern Region

Transmission system for integration of 18.5 GW REZ in SR

Transmission system under implementation for 8 GW REZ

Transmission Scheme for Evacuation of power from RE sources in Karur/ Tiruppur Wind Energy Zone (Tamil Nadu) (1000 MW) under Phase-I

Cost : Rs 245 Crs.

- Establishment of 2x500 MVA, 400/230 kV Karur Pooling Station (at a location in between Karur Wind Zone and Tiruppur wind zone)
- LILO of both circuits of Pugalur – Pugalur (HVDC) 400 kV D/c line (with Quad Moose ACSR Conductor) at Karur PS
- 4 Nos. of 230 kV line bays for interconnection of wind projects
- 2x125 MVA, 400 kV Bus reactors at Karur PS
- Space provision for Phase-II:
 - 400/230 kV ICTs along with bays: 3 nos.
 - 230 kV line bays: 5 nos.
 - 230 kV bus sectionalizer bays: 2 nos.
- Adequate space provision for future expansion for:
 - 400/230 kV ICTs along with bays: 3 nos.
 - 400 kV line bays: 6 nos.
 - 230 kV line bays: 7 nos

The schedule of implementation would be matching with schedule of RE developers or 18 months from the date of transfer of SPV, whichever is later. – June 2023

Transmission Scheme for Evacuation of power from RE sources in Karur/ Tiruppur Wind Energy Zone (Tamil Nadu) (1500MW) under Phase-II

Cost : Rs 99 Crs.

- Augmentation of 3x500 MVA, 400/230 kV at Karur PS
- 5 Nos. of 230 kV line bays for interconnection of wind projects

Phase-II scheme to be taken up only after receipt of Connectivity/LTA applications beyond 1000 MW at Karur.

Transmission scheme for evacuation of 1000 MW from Gadag SEZ under Phase-I

Cost : Rs 338 Crs.

- Establishment of 400/220 kV, 2x500 MVA Gadag Pooling Station
- Gadag PS - Narendra (New) PS 400 kV (high capacity equivalent to quad moose) D/C Line
- 400 kV line bays (GIS) at Narendra (New) for Gadag PS- Narendra (New) PS 400 kV D/c line
- 220 kV line bays for interconnection of solar projects (4 nos)
- 1x125 MVar (400 kV) bus reactor at Gadag PS
- Future provisions:
 - Space for 400 kV Line bay with switchable line reactor: 8 nos.
 - 400/220 kV ICT along with associated bay: 4 nos.

220 kV:

- Bus sectionalizer bay: 2 nos. (One no. bay for each Main Bus)
- Bus coupler bay: 2 nos.
- Transfer Bus coupler bay: 2 nos.
- Space for future 400/220kV ICT bay: 4 nos.
- Space for future line bay: 8 nos.

The schedule of implementation would be matching with schedule of RE developers or 18 months from the date of transfer of SPV, whichever is later – June 2023

Transmission scheme for evacuation of 1500 MW from Gadag SEZ under Phase-II

Cost : Rs 262 Crs.

- Augmentation of 400/220 kV, 3x500 MVA Gadag Pooling Station
- Gadag PS - Koppal PS 400 kV (high capacity equivalent to quad moose) D/C Line
- 400 kV line bays at Koppal PS for Gadag PS- Koppal PS 400 kV D/c line
- 220 kV line bays for interconnection of solar projects (4 nos)

Transmission scheme for Evacuation of power from RE sources in Koppal Wind Energy Zone (Karnataka) (2500MW)

Cost : Rs 647 Crs.

- Establishment of 3x500 MVA, 400/220 kV pooling station near Munirabad /suitable location in Koppal distt.

- Pooling station (near Munirabad /suitable location in Koppal distt.) - Narendra (New) GIS 400 kV D/c Line (with Quad Moose ACSR conductor)
- 400 kV GIS line bays at Narendra (new) for Koppal PS- Narendra (New) GIS PS 400 kV D/c line
- 5 Nos of 220 kV line bays for interconnection of wind projects
- 2x125 MVA, 400 kV bus reactor at Pooling station (near Munirabad /suitable location in Koppal Distt.)
- Space provision for additional future expansion
 - Space for future 400kV line bay with switchable line reactor: 6 nos.
 - Space for future 400/220kV ICT along with associated bay: 3 nos.
 - Space for future 220kv line bay: 7 nos.

Commissioning schedule of 18 months – April 2023

- Augmentation of 2x500 MVA, 400/220 kV ICTs at pooling station near Munirabad /suitable location in Koppal distt.
- 4 Nos of 220 kV line bays for interconnection of wind projects

Commissioning schedule of 24 months – October 2023

Tirunelveli and Tuticorin Wind Energy Zone (Tamil Nadu) (500 MW)

Cost : Rs 37 Crs.

- Addition of 1x500 MVA, 400/230kV ICTs (4th) at Tuticorin-II GIS sub-station.

Commissioning schedule of 15 months matching with generation schedule – March 2023

Transmission system planned – 10.5 GW

Kurnool(AP) Wind Energy Zone (2500MW) Part A / Kurnool(AP) Wind Energy Zone (500MW) and Solar Energy Zone (1500MW) (Part B) / Ananthapur and Kurnool SEZ (Ananthapur-2500 MW & Kurnool-1000 MW)

Kurnool(AP) Wind Energy Zone (2500MW) Part A

Cost: Rs. 1101 Crs

- Establishment of 2x1500 MVA, 765/400 KV and 5x500 MVA 400/220kV Pooling station at suitable location in Kurnool Distt. (Kurnool-III)
- Kurnool-III Pooling station - Kurnool(new) 765 kV D/c Line
- 220 kV line bays for interconnection of wind projects (9 nos)
- 1x330 MVA (765kV) & 1x125MVA (400kV) bus reactor at Kurnool-III PS
- Adequate space provision for future expansion for
 - 765/400kV ICTs along with bays: 2 nos.
 - 400/220kV ICTs along with bays: 4 nos.
 - 765kV line bays: 6 nos.
 - 400kV line bays: 4 nos.
 - 220kV line bays: 7 nos.
- Augmentation of transformation capacity by 1x1500 MVA, 765/400 KV and 4x500 MVA 400/220kV at Kurnool-III Pooling Station (in matching time frame of Kurnool Part-B)

- Spare ICTs & reactors
 - 1x500 MVA, 765/400 kV, 1-ph ICT
 - 1x110 MVAR, 765 kV, 1-ph. switchable reactor for 330 MVA bus reactor
 - 1x80 MVAR, 765 kV; 1-ph. switchable reactor for 240 MVA line reactor (in matching time frame of Kurnool Part-B)

Kurnool(AP) Wind Energy Zone (500MW) and Solar Energy Zone (1500MW) (Part B)

Cost: Rs. 1604 Crs

- Kurnool-III Pooling station - Maheshwaram(PG) 765 kV D/c Line
- 220 kV line bays for interconnection of wind projects (6 nos) at Kurnool-III Pooling Station
- 240 MVA Switchable line reactors at both ends of Kurnool-III PS – Maheshwaram (PG) 765 kV D/c Line.

Ananthapur and Kurnool SEZ (Ananthapur-2500 MW & Kurnool-1000 MW)

Cost: Rs. 823 Crs

- Establishment of 400/220 kV, 7x500 MVA, Ananthapur pooling station at suitable border location between Ananthapur & Kurnool Distt
- Ananthapur PS - Kurnool-III PS 400 kV (High capacity equivalent to quad moose) D/c Line
- Ananthapur PS - Cuddapah 400 kV (High capacity equivalent to quad moose) D/c Line with 80 MVA switchable line reactor on Ananthapur PS end of each circuit
- 220 kV line bays for interconnection of wind/solar projects (12 nos)
- 2x125 MVA (400kV) bus reactor at Ananthapur PS
- Adequate space provision for future expansion for
 - 400/220kV ICTs along with bays: 1 no.
 - 400kV line bays: 6 nos.
 - 220kV line bays: 4 nos

Gadag Solar Energy Zone, Karnataka (2500MW) Part B

Cost: Rs. 554 Crs

- Upgradation of Narendra New to its rated voltage of 765kV level along with 2x1500 MVA, 765/400kV ICTs and 1x330 MVA Bus Reactor
- Upgradation of Kolhapur (PG) to its rated voltage of 765kV level along with 2x1500 MVA transformer and 1x330 MVA Bus Reactor
- Upgradation/charging of Narendra new - Kolhapur (PG) 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVA switchable Line Reactor on Kolhapur (PG) end of each circuit
- Spare ICTs & reactors
Spare for Narendra New ss:
 - 500 MVA / 765/400 kV 1-phase ICT
 - 110 MVAR, 765 kV, 1 ph Reactor for both the bus reactors and 1X330 MVA line reactor on Madhugiri (Tumkur) - Narendra New 765 kV D/c line
- Spare for Kolhapur (PG) ss:

- 500 MVA / 765/400 kV 1-phase ICT
- 110 MVAR, 765 kV, 1 ph Reactor for both the bus reactors and 1X330 MVAR line reactor on Narendra new- Kolhapur (PG) 765 kV D/c line

Common Transmission System Strengthening in Southern Region for export of power from Solar & Wind Energy Zone in Southern Region

Cost: Rs. 1202 Crs

- Upgradation of Tuticorin PS to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x330 MVAR Bus Reactor
- Upgradation of Dharmapuri (Salem New) to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x240 MVAR Bus Reactor
- Upgradation of Madhugiri (Tumkur) to its rated voltage of 765kV level alongwith 2x1500 MVA, 765/400kV ICTs and 1x240 MVAR Bus Reactor
- Upgradation/charging of Tuticorin PS - Dharmapuri (Salem New) 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVAR switchable Line Reactor on both end of each circuit.
- Upgradation/charging of Dharmapuri (Salem New) - Madhugiri (Tumkur) 765 kV 2xS/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVAR switchable Line Reactor on Dharmapuri (Salem New) end of both ckts.
- Upgradation/charging of Madhugiri (Tumkur) - Narendra New 765 kV D/c line (initially charged at 400 kV) to its rated voltage of 765 kV along with 1x330 MVAR switchable Line Reactor on both end of each circuit.
- Conversion of 400 kV Line Reactors installed on the above 765 kV circuits/ lines (initially charged at 400 kV) mentioned into 400 kV bus Reactor with suitable arrangements at respective substations.
- Spare ICTs & reactors

Spare for Tuticorin PS

- 1x500 MVA, 765/400 kV, 1 ph ICT
- 1x110 MVAR, 765 kV, 1 ph. Switchable reactor for 330 MVAR line/bus reactor

Spare for Dharmapuri (Salem New)

- 1x500 MVA, 765/400 kV, 1ph ICT
- 1x110 MVAR, 765kV, 1 ph. Switchable reactor for 330 MVAR line reactor
- 1x80 MVAR, 765 kV, 1 ph. Switchable reactor for 240 MVAR bus reactor

Spare for Madhugiri (Tumkur):

- 1x500 MVA, 765/400 kV, 1ph ICT
- 1x110 MVAR, 765kV, 1 ph. Switchable reactor for 330 MVAR line reactor
- 1x80 MVAR, 765 kV, 1 ph. Switchable reactor for 240 MVAR bus reactor

Page intentionally left blank.

Annex-7.1.1

Inter-Regional AC transmission Lines Flow

From Name	To Name	Voltage	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
SAKATPUR	BHANPURA-2	220	1	214	155	-43	-45	146	-111	-96	325	56	50
MODAK	BHANPURA-2	220	1	214	217	-3	-12	261	-30	-12	674	288	235
BHINMAL	ZERDA	400	2	857	967	-399	-421	933	-460	-391	1553	23	186
RAPS_C4	SHUJALPR-4	400	1	857	658	155	141	629	-11	6	981	303	272
RAPS_C4	SHUJALPR-4	400	2	857	658	155	141	629	-11	6	981	303	272
SAHUPU_N	PUSAULI BSPT	220	1	214	380	318	143	386	-10	164	188	62	112
RANGIA	MOTANGA	132	1	84	-12	-76	-50	-31	-93	-45	-16	-70	-51
SALAKATI	GELEPHU1	132	1	84	-19	-89	-44	-50	-117	-39	-28	-78	-52

- Note: Highlighted cell indicates Power flow > Thermal limit

Page intentionally left blank.

Annex-7.2

765/400 kV ICT loadings above 80% of MVA rating

Area	From Name	Voltage	To Name	Voltage	Id	MVA Rating	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	BHIWN-PG	400	BHIWN-PG	765	1	1000	-941	98	256	-1134	-274	11	-822	167	83
NORTH	BHIWN-PG	400	BHIWN-PG	765	2	1000	-941	98	256	-1134	-274	11	-822	167	83
NORTH	BHIWANI SR	400	BHIWN-PG	765	2	1000	-652	-32	49	-845	-240	-58	-575	88	85
NORTH	FATEHG-2	400	FATEH-2	765	1	1500	1527	179	156	1522	184	132	1464	42	-17
NORTH	FATEHG-2	400	FATEH-2	765	2	1500	1527	179	156	1522	184	132	1464	42	-17
NORTH	FATEHG-2	400	FATEH-2	765	3	1500	1527	179	156	1522	184	132	1464	42	-17
NORTH	FATEHG-2	400	FATEH-2	765	4	1500	1527	179	156	1522	184	132	1464	42	-17
NORTH	FATEHG-2	400	FATEH-2	765	5	1500	1527	179	156	1522	184	132	1464	42	-17
NORTH	FATEHG-2	400	FATEH-2	765	6	1500	1527	179	156	1522	184	132	1464	42	-17
NORTH	FATEHG-3	400	FATEHG-3	765	1	1500	1406	-47	-46	1380	-62	-48	1496	0	11
NORTH	FATEHG-3	400	FATEHG-3	765	2	1500	1406	-47	-46	1380	-62	-48	1496	0	11
NORTH	FATEHG-3	400	FATEHG-3	765	3	1500	1406	-47	-46	1380	-62	-48	1496	0	11
NORTH	FATEHG-3	400	FATEHG-3	765	4	1500	1406	-47	-46	1380	-62	-48	1496	0	11
NORTH	FATEHG-3	400	FATEHG-3	765	5	1500	1406	-47	-46	1380	-62	-48	1496	0	11
NORTH	FATEHG-3	400	FATEHG-3	765	6	1500	1406	-47	-46	1380	-62	-48	1496	0	11
NORTH	BHADLA-3	400	BHADLA-3	765	6	1500	1746	205	196	1749	234	182	1700	18	-42
NORTH	BHADLA-3	400	BHADLA-3	765	7	1500	1746	205	196	1749	234	182	1700	18	-42
NORTH	ORAI	400	ORAI	765	1	1000	-125	-643	-643	-262	-853	-679	471	-164	2
NORTH	ORAI	400	ORAI	765	2	1000	-125	-643	-643	-262	-853	-679	471	-164	2
EAST	BEGUNIA	400	BEGUNIA	765	2	1500	-935	-1214	-1255	-975	-1116	-1100	-436	-637	-379
EAST	BEGUNIA	400	BEGUNIA	765	3	1500	-935	-1214	-1255	-975	-1116	-1100	-436	-637	-379

Area	From Name	Voltage	To Name	Voltage	Id	MVA Rating	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
SOUTH	ADONI	400	ADONI	765	1	1500	1350	859	765	1335	812	749	740	305	90
SOUTH	ADONI	400	ADONI	765	2	1500	1350	859	765	1335	812	749	740	305	90
SOUTH	ADONI	400	ADONI	765	3	1500	1350	859	765	1335	812	749	740	305	90
SOUTH	NARDR-NW	400	NARENDERA NW	765	1	1500	1244	840	723	1485	1138	1058	1130	494	306
SOUTH	NARDR-NW	400	NARENDERA NW	765	2	1500	1244	840	723	1485	1138	1058	1130	494	306

- Note: Highlighted cell indicates Power flow > MVA rating

400/220 kV ICT loadings above 80% of MVA rating

Area	From Name	Voltage	To Name	Voltage	Id	MVA rating	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	BHADLA-S	220	BHADLA	400	1	500	410	-25	-32	397	-49	-80	375	-90	-86
NORTH	BHADLA-S	220	BHADLA	400	2	500	410	-25	-32	397	-49	-80	375	-90	-86
NORTH	BHADLA-S	220	BHADLA	400	3	500	410	-25	-32	397	-49	-80	375	-90	-86
NORTH	BHADLA-S	220	BHADLA	400	4	500	410	-25	-32	397	-49	-80	375	-90	-86
NORTH	BHADLA-PG	220	BHADLA PG	400	1	500	433	0	0	428	0	0	453	0	0
NORTH	BHADLA-PG	220	BHADLA PG	400	2	500	433	0	0	428	0	0	453	0	0
NORTH	BHADLA-PG	220	BHADLA PG	400	3	500	433	0	0	428	0	0	453	0	0
NORTH	BHADLA-PG	220	BHADLA PG	400	4	500	433	0	0	428	0	0	453	0	0
NORTH	BHADLA-PG	220	BHADLA PG	400	5	500	433	0	0	428	0	0	453	0	0
NORTH	BHADLA-PG	220	BHADLA PG	400	6	500	433	0	0	428	0	0	453	0	0
NORTH	RAMG-II	220	FATEHG-3 SPL	400	1	500	420	0	0	415	0	0	439	0	0
NORTH	RAMG-II	220	FATEHG-3 SPL	400	2	500	420	0	0	415	0	0	439	0	0
NORTH	RAMG-II	220	FATEHG-3 SPL	400	3	500	420	0	0	415	0	0	439	0	0
NORTH	RAMG-II	220	FATEHG-3 SPL	400	4	500	420	0	0	415	0	0	439	0	0

Area	From Name	Voltage	To Name	Voltage	Id	MVA rating	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	RAMG-II	220	FATEHG-3 SPL	400	5	500	420	0	0	415	0	0	439	0	0
NORTH	RAMGARH-I	220	RAMG-I	400	1	500	414	0	0	410	0	0	434	0	0
NORTH	RAMGARH-I	220	RAMG-I	400	2	500	414	0	0	410	0	0	434	0	0
NORTH	FATEH-2	220	FATEHG-2	400	1	500	459	0	0	454	0	0	480	0	0
NORTH	FATEH-2	220	FATEHG-2	400	2	500	459	0	0	454	0	0	480	0	0
NORTH	FATEH-2	220	FATEHG-2	400	3	500	459	0	0	454	0	0	480	0	0
NORTH	FATEH-2	220	FATEHG-2	400	4	500	459	0	0	454	0	0	480	0	0
NORTH	FATEH-2	220	FATEHG-2	400	5	500	459	0	0	454	0	0	480	0	0
NORTH	FATEHG-3	220	FATEHG-3	400	1	500	446	0	0	441	0	0	466	0	0
NORTH	FATEHG-3	220	FATEHG-3	400	2	500	446	0	0	441	0	0	466	0	0
NORTH	FATEHG-3	220	FATEHG-3	400	3	500	446	0	0	441	0	0	466	0	0
NORTH	FATEHG-3	220	FATEHG-3	400	4	500	446	0	0	441	0	0	466	0	0
NORTH	FATEHG-3	220	FATEHG-3	400	5	500	446	0	0	441	0	0	466	0	0
NORTH	FATEHG-4	220	FATEHG-4	400	1	500	387	0	0	383	0	0	405	0	0
NORTH	FATEHG-4	220	FATEHG-4	400	2	500	387	0	0	383	0	0	405	0	0
NORTH	FATEHG-4	220	FATEHG-4	400	3	500	387	0	0	383	0	0	405	0	0
NORTH	FATEHG-4	220	FATEHG-4	400	4	500	387	0	0	383	0	0	405	0	0
NORTH	FATEHG-4	220	FATEHG-4	400	5	500	387	0	0	383	0	0	405	0	0
NORTH	BHADLA-3	220	BHADLA-3	400	1	500	414	0	0	410	0	0	434	0	0
NORTH	BHADLA-3	220	BHADLA-3	400	2	500	414	0	0	410	0	0	434	0	0
NORTH	BHADLA-3	220	BHADLA-3	400	3	500	414	0	0	410	0	0	434	0	0
NORTH	BHADLA-3	220	BHADLA-3	400	4	500	414	0	0	410	0	0	434	0	0
NORTH	BHADLA-3	220	BHADLA-3	400	5	500	414	0	0	410	0	0	434	0	0
NORTH	BHADLA-2	220	BHADLA-2	400	1	500	448	0	0	443	0	0	468	0	0

Area	From Name	Voltage	To Name	Voltage	Id	MVA rating	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	BHADLA-2	220	BHADLA-2	400	2	500	448	0	0	443	0	0	468	0	0
NORTH	BHADLA-2	220	BHADLA-2	400	3	500	448	0	0	443	0	0	468	0	0
NORTH	BHADLA-2	220	BHADLA-2	400	4	500	448	0	0	443	0	0	468	0	0
NORTH	BHADLA-2	220	BHADLA-2	400	5	500	448	0	0	443	0	0	468	0	0
NORTH	BHAD-2 SPLT	220	BHADLA-2	400	1	1500	1308	0	0	1293	0	0	1368	0	0
NORTH	POKARAN-S	220	POKARAN	400	1	500	443	76	55	429	56	24	381	0	-38
NORTH	POKARAN-S	220	POKARAN	400	2	500	443	76	55	429	56	24	381	0	-38
NORTH	KOTA	220	KOTA	400	1	315	-167	-198	-195	-197	-237	-268	-232	-250	-196
NORTH	KOTA	220	KOTA	400	2	315	-167	-198	-195	-197	-237	-268	-232	-250	-196
NORTH	FATEH-SPL 2	220	FATEHG-2	400	1	500	455	0	0	450	0	0	476	0	0
NORTH	FATEH-SPL 2	220	FATEHG-2	400	2	500	455	0	0	450	0	0	476	0	0
NORTH	FATEH-SPL 2	220	FATEHG-2	400	3	500	455	0	0	450	0	0	476	0	0
NORTH	FATEH-SPL 2	220	FATEHG-2	400	4	500	455	0	0	450	0	0	476	0	0
NORTH	FATEH-SPL 2	220	FATEHG-2	400	5	500	455	0	0	450	0	0	476	0	0
NORTH	BHADLA3-SPL	220	BHADLA-3	400	1	0	414	0	0	410	0	0	434	0	0
NORTH	BHADLA3-SPL	220	BHADLA-3	400	2	0	414	0	0	410	0	0	434	0	0
NORTH	BHADLA3-SPL	220	BHADLA-3	400	3	0	414	0	0	410	0	0	434	0	0
NORTH	BHADLA3-SPL	220	BHADLA-3	400	4	0	414	0	0	410	0	0	434	0	0
NORTH	BHADLA3-SPL	220	BHADLA-3	400	5	0	414	0	0	410	0	0	434	0	0
NORTH	REWAROAD	220	REWA	400	1	315	-211	-261	-258	-244	-303	-259	-218	-243	-137
NORTH	AGRA-PG	220	AGRA	400	1	315	-155	-222	-234	-236	-262	-246	-121	-194	-133
NORTH	AGRA-PG	220	AGRA	400	2	315	-155	-222	-234	-236	-262	-246	-121	-194	-133
NORTH	GURUSARAI2	220	GURUSARAI400	400	1	500	429	0	0	424	0	0	448	0	0
NORTH	GURUSARAI2	220	GURUSARAI400	400	2	500	429	0	0	424	0	0	448	0	0

Area	From Name	Voltage	To Name	Voltage	Id	MVA rating	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	GURUSARAI2	220	GURUSARAI400	400	3	500	429	0	0	424	0	0	448	0	0
NORTH	MAHEBA2	220	MAHEBA	400	1	500	389	0	0	385	0	0	407	0	0
NORTH	MAHEBA2	220	MAHEBA	400	2	500	389	0	0	385	0	0	407	0	0
WEST	SOLPR-PG22	220	SOLAPUR-PG	400	1	315	-202	-201	-216	-261	-236	-244	-331	-288	-232

- Note: Highlighted cell indicates Power flow > MVA rating

Page intentionally left blank.

Annex-7.3

765kV Transmission Line loadings above 70% of thermal limit

Area	From Name	To Name	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	NARELA ISTS	MERUT-PG	2	3802	2975	477	575	3079	520	417	2816	81	-41
NORTH	BHADLA-3	SIKAR NEW	1	4363	3073	204	196	3062	233	182	3089	18	-42
NORTH	BHADLA-3	SIKAR NEW	2	4363	3073	204	196	3062	233	182	3089	18	-42

- Note: Highlighted cell indicates Power flow > Thermal Limit

400kV Transmission Line loadings above 70% of thermal limit

Area	From Name	To Name	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
WEST	ASOJ-BYP-KOS	ASOJ4	1	857	-551	-40	-74	-626	-168	-199	-724	-158	-301
WEST	ASOJ-BYP-KOS	KOSAMBA	1	857	551	40	74	626	168	199	724	158	301
WEST	DGM-BYP-NICL	RANCHODPURA	2	857	-543	-490	-431	-608	-519	-457	-598	-490	-435
WEST	DGM-BYP-NICL	NICOL TORREN	2	857	543	490	431	608	519	457	598	490	435
NORTH	KISHENPUR	SAMBA	1	857	776	544	326	814	660	396	428	284	129
NORTH	MALKANA	TALWANDISABO	1	857	-268	-793	-528	-348	-873	-683	-549	-681	-389
NORTH	BHIWANI	BHIWN-PG	1	857	-675	-64	76	-733	-361	-43	-505	2	-7
NORTH	GOPAL PUR	NARELA ISTS	1	857	-974	-413	-421	-994	-458	-455	-736	-132	-6
NORTH	GOPAL PUR	NARELA ISTS	2	857	-974	-413	-421	-994	-458	-455	-736	-132	-6
NORTH	JAISALMER-2	AKAL-4	1	857	342	-654	-579	318	-663	-530	763	-288	-58
NORTH	JAISALMER-2	BARMER-4	1	857	688	-190	-179	679	-178	-115	858	-3	56
NORTH	JAISALMER-2	BARMER-4	2	857	668	-184	-174	659	-173	-112	833	-3	54
NORTH	JAISALMER-2	JODH KANKANI	1	857	865	155	140	847	141	135	847	102	47

Area	From Name	To Name	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	JAISALMER-2	JODH KANKANI	2	857	865	155	140	847	141	135	847	102	47
NORTH	JAISALMER-2	JODH KANKANI	3	857	772	138	125	756	126	120	756	91	42
NORTH	MERTA	JODH KANKANI	1	857	-715	-287	-249	-712	-233	-184	-579	-91	2
NORTH	AKAL-4	JODH KANKANI	1	857	633	306	273	624	295	254	510	163	55
NORTH	BARMER-4	BHINMAL	1	857	742	11	-2	725	1	39	987	183	189
NORTH	BARMER-4	BHINMAL	2	857	742	11	-2	725	1	39	987	183	189
NORTH	KANKROLI	JODH SURPURA	1	857	-680	80	88	-655	109	69	-891	-83	-82
NORTH	KOTA	ANTA-4	1	857	169	-390	-347	-92	-494	-486	-540	-682	-499
NORTH	BASSI	AGRA	1	857	612	89	82	466	19	-36	453	-126	-176
NORTH	NEEMR-PG	SIKAR NEW	1	857	-875	-79	-56	-918	-195	-101	-833	-25	12
NORTH	NEEMR-PG	SIKAR NEW	2	857	-875	-79	-56	-918	-195	-101	-833	-25	12
NORTH	FATEHG-2	BHADLA-3	1	857	-657	65	57	-658	49	38	-736	20	-10
NORTH	FATEHG-2	BHADLA-3	2	857	-657	65	57	-658	49	38	-736	20	-10
NORTH	BIKANER-II	KHETRI	1	857	711	50	47	707	54	40	694	11	-9
NORTH	BIKANER-II	KHETRI	2	857	711	50	47	707	54	40	694	11	-9
NORTH	BIKANER-II	KHETRI	3	857	711	50	47	707	54	40	694	11	-9
NORTH	BIKANER-II	KHETRI	4	857	711	50	47	707	54	40	694	11	-9
NORTH	KHETRI	BHIWADI	1	857	1239	-50	-11	1274	159	46	1172	-27	-78
NORTH	KHETRI	BHIWADI	2	857	1239	-50	-11	1274	159	46	1172	-27	-78
NORTH	DAUSA	AGRA	1	857	674	163	157	558	138	76	486	-62	-132
NORTH	DAUSA	AGRA	2	857	674	163	157	558	138	76	486	-62	-132
NORTH	MEJA	BARA	1	857	-370	-615	-581	-520	-420	-326	-392	-386	-151
NORTH	MEJA	BARA	2	857	-370	-615	-581	-520	-420	-326	-392	-386	-151
NORTH	MEJA	ALLAHABA	1	857	294	478	439	419	710	552	601	729	318

Area	From Name	To Name	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
NORTH	MEJA	ALLAHABA	2	857	294	478	439	419	710	552	601	729	318
NORTH	ORAI	ORAI	1	857	-430	-527	-524	-548	-654	-523	25	-126	6
NORTH	ORAI	ORAI	2	857	-430	-527	-524	-548	-654	-523	25	-126	6
NORTH	GAZIABAD	MUZAFRN4	1	857	-470	-646	-608	-393	-475	-406	-197	-341	-109
NORTH	AGRAUP4	AGRA	2	857	-820	-1031	-1082	-1358	-1068	-936	-387	-578	-343
NORTH	AGRANW	AGRA	2	857	-422	-579	-611	-752	-596	-520	-166	-317	-190
NORTH	RIHAND-G	RIHAN-HV	1	857	754	754	754	754	754	250	754	754	250
NORTH	RIHAND-G	RIHAN-HV	2	857	754	754	754	754	754	250	754	754	250
NORTH	DADR-NCR	DADR-HVD	1	857	-722	-722	-722	-722	-722	-247	-722	-722	-247
NORTH	DADR-NCR	DADR-HVD	2	857	-722	-722	-722	-722	-722	-247	-722	-722	-247
NORTH	LUCK4-PG	LUCK74-P	1	857	-560	-384	-330	-674	-349	-290	-249	-52	35
NORTH	LUCK4-PG	LUCK74-P	2	857	-560	-384	-330	-674	-349	-290	-249	-52	35
NORTH	DADRI_SPLT	MURADNAG-2	1	857	239	586	685	128	350	396	234	461	289
NORTH	ANPARA4	SINGRL4	1	857	-496	-682	-554	-466	-548	-1077	-337	-489	-1115
NRTHEAST	BALIPARA-PG	BON-BAL-FSC1	1	857	412	-668	29	-415	-1153	108	87	-516	-172
NRTHEAST	BALIPARA-PG	BON-BAL-FSC2	1	857	412	-668	29	-415	-1153	108	87	-516	-172
WEST	KNTPC	KORBA-WEST	1	857	821	749	805	623	544	507	621	458	629
WEST	GANCS4	DEHGM4	1	857	-530	-53	-90	-572	-173	-192	-694	-258	-353
WEST	GANCS4	DEHGM4	2	857	-530	-53	-90	-572	-173	-192	-694	-258	-353
WEST	GANCS4	GPEC4	1	857	-682	-377	-332	-775	-439	-403	-750	-289	-398
WEST	GPEC4	KASOR4	1	857	-683	-378	-333	-777	-440	-403	-752	-290	-399
WEST	PIRANA_T	AHMDABAD PG	1	857	-813	-461	-392	-918	-559	-544	-902	-413	-509
WEST	PIRANA_T	AHMDABAD PG	2	857	-813	-461	-392	-918	-559	-544	-902	-413	-509
WEST	KOSAMBA	VAV4	1	857	586	328	350	569	314	293	633	298	357

Area	From Name	To Name	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
WEST	PRANTIJ	SANKHARI	1	857	-560	-314	-259	-616	-215	-204	-606	-125	-142
WEST	PRANTIJ	SANKHARI	2	857	-560	-314	-259	-616	-215	-204	-606	-125	-142
WEST	SATPURA	KORADI-I	1	857	674	266	299	667	121	76	596	185	300
WEST	NAGDA-4	MANDSAUR-4	1	857	-617	37	39	-611	168	141	-786	-9	-46
WEST	NAGDA-4	MANDSAUR-4	2	857	-617	37	39	-611	168	141	-786	-9	-46
WEST	MALWA	MALWA_II	1	857	-267	-90	-81	-212	278	256	-235	-646	-539
WEST	KHARGAR	PADGHEGIS	1	1714	-918	-727	-810	-1032	-826	-856	-1242	-926	-866
WEST	LONIKAND I	PUNE-PG-AIS	1	857	-337	-99	-233	-367	-127	-189	-725	-481	-554
WEST	KARAD4	KOLHAPUR	1	857	-518	-379	-405	-612	-429	-524	-297	-80	-18
WEST	KARAD4	KOLHAPUR	2	857	-518	-379	-405	-612	-429	-524	-297	-80	-18
WEST	KARAD4	KESURDI400	1	857	525	761	650	586	786	698	364	484	241
WEST	DHULE4	BABLESWAR	1	857	485	212	249	556	255	233	631	327	363
WEST	DHULE4	BABLESWAR	2	857	485	212	249	556	255	233	631	327	363
WEST	TAPS4	VELGAON4	2	857	610	535	604	597	535	544	738	654	612
WEST	RGPPL	NAGOTHANE	1	857	272	597	425	321	636	493	-3	326	47
WEST	RGPPL	NAGOTHANE	2	857	272	597	425	321	636	493	-3	326	47
WEST	CHAKAN	PUNE-PG-AIS	1	857	-491	-301	-412	-552	-354	-398	-881	-643	-667
WEST	SOLAPUR-PG	ALKUD	1	857	-23	-405	-255	82	-319	-208	640	246	378
WEST	PUNE-PG-AIS	PUNE-PG-GIS	1	857	-378	-261	-319	-462	-334	-368	-635	-457	-462
WEST	PUNE-PG-AIS	PUNE-PG-GIS	2	857	-378	-261	-319	-462	-334	-368	-635	-457	-462
WEST	PUNE-PG-AIS	PUNE-PG-GIS	3	857	-378	-261	-319	-462	-334	-368	-635	-457	-462
WEST	PUNE-PG-AIS	PUNE-PG-GIS	4	857	-373	-257	-314	-455	-329	-363	-625	-451	-455
WEST	PADGHEGIS	NAVI-MUM	1	1714	889	701	784	996	793	822	1207	900	842
EAST	PANDIABILI	BEGUNIA	1	1093	-799	-1028	-1036	-852	-956	-937	-313	-505	-277

Area	From Name	To Name	Id	Thermal limit	P-Sc1	P-Sc2	P-Sc3	P-Sc4	P-Sc5	P-Sc6	P-Sc7	P-Sc8	P-Sc9
EAST	PANDIABILI	BEGUNIA	2	1093	-799	-1028	-1036	-852	-956	-937	-313	-505	-277
EAST	BARIPADA	KHARAGPUR-WB	1	850	547	606	572	774	755	883	-75	130	85
EAST	SAGARDIGHI_4	FARAKKA	1	1093	-584	-494	-643	-538	-431	-601	-776	-518	-449
EAST	SAGARDIGHI_4	FARAKKA	2	1093	-584	-494	-643	-538	-431	-601	-776	-518	-449
EAST	RANCHI	RNC-SIPT FSC	2	850	-442	-607	-567	-554	-592	-656	21	-153	-108
EAST	RANCHI	RNC-SIPT FSC	1	850	-442	-607	-567	-554	-592	-656	21	-153	-108
SOUTH	CUDP	CHITOR	1	852	517	53	40	666	94	56	866	221	336
SOUTH	KURNOOL4	SSLBPH4	1	852	623	197	250	544	301	309	316	19	-88
SOUTH	RAMGUNDM STP	GAJWEL4	1	852	625	575	607	589	531	508	517	525	584
SOUTH	HYDERABAD	GAJWEL4	1	852	937	834	944	833	708	819	563	631	677
SOUTH	MAILARM4	NARSAPUR	1	852	801	562	704	732	518	636	516	439	533
SOUTH	MAILARM4	NARSAPUR	2	852	801	562	704	732	518	636	516	439	533
SOUTH	RAIC	BELLARY TPP	1	850	-359	-792	-641	-295	-756	-666	-246	-251	-75
SOUTH	GULBRG	YERAMRS TPP	1	948	110	-583	-456	44	-675	-556	-506	-714	-662
SOUTH	GULBRG	YERAMRS TPP	3	948	110	-583	-456	44	-675	-556	-506	-714	-662

- **Note:** Highlighted cell indicates Power flow > Thermal limit

Page intentionally left blank.

Annex-7.4.1

N-1 Contingency of 765/400 kV Transformers

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
1.	354292 KHAVDA-IIS 400.00 358202 KHAVDA-II 765.00 1	OPEN LINE FROM BUS 354292 [KHAVDA-IIS 400.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 3	1109.87	2205.17	1500	147.01	SC-1
2.	524015 NARDR-NW 400.00 528002 NARENDERA NW765.00 1	OPEN LINE FROM BUS 524015 [NARDR-NW 400.00] TO BUS 528002 [NARENDERA NW765.00] CKT 2	1257.03	2151.47	1500	143.43	SC-1
3.	144469 BHIWN-PG 400.00 147704 BHIWN-PG 765.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 147704 [BHIWN-PG 765.00] CKT 2	991.03	1301.48	1000	130.15	SC-1
4.	504049 ADONI 400.00 508049 ADONI 765.00 1	OPEN LINE FROM BUS 504049 [ADONI 400.00] TO BUS 508049 [ADONI 765.00] CKT 2	1369.15	1949.22	1500	129.95	SC-1
5.	164480 FATEHG-2 400.00 167480 FATEH-2 765.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 167480 [FATEH-2 765.00] CKT 2	1560.7	1837.11	1500	122.47	SC-1
6.	164481 FATEHG-3 400.00 167481 FATEHG-3 765.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 167481 [FATEHG-3 765.00] CKT 2	1431.28	1698.65	1500	113.24	SC-1
7.	354203 KHAVDA-III 400.00 358203 KHAVDA-III 765.00 1	OPEN LINE FROM BUS 354203 [KHAVDA-III 400.00] TO BUS 358203 [KHAVDA-III 765.00] CKT 2	1101.96	1651.14	1500	110.08	SC-1
8.	354201 KHAVDA2 400.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 354201 [KHAVDA2 400.00] TO BUS 358299 [KHAVDA2 765.00] CKT 2	1096.77	1644.95	1500	109.66	SC-1
9.	164434 JODH KANKANI400.00 167799 JODH KANKANI765.00 1	OPEN LINE FROM BUS 164434 [JODH KANKANI400.00] TO BUS 167799 [JODH KANKANI765.00] CKT 2	1114.29	1539.42	1500	102.63	SC-1
10	164497 SIKAR NEW 400.00 167497 SIKAR NEW 765.00 1	OPEN LINE FROM BUS 164497 [SIKAR NEW 400.00] TO BUS 167497 [SIKAR NEW 765.00] CKT 2	913.61	1515.82	1500	101.05	SC-1
11	154501 NARELA ISTS 400.00 157001 NARELA ISTS 765.00 1	OPEN LINE FROM BUS 154501 [NARELA ISTS 400.00] TO BUS 157001 [NARELA ISTS 765.00] CKT 2	1143.68	1500.86	1500	100.06	SC-1
12	164498 BHADLA-2 400.00 167498 BHADLA-2 765.00 1	OPEN LINE FROM BUS 164498 [BHADLA-2 400.00] TO BUS 167498 [BHADLA-2 765.00] CKT 2	1231.64	1471.98	1500	98.13	SC-1
13	374050 KOLHAPURPG 400.00 378050 KOLHAPURPG 765.00 1	OPEN LINE FROM BUS 374050 [KOLHAPURPG 400.00] TO BUS 378050 [KOLHAPURPG 765.00] CKT 2	853.54	1467.61	1500	97.84	SC-1
14	164422 RAMG-I 400.00 167422 RAMGARH-I 765.00 1	OPEN LINE FROM BUS 164422 [RAMG-I 400.00] TO BUS 167422 [RAMGARH-I 765.00] CKT 2	927.78	1391.49	1500	92.77	SC-1
15	444090 JEERAT-NEW 400.00 448008 JEERAT7 765.00 1	OPEN LINE FROM BUS 444090 [JEERAT-NEW 400.00] TO BUS 448008 [JEERAT7 765.00] CKT 2	815.96	1363.54	1500	90.9	SC-1
16	374050 KOLHAPURPG 400.00 378050 KOLHAPURPG 765.00 1	OPEN LINE FROM BUS 374050 [KOLHAPURPG 400.00] TO BUS 378050 [KOLHAPURPG 765.00] CKT 2	920.13	1590.35	1500	106.02	SC-2

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
17	174401 UNNAO4 400.00 177407 UNNAO7 765.00 1	OPEN LINE FROM BUS 174401 [UNNAO4 400.00] TO BUS 177407 [UNNAO7 765.00] CKT 2	641.2	1027.34	1000	102.73	SC-2
18	524013 RAIC-NEW 400.00 528003 RAIC800 765.00 1	OPEN LINE FROM BUS 524013 [RAIC-NEW 400.00] TO BUS 528003 [RAIC800 765.00] CKT 2	962	1457.74	1500	97.18	SC-2
19	524015 NARDR-NW 400.00 528002 NARENDERA NW765.00 1	OPEN LINE FROM BUS 524015 [NARDR-NW 400.00] TO BUS 528002 [NARENDERA NW765.00] CKT 2	841.23	1438.1	1500	95.87	SC-2
20	444090 JEERAT-NEW 400.00 448008 JEERAT7 765.00 1	OPEN LINE FROM BUS 444090 [JEERAT-NEW 400.00] TO BUS 448008 [JEERAT7 765.00] CKT 2	838.18	1407.09	1500	93.81	SC-2
21	314008 SIPAT4 400.00 318007 SIPAT 765.00 1	OPEN LINE FROM BUS 314008 [SIPAT4 400.00] TO BUS 318007 [SIPAT 765.00] CKT 2	617.63	925.35	1000	92.53	SC-2
22	174258 ORAI 400.00 177258 ORAI 765.00 1	OPEN LINE FROM BUS 174258 [ORAI 400.00] TO BUS 177258 [ORAI 765.00] CKT 2	645.21	922.69	1000	92.27	SC-2
23	174475 BAL74-PG 400.00 177701 BALI7-PG 765.00 1	OPEN LINE FROM BUS 174475 [BAL74-PG 400.00] TO BUS 177701 [BALI7-PG 765.00] CKT 3	926.09	1357.95	1500	90.53	SC-2
24	174401 UNNAO4 400.00 177407 UNNAO7 765.00 1	OPEN LINE FROM BUS 174401 [UNNAO4 400.00] TO BUS 177407 [UNNAO7 765.00] CKT 2	643.35	1027.76	1000	102.78	SC-3
25	374050 KOLHAPURPG 400.00 378050 KOLHAPURPG 765.00 1	OPEN LINE FROM BUS 374050 [KOLHAPURPG 400.00] TO BUS 378050 [KOLHAPURPG 765.00] CKT 2	863.62	1485.05	1500	99	SC-3
26	444090 JEERAT-NEW 400.00 448008 JEERAT7 765.00 1	OPEN LINE FROM BUS 444090 [JEERAT-NEW 400.00] TO BUS 448008 [JEERAT7 765.00] CKT 2	835.71	1391.7	1500	92.78	SC-3
27	174258 ORAI 400.00 177258 ORAI 765.00 1	OPEN LINE FROM BUS 174258 [ORAI 400.00] TO BUS 177258 [ORAI 765.00] CKT 2	644.98	922.45	1000	92.24	SC-3
28	524015 NARDR-NW 400.00 528002 NARENDERA NW765.00 1	OPEN LINE FROM BUS 524015 [NARDR-NW 400.00] TO BUS 528002 [NARENDERA NW765.00] CKT 2	1488.98	2545.15	1500	169.68	SC-4
29	144469 BHIWN-PG 400.00 147704 BHIWN-PG 765.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 147704 [BHIWN-PG 765.00] CKT 2	1187.82	1561.41	1000	156.14	SC-4
30	354292 KHAVDA-IIS 400.00 358202 KHAVDA-II 765.00 1	OPEN LINE FROM BUS 354292 [KHAVDA-IIS 400.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 3	1155.88	2300.77	1500	153.38	SC-4
31	504049 ADONI 400.00 508049 ADONI 765.00 1	OPEN LINE FROM BUS 504049 [ADONI 400.00] TO BUS 508049 [ADONI 765.00] CKT 2	1351.27	1924.44	1500	128.3	SC-4
32	164480 FATEHG-2 400.00 167480 FATEH-2 765.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 167480 [FATEH-2 765.00] CKT 2	1558.33	1834.22	1500	122.28	SC-4
33	354201 KHAVDA2 400.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 354201 [KHAVDA2 400.00] TO BUS 358299 [KHAVDA2 765.00] CKT 2	1153.51	1723.84	1500	114.92	SC-4
34	354203 KHAVDA-III 400.00 358203 KHAVDA-III 765.00 1	OPEN LINE FROM BUS 354203 [KHAVDA-III 400.00] TO BUS 358203 [KHAVDA-III 765.00] CKT 2	1146.35	1719.81	1500	114.65	SC-4
35	374050 KOLHAPURPG 400.00 378050 KOLHAPURPG 765.00 1	OPEN LINE FROM BUS 374050 [KOLHAPURPG 400.00] TO BUS 378050 [KOLHAPURPG 765.00] CKT 2	980.07	1686.88	1500	112.46	SC-4

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
36	164481 FATEHG-3 400.00 167481 FATEHG-3 765.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 167481 [FATEHG-3 765.00] CKT 2	1405.74	1669.01	1500	111.27	SC-4
37	164497 SIKAR NEW 400.00 167497 SIKAR NEW 765.00 1	OPEN LINE FROM BUS 164497 [SIKAR NEW 400.00] TO BUS 167497 [SIKAR NEW 765.00] CKT 2	955.37	1584.7	1500	105.65	SC-4
38	444090 JEERAT-NEW 400.00 448008 JEERAT7 765.00 1	OPEN LINE FROM BUS 444090 [JEERAT-NEW 400.00] TO BUS 448008 [JEERAT7 765.00] CKT 2	931.83	1556.24	1500	103.75	SC-4
39	134423 MOGA 400.00 137703 MOGA-PG 765.00 1	OPEN LINE FROM BUS 134423 [MOGA 400.00] TO BUS 137703 [MOGA-PG 765.00] CKT 2	899.41	1541.61	1500	102.77	SC-4
40	154501 NARELA ISTS 400.00 157001 NARELA ISTS 765.00 1	OPEN LINE FROM BUS 154501 [NARELA ISTS 400.00] TO BUS 157001 [NARELA ISTS 765.00] CKT 2	1165.48	1529.82	1500	101.99	SC-4
41	164434 JODH KANKANI 400.00 167799 JODH KANKANI 765.00 1	OPEN LINE FROM BUS 164434 [JODH KANKANI 400.00] TO BUS 167799 [JODH KANKANI 765.00] CKT 2	1059.88	1464.59	1500	97.64	SC-4
42	164498 BHADLA-2 400.00 167498 BHADLA-2 765.00 1	OPEN LINE FROM BUS 164498 [BHADLA-2 400.00] TO BUS 167498 [BHADLA-2 765.00] CKT 2	1221.74	1460.05	1500	97.34	SC-4
43	314008 SIPAT4 400.00 318007 SIPAT 765.00 1	OPEN LINE FROM BUS 314008 [SIPAT4 400.00] TO BUS 318007 [SIPAT 765.00] CKT 2	646.6	968.55	1000	96.85	SC-4
44	164422 RAMG-I 400.00 167422 RAMGARH-I 765.00 1	OPEN LINE FROM BUS 164422 [RAMG-I 400.00] TO BUS 167422 [RAMGARH-I 765.00] CKT 2	917.57	1376.18	1500	91.74	SC-4
45	524015 NARDR-NW 400.00 528002 NARENDRA NW 765.00 1	OPEN LINE FROM BUS 524015 [NARDR-NW 400.00] TO BUS 528002 [NARENDRA NW 765.00] CKT 2	1141	1947.43	1500	129.83	SC-5
46	174258 ORAI 400.00 177258 ORAI 765.00 1	OPEN LINE FROM BUS 174258 [ORAI 400.00] TO BUS 177258 [ORAI 765.00] CKT 2	859.68	1234.98	1000	123.5	SC-5
47	174401 UNNAO4 400.00 177407 UNNAO7 765.00 1	OPEN LINE FROM BUS 174401 [UNNAO4 400.00] TO BUS 177407 [UNNAO7 765.00] CKT 2	739.71	1185.86	1000	118.59	SC-5
48	374050 KOLHAPURPG 400.00 378050 KOLHAPURPG 765.00 1	OPEN LINE FROM BUS 374050 [KOLHAPURPG 400.00] TO BUS 378050 [KOLHAPURPG 765.00] CKT 2	994.44	1713.99	1500	114.27	SC-5
49	444090 JEERAT-NEW 400.00 448008 JEERAT7 765.00 1	OPEN LINE FROM BUS 444090 [JEERAT-NEW 400.00] TO BUS 448008 [JEERAT7 765.00] CKT 2	906.44	1507.78	1500	100.52	SC-5
50	544095 TUTI-POOL 400.00 548095 TUTI-POL 765.00 1	OPEN LINE FROM BUS 544095 [TUTI-POOL 400.00] TO BUS 548095 [TUTI-POL 765.00] CKT 2	871.12	1490.87	1500	99.39	SC-5
51	314008 SIPAT4 400.00 318007 SIPAT 765.00 1	OPEN LINE FROM BUS 314008 [SIPAT4 400.00] TO BUS 318007 [SIPAT 765.00] CKT 2	635.69	951.77	1000	95.18	SC-5
52	364012 SATNA-74 400.00 368012 SATNA-7 765.00 1	OPEN LINE FROM BUS 364012 [SATNA-74 400.00] TO BUS 368012 [SATNA-7 765.00] CKT 2	624.97	909.92	1000	90.99	SC-5
53	414201 KATI HAR4 400.00 418201 KATI HAR8 765.00 1	OPEN LINE FROM BUS 414201 [KATI HAR4 400.00] TO BUS 418201 [KATI HAR8 765.00] CKT 4	761.49	1355.29	1500	90.35	SC-5
54	524015 NARDR-NW 400.00 528002 NARENDRA NW 765.00 1	OPEN LINE FROM BUS 524015 [NARDR-NW 400.00] TO BUS 528002 [NARENDRA NW 765.00] CKT 2	1067.04	1820.82	1500	121.39	SC-6

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
55	374050 KOLHAPURPG 400.00 378050 KOLHAPURPG 765.00 1	OPEN LINE FROM BUS 374050 [KOLHAPURPG 400.00] TO BUS 378050 [KOLHAPURPG 765.00] CKT 2	1019.13	1750.62	1500	116.71	SC-6
56	174401 UNNAO4 400.00 177407 UNNAO7 765.00 1	OPEN LINE FROM BUS 174401 [UNNAO4 400.00] TO BUS 177407 [UNNAO7 765.00] CKT 2	675.92	1078.69	1000	107.87	SC-6
57	444090 JEERAT-NEW 400.00 448008 JEERAT7 765.00 1	OPEN LINE FROM BUS 444090 [JEERAT-NEW 400.00] TO BUS 448008 [JEERAT7 765.00] CKT 2	903.01	1500.76	1500	100.05	SC-6
58	314008 SIPAT4 400.00 318007 SIPAT 765.00 1	OPEN LINE FROM BUS 314008 [SIPAT4 400.00] TO BUS 318007 [SIPAT 765.00] CKT 2	665.1	996.44	1000	99.64	SC-6
59	174258 ORAI 400.00 177258 ORAI 765.00 1	OPEN LINE FROM BUS 174258 [ORAI 400.00] TO BUS 177258 [ORAI 765.00] CKT 2	679.97	971.69	1000	97.17	SC-6
60	544095 TUTI-POOL 400.00 548095 TUTI-POL 765.00 1	OPEN LINE FROM BUS 544095 [TUTI-POOL 400.00] TO BUS 548095 [TUTI-POL 765.00] CKT 2	796.32	1361.49	1500	90.77	SC-6
61	524015 NARDR-NW 400.00 528002 NARENDRA NW765.00 1	OPEN LINE FROM BUS 524015 [NARDR-NW 400.00] TO BUS 528002 [NARENDRA NW765.00] CKT 2	1132.62	1929.31	1500	128.62	SC-7
62	354292 KHAVDA-IIS 400.00 358202 KHAVDA-II 765.00 1	OPEN LINE FROM BUS 354292 [KHAVDA-IIS 400.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 3	948.45	1878.14	1500	125.21	SC-7
63	164481 FATEHG-3 400.00 167481 FATEHG-3 765.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 167481 [FATEHG-3 765.00] CKT 2	1533.91	1818.1	1500	121.21	SC-7
64	164480 FATEHG-2 400.00 167480 FATEH-2 765.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 167480 [FATEH-2 765.00] CKT 2	1488.95	1752.73	1500	116.85	SC-7
65	144469 BHIWN-PG 400.00 147704 BHIWN-PG 765.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 147704 [BHIWN-PG 765.00] CKT 2	855.85	1122.03	1000	112.2	SC-7
66	134423 MOGA 400.00 137703 MOGA-PG 765.00 1	OPEN LINE FROM BUS 134423 [MOGA 400.00] TO BUS 137703 [MOGA-PG 765.00] CKT 2	928.27	1578.95	1500	105.26	SC-7
67	364007 GWALIOR-4 400.00 368007 GWALIOR 765.00 1	OPEN LINE FROM BUS 364007 [GWALIOR-4 400.00] TO BUS 368007 [GWALIOR 765.00] CKT 2	816.86	1493.47	1500	99.56	SC-7
68	164422 RAMG-I 400.00 167422 RAMGARH-I 765.00 1	OPEN LINE FROM BUS 164422 [RAMG-I 400.00] TO BUS 167422 [RAMGARH-I 765.00] CKT 2	965.4	1450.32	1500	96.69	SC-7
69	164498 BHADLA-2 400.00 167498 BHADLA-2 765.00 1	OPEN LINE FROM BUS 164498 [BHADLA-2 400.00] TO BUS 167498 [BHADLA-2 765.00] CKT 2	1213.31	1449.73	1500	96.65	SC-7
70	514101 MAHESWRM 400.00 518051 HYDR 800 765.00 1	OPEN LINE FROM BUS 514101 [MAHESWRM 400.00] TO BUS 518051 [HYDR 800 765.00] CKT 2	1076.64	1447.21	1500	96.48	SC-7
71	164497 SIKAR NEW 400.00 167497 SIKAR NEW 765.00 1	OPEN LINE FROM BUS 164497 [SIKAR NEW 400.00] TO BUS 167497 [SIKAR NEW 765.00] CKT 2	867.43	1436.23	1500	95.75	SC-7
72	374051 PADGHEGIS 400.00 378051 PADGHEGIS 765.00 1	OPEN LINE FROM BUS 374051 [PADGHEGIS 400.00] TO BUS 378051 [PADGHEGIS 765.00] CKT 2	1118.67	1434.87	1500	95.66	SC-7
73	544127 ARIYALUR4 400.00 548127 ARIYALUR7 765.00 1	OPEN LINE FROM BUS 544127 [ARIYALUR4 400.00] TO BUS 548127 [ARIYALUR7 765.00] CKT 2	936.99	1409.8	1500	93.99	SC-7

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
74	514061 NIZAMABAD 400.00 518062 NIZAMABAD 765.00 1	OPEN LINE FROM BUS 514061 [NIZAMABAD 400.00] TO BUS 518062 [NIZAMABAD 765.00] CKT 3	1039.12	1406.34	1500	93.76	SC-7
75	354203 KHAVDA-III 400.00 358203 KHAVDA-III 765.00 1	OPEN LINE FROM BUS 354203 [KHAVDA-III 400.00] TO BUS 358203 [KHAVDA-III 765.00] CKT 2	937.07	1405.54	1500	93.7	SC-7
76	354201 KHAVDA2 400.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 354201 [KHAVDA2 400.00] TO BUS 358299 [KHAVDA2 765.00] CKT 2	927.39	1391.04	1500	92.74	SC-7
77	174401 UNNAO4 400.00 177407 UNNAO7 765.00 1	OPEN LINE FROM BUS 174401 [UNNAO4 400.00] TO BUS 177407 [UNNAO7 765.00] CKT 2	720.76	1154.96	1000	115.5	SC-8
78	544127 ARIYALUR4 400.00 548127 ARIYALUR7 765.00 1	OPEN LINE FROM BUS 544127 [ARIYALUR4 400.00] TO BUS 548127 [ARIYALUR7 765.00] CKT 2	923.81	1386.97	1500	92.46	SC-9

N-1 Contingency of 400/220 kV Transformers

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
1.	164422 RAMG-I 400.00 162422 RAMGARH-I 220.00 1	OPEN LINE FROM BUS 164422 [RAMG-I 400.00] TO BUS 162422 [RAMGARH-I 220.00] CKT 2	436.3	872.54	500	174.51	SC-1
2.	174959 MAHEBA 400.00 172303 MAHEBA2 220.00 1	OPEN LINE FROM BUS 174959 [MAHEBA 400.00] TO BUS 172303 [MAHEBA2 220.00] CKT 2	390.28	782.97	500	156.59	SC-1
3.	164458 BIKANER-NW 400.00 162458 BIKANER 220.00 1	OPEN LINE FROM BUS 164458 [BIKANER-NW 400.00] TO BUS 162458 [BIKANER 220.00] CKT 2	397.23	782.39	500	156.48	SC-1
4.	164757 POKARAN 400.00 162757 POKARAN-S 220.00 1	OPEN LINE FROM BUS 164757 [POKARAN 400.00] TO BUS 162757 [POKARAN-S 220.00] CKT 2	452.55	724.19	500	144.84	SC-1
5.	164459 BHADLA PG 400.00 162659 BHADLA-SPLT 220.00 1	OPEN LINE FROM BUS 164459 [BHADLA PG 400.00] TO BUS 162659 [BHADLA-SPLT 220.00] CKT 2	353.89	707.81	500	141.56	SC-1
6.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	454.23	662.05	500	132.41	SC-1
7.	174964 GURUSARAI400400.00 172301 GURUSARAI2 220.00 1	OPEN LINE FROM BUS 174964 [GURUSARAI400400.00] TO BUS 172301 [GURUSARAI2 220.00] CKT 2	433.6	649.97	500	129.99	SC-1

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
8.	374028 NAGOTHANE 400.00 372150 NAGOTHA2 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	260.01	407.95	315	129.51	SC-1
9.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	301.21	629.58	500	125.92	SC-1
10.	164481 FATEHG-3 400.00 162481 FATEHG-3 220.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 162481 [FATEHG-3 220.00] CKT 2	469.27	586.58	500	117.32	SC-1
11.	164480 FATEHG-2 400.00 162480 FATEH-2 220.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 162480 [FATEH-2 220.00] CKT 2	468.02	584.52	500	116.9	SC-1
12.	164480 FATEHG-2 400.00 163480 FATEH-SPL 2 220.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 163480 [FATEH-SPL 2 220.00] CKT 2	464.33	579.87	500	115.97	SC-1
13.	164498 BHADLA-2 400.00 162498 BHADLA-2 220.00 1	OPEN LINE FROM BUS 164498 [BHADLA-2 400.00] TO BUS 162498 [BHADLA-2 220.00] CKT 2	463.03	577.09	500	115.42	SC-1
14.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	187.57	215.5	190	113.42	SC-1
15.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	192.8	345.74	315	109.76	SC-1
16.	314006 RAIG4 400.00 312006 RAIGPG2 220.00 1	OPEN LINE FROM BUS 314006 [RAIG4 400.00] TO BUS 312006 [RAIGPG2 220.00] CKT 2	232.44	340.66	315	108.15	SC-1
17.	164404 BHADLA 400.00 162285 BHADLA-S 220.00 1	OPEN LINE FROM BUS 164404 [BHADLA 400.00] TO BUS 162285 [BHADLA-S 220.00] CKT 2	425.19	532.08	500	106.42	SC-1
18.	164461 FATEHG-3 SPL400.00 162361 RAMG-II 220.00 1	OPEN LINE FROM BUS 164461 [FATEHG-3 SPL400.00] TO BUS 162361 [RAMG-II 220.00] CKT 2	424.4	530.57	500	106.11	SC-1
19.	164459 BHADLA PG 400.00 162359 BHADLA-PG 220.00 1	OPEN LINE FROM BUS 164459 [BHADLA PG 400.00] TO BUS 162359 [BHADLA-PG 220.00] CKT 2	438.14	525.91	500	105.18	SC-1
20.	164484 BHADLA-3 400.00 162484 BHADLA-3 220.00 1	OPEN LINE FROM BUS 164484 [BHADLA-3 400.00] TO BUS 162484 [BHADLA-3 220.00] CKT 2	415.05	519.05	500	103.81	SC-1

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
21.	164482 FATEHG-4 400.00 162482 FATEHG-4 220.00 1	OPEN LINE FROM BUS 164482 [FATEHG-4 400.00] TO BUS 162482 [FATEHG-4 220.00] CKT 2	407.22	509.02	500	101.8	SC-1
22.	524050 JAGALUR4 400.00 522158 JAGALUR2 220.00 1	OPEN LINE FROM BUS 524050 [JAGALUR4 400.00] TO BUS 522158 [JAGALUR2 220.00] CKT 2	328.72	502.85	500	100.57	SC-1
23.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	206.72	311.29	315	98.82	SC-1
24.	364012 SATNA-74 400.00 362022 SATNAPG-742 220.00 1	OPEN LINE FROM BUS 364012 [SATNA-74 400.00] TO BUS 362022 [SATNAPG-742 220.00] CKT 3	203.32	295.95	315	93.95	SC-1
25.	524044 HIRY 400.00 522044 HIRY 220.00 1	OPEN LINE FROM BUS 524044 [HIRY 400.00] TO BUS 522044 [HIRY 220.00] CKT 3	201.05	293.01	315	93.02	SC-1
26.	164498 BHADLA-2 400.00 162499 BHAD-2 SPLT 220.00 1	OPEN LINE FROM BUS 164484 [BHADLA-3 400.00] TO BUS 167484 [BHADLA-3 765.00] CKT 6	1354.25	1371.13	1500	91.41	SC-1
27.	364021 SHUJALPR-4 400.00 362068 SHUJALP-42 220.00 1	OPEN LINE FROM BUS 364021 [SHUJALPR-4 400.00] TO BUS 362068 [SHUJALP-42 220.00] CKT 2	198.32	284.03	315	90.17	SC-1
28.	134917 LUDHIANA 400.00 132913 LUDHIANA 220.00 1	OPEN LINE FROM BUS 134917 [LUDHIANA 400.00] TO BUS 132913 [LUDHIANA 220.00] CKT 4	231.65	282.97	315	89.83	SC-1
29.	524016 GULBRG 400.00 523090 GLBRGA220 220.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 523090 [GLBRGA220 220.00] CKT 2	449.08	821.96	500	164.39	SC-2
30.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	327.57	685.89	500	137.18	SC-2
31.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	462.09	673.21	500	134.64	SC-2
32.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	206.41	370.79	315	117.71	SC-2
33.	504033 ASPIRI 400.00 502090 ASPIRI 220.00 1	OPEN LINE FROM BUS 504033 [ASPIRI 400.00] TO BUS 502090 [ASPIRI 220.00] CKT 2	238.5	358	315	113.65	SC-2

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
34.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	384.59	556.44	500	111.29	SC-2
35.	144483 KURUKSHETR 400.00 142287 KURUKSHETRA 220.00 1	OPEN LINE FROM BUS 144483 [KURUKSHETR 400.00] TO BUS 142287 [KURUKSHETRA 220.00] CKT 2	410.9	554.75	500	110.95	SC-2
36.	314013 JINDAL-B2 400.00 312013 JINDAL-B2 220.00 1	OPEN LINE FROM BUS 314013 [JINDAL-B2 400.00] TO BUS 312013 [JINDAL-B2 220.00] CKT 2	221.14	345.9	315	109.81	SC-2
37.	164428 CHITTOR4 400.00 162228 CHITTOR-42 220.00 1	OPEN LINE FROM BUS 164428 [CHITTOR4 400.00] TO BUS 162228 [CHITTOR-42 220.00] CKT 2	225.26	330.48	315	104.92	SC-2
38.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	216.62	326.22	315	103.56	SC-2
39.	174497 JAUNPUR 400.00 172497 JAUNPUR 220.00 1	OPEN LINE FROM BUS 174497 [JAUNPUR 400.00] TO BUS 172497 [JAUNPUR 220.00] CKT 2	340.38	515.96	500	103.19	SC-2
40.	314054 DHARDEHI 400.00 312053 DHARDEHI 220.00 1	OPEN LINE FROM BUS 314054 [DHARDEHI 400.00] TO BUS 312053 [DHARDEHI 220.00] CKT 2	241.78	320.74	315	101.82	SC-2
41.	144410 NUHIYANWALI 400.00 142263 NUHIYANWALI 220.00 1	OPEN LINE FROM BUS 144410 [NUHIYANWALI 400.00] TO BUS 142263 [NUHIYANWALI 220.00] CKT 2	213.24	315.7	315	100.22	SC-2
42.	164401 AKAL-4 400.00 162280 AKAL-2 220.00 1	OPEN LINE FROM BUS 164401 [AKAL-4 400.00] TO BUS 162280 [AKAL-2 220.00] CKT 2	398.12	497.06	500	99.41	SC-2
43.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	515.5	594.53	600	99.09	SC-2
44.	174265 REWA 400.00 172112 REWAROAD 220.00 1	OPEN LINE FROM BUS 174474 [ALLAHABA 400.00] TO BUS 172100 [ALLAHABA 220.00] CKT 1	277.01	306.04	315	97.16	SC-2
45.	374057 DOLVI 400.00 372244 NDIL 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	477.95	483.49	500	96.7	SC-2
46.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	159.77	183.48	190	96.57	SC-2

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
47.	174472 OBRA4 400.00 172062 OBRA2 220.00 1	OPEN LINE FROM BUS 174472 [OBRA4 400.00] TO BUS 172062 [OBRA2 220.00] CKT 2	230.51	296.17	315	94.02	SC-2
48.	174922 AGRA 400.00 172115 AGRA-PG 220.00 1	OPEN LINE FROM BUS 174922 [AGRA 400.00] TO BUS 172115 [AGRA-PG 220.00] CKT 2	223.33	291.6	315	92.57	SC-2
49.	164420 KOTA 400.00 162919 KOTA 220.00 1	OPEN LINE FROM BUS 164420 [KOTA 400.00] TO BUS 162919 [KOTA 220.00] CKT 2	223.1	289.75	315	91.99	SC-2
50.	354015 MUNDRA-APL 400.00 352015 MUNDRA-APL 220.00 1	OPEN LINE FROM BUS 354015 [MUNDRA-APL 400.00] TO BUS 352015 [MUNDRA-APL 220.00] CKT 2	208.51	288.67	315	91.64	SC-2
51.	174995 NOIDA-SEC123400.00 172582 NOIDA-SEC123220.00 1	OPEN LINE FROM BUS 174995 [NOIDA-SEC123400.00] TO BUS 172582 [NOIDA-SEC123220.00] CKT 2	139.14	182.31	200	91.16	SC-2
52.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	206.56	285.51	315	90.64	SC-2
53.	134323 DHANANSU 400.00 132324 DHANANSU 220.00 1	OPEN LINE FROM BUS 134323 [DHANANSU 400.00] TO BUS 132324 [DHANANSU 220.00] CKT 2	228.71	285.3	315	90.57	SC-2
54.	124419 DEHAR 400.00 122218 DEHAR 220.00 1	OPEN LINE FROM BUS 124419 [DEHAR 400.00] TO BUS 144460 [PANCH-PG 400.00] CKT 1	169.09	283.95	315	90.14	SC-2
55.	524022 KOPPAL 400.00 522370 KOPPAL 220.00 1	OPEN LINE FROM BUS 524022 [KOPPAL 400.00] TO BUS 522370 [KOPPAL 220.00] CKT 2	357.51	446.71	500	89.34	SC-2
56.	524016 GULBRG 400.00 523090 GLBRGA220 220.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 523090 [GLBRGA220 220.00] CKT 2	334.16	609.93	500	121.99	SC-3
57.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	408.95	596.39	500	119.28	SC-3
58.	314013 JINDAL-B2 400.00 312013 JINDAL-B2 220.00 1	OPEN LINE FROM BUS 314013 [JINDAL-B2 400.00] TO BUS 312013 [JINDAL-B2 220.00] CKT 2	221.2	345.98	315	109.83	SC-3
59.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	376.58	545.46	500	109.09	SC-3

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
60.	174497 JAUNPUR 400.00 172497 JAUNPUR 220.00 1	OPEN LINE FROM BUS 174497 [JAUNPUR 400.00] TO BUS 172497 [JAUNPUR 220.00] CKT 2	350.97	534.84	500	106.97	SC-3
61.	144483 KURUKSHETR 400.00 142287 KURUKSHETRA 220.00 1	OPEN LINE FROM BUS 144483 [KURUKSHETR 400.00] TO BUS 142287 [KURUKSHETRA 220.00] CKT 2	375.94	508.77	500	101.75	SC-3
62.	314054 DHARDEHI 400.00 312053 DHARDEHI 220.00 1	OPEN LINE FROM BUS 314054 [DHARDEHI 400.00] TO BUS 312053 [DHARDEHI 220.00] CKT 2	240.53	319.18	315	101.33	SC-3
63.	174002 BAGPAT 400.00 172114 BAGPAT-PG 220.00 1	OPEN LINE FROM BUS 174002 [BAGPAT 400.00] TO BUS 172114 [BAGPAT-PG 220.00] CKT 2	370.55	504.95	500	100.99	SC-3
64.	164428 CHITTOR4 400.00 162228 CHITTOR-42 220.00 1	OPEN LINE FROM BUS 164428 [CHITTOR4 400.00] TO BUS 162228 [CHITTOR-42 220.00] CKT 2	217.07	314.77	315	99.93	SC-3
65.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	208.78	314.36	315	99.8	SC-3
66.	174995 NOIDA-SEC123400.00 172582 NOIDA-SEC123220.00 1	OPEN LINE FROM BUS 174995 [NOIDA-SEC123400.00] TO BUS 172582 [NOIDA-SEC123220.00] CKT 2	151.04	198.03	200	99.02	SC-3
67.	504033 ASPIRI 400.00 502090 ASPIRI 220.00 1	OPEN LINE FROM BUS 504033 [ASPIRI 400.00] TO BUS 502090 [ASPIRI 220.00] CKT 2	207.38	311.24	315	98.81	SC-3
68.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	162.61	186.87	190	98.35	SC-3
69.	174922 AGRA 400.00 172115 AGRA-PG 220.00 1	OPEN LINE FROM BUS 174922 [AGRA 400.00] TO BUS 172115 [AGRA-PG 220.00] CKT 2	236.92	309.78	315	98.34	SC-3
70.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	218.16	301.99	315	95.87	SC-3
71.	374057 DOLVI 400.00 372244 NDIL 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	472.54	478.33	500	95.67	SC-3
72.	174467 SHAHJ-PG 400.00 172107 SHAHJAHAN4 220.00 1	OPEN LINE FROM BUS 174467 [SHAHJ-PG 400.00] TO BUS 172107 [SHAHJAHAN4 220.00] CKT 2	200.33	298.95	315	94.9	SC-3

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
73.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	163.32	296.72	315	94.2	SC-3
74.	174265 REWA 400.00 172112 REWAROAD 220.00 1	OPEN LINE FROM BUS 174474 [ALLAHABA 400.00] TO BUS 172100 [ALLAHABA 220.00] CKT 1	266	295.94	315	93.95	SC-3
75.	514005 ANNARAM-LI 400.00 512005 ANNARAM -LI2220.00 1	OPEN LINE FROM BUS 514005 [ANNARAM-LI 400.00] TO BUS 512005 [ANNARAM -LI2220.00] CKT 2	361.62	469.72	500	93.94	SC-3
76.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	479.11	553.48	600	92.25	SC-3
77.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	221.76	454.1	500	90.82	SC-3
78.	174472 OBRA4 400.00 172062 OBRA2 220.00 1	OPEN LINE FROM BUS 174472 [OBRA4 400.00] TO BUS 172062 [OBRA2 220.00] CKT 2	219.98	283.19	315	89.9	SC-3
79.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	402.17	911.81	500	182.36	SC-4
80.	164422 RAMG-I 400.00 162422 RAMGARH-I 220.00 1	OPEN LINE FROM BUS 164422 [RAMG-I 400.00] TO BUS 162422 [RAMGARH-I 220.00] CKT 2	431.48	862.89	500	172.58	SC-4
81.	164458 BIKANER-NW 400.00 162458 BIKANER 220.00 1	OPEN LINE FROM BUS 164458 [BIKANER-NW 400.00] TO BUS 162458 [BIKANER 220.00] CKT 2	395.52	778.62	500	155.72	SC-4
82.	174959 MAHEBA 400.00 172303 MAHEBA2 220.00 1	OPEN LINE FROM BUS 174959 [MAHEBA 400.00] TO BUS 172303 [MAHEBA2 220.00] CKT 2	385.43	773.4	500	154.68	SC-4
83.	164757 POKARAN 400.00 162757 POKARAN-S 220.00 1	OPEN LINE FROM BUS 164757 [POKARAN 400.00] TO BUS 162757 [POKARAN-S 220.00] CKT 2	439.42	703.04	500	140.61	SC-4
84.	164459 BHADLA PG 400.00 162659 BHADLA-SPLT 220.00 1	OPEN LINE FROM BUS 164459 [BHADLA PG 400.00] TO BUS 162659 [BHADLA-SPLT 220.00] CKT 2	349.98	699.98	500	140	SC-4
85.	374028 NAGOTHANE 400.00 372150 NAGOTHA2 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	275.9	434.83	315	138.04	SC-4

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
86.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	223.07	256.58	190	135.04	SC-4
87.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	457.95	667.53	500	133.51	SC-4
88.	174964 GURUSARAI400400.00 172301 GURUSARAI2 220.00 1	OPEN LINE FROM BUS 174964 [GURUSARAI400400.00] TO BUS 172301 [GURUSARAI2 220.00] CKT 2	427.41	641.18	500	128.24	SC-4
89.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	610.69	711.92	600	118.65	SC-4
90.	164481 FATEHG-3 400.00 162481 FATEHG-3 220.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 162481 [FATEHG-3 220.00] CKT 2	464.08	580.09	500	116.02	SC-4
91.	164480 FATEHG-2 400.00 162480 FATEH-2 220.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 162480 [FATEH-2 220.00] CKT 2	464.15	578.91	500	115.78	SC-4
92.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	263.03	363.78	315	115.48	SC-4
93.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	202.12	362.48	315	115.07	SC-4
94.	164480 FATEHG-2 400.00 163480 FATEH-SPL 2 220.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 163480 [FATEH-SPL 2 220.00] CKT 2	460.5	574.32	500	114.86	SC-4
95.	164498 BHADLA-2 400.00 162498 BHADLA-2 220.00 1	OPEN LINE FROM BUS 164498 [BHADLA-2 400.00] TO BUS 162498 [BHADLA-2 220.00] CKT 2	460.62	572.84	500	114.57	SC-4
96.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	235.87	355.51	315	112.86	SC-4
97.	354035 VADODARA 400.00 352210 VADODARAPG 220.00 1	OPEN LINE FROM BUS 354035 [VADODARA 400.00] TO BUS 352210 [VADODARAPG 220.00] CKT 2	404.6	553.07	500	110.61	SC-4
98.	504084 KAKINADA SEZ400.00 502284 KAKINADASEZ 220.00 1	OPEN LINE FROM BUS 504084 [KAKINADA SEZ400.00] TO BUS 502284 [KAKINADASEZ 220.00] CKT 2	331.81	551	500	110.2	SC-4

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
99.	164461 FATEHG-3 SPL400.00 162361 RAMG-II 220.00 1	OPEN LINE FROM BUS 164461 [FATEHG-3 SPL400.00] TO BUS 162361 [RAMG-II 220.00] CKT 2	420.15	525.18	500	105.04	SC-4
100.	164459 BHADLA PG 400.00 162359 BHADLA-PG 220.00 1	OPEN LINE FROM BUS 164459 [BHADLA PG 400.00] TO BUS 162359 [BHADLA-PG 220.00] CKT 2	434.1	520.84	500	104.17	SC-4
101.	164404 BHADLA 400.00 162285 BHADLA-S 220.00 1	OPEN LINE FROM BUS 164404 [BHADLA 400.00] TO BUS 162285 [BHADLA-S 220.00] CKT 2	415.24	518.38	500	103.68	SC-4
102.	354012 SUGEN 400.00 352012 SUGEN 220.00 1	OPEN LINE FROM BUS 354012 [SUGEN 400.00] TO BUS 352012 [SUGEN 220.00] CKT 2	261.72	325.7	315	103.4	SC-4
103.	164484 BHADLA-3 400.00 162484 BHADLA-3 220.00 1	OPEN LINE FROM BUS 164484 [BHADLA-3 400.00] TO BUS 162484 [BHADLA-3 220.00] CKT 2	410.45	513.29	500	102.66	SC-4
104.	174922 AGRA 400.00 172115 AGRA-PG 220.00 1	OPEN LINE FROM BUS 174400 [AGRAUP4 400.00] TO BUS 174922 [AGRA 400.00] CKT 2	242.69	321.74	315	102.14	SC-4
105.	134917 LUDHIANA 400.00 132913 LUDHIANA 220.00 1	OPEN LINE FROM BUS 134917 [LUDHIANA 400.00] TO BUS 132913 [LUDHIANA 220.00] CKT 4	262.61	320.41	315	101.72	SC-4
106.	354024 BACHAU 400.00 352024 BHIMASAR 220.00 1	OPEN LINE FROM BUS 354024 [BACHAU 400.00] TO BUS 352024 [BHIMASAR 220.00] CKT 2	223.87	319.47	315	101.42	SC-4
107.	314054 DHARDEHI 400.00 312053 DHARDEHI 220.00 1	OPEN LINE FROM BUS 314054 [DHARDEHI 400.00] TO BUS 312053 [DHARDEHI 220.00] CKT 2	240.94	319.27	315	101.36	SC-4
108.	374029 CHAKAN 400.00 372234 CHAKNII2 220.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 372234 [CHAKNII2 220.00] CKT 2	235.78	316.92	315	100.61	SC-4
109.	164482 FATEHG-4 400.00 162482 FATEHG-4 220.00 1	OPEN LINE FROM BUS 164482 [FATEHG-4 400.00] TO BUS 162482 [FATEHG-4 220.00] CKT 2	402.61	502.53	500	100.51	SC-4
110.	374052 KUDUS 400.00 372254 KUDUS220 220.00 1	OPEN LINE FROM BUS 374052 [KUDUS 400.00] TO BUS 372254 [KUDUS220 220.00] CKT 2	407.69	490.51	500	98.1	SC-4
111.	364012 SATNA-74 400.00 362022 SATNAPG-742 220.00 1	OPEN LINE FROM BUS 364012 [SATNA-74 400.00] TO BUS 362022 [SATNAPG-742 220.00] CKT 3	212.2	308.49	315	97.93	SC-4

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
112.	364021 SHUJALPR-4 400.00 362068 SHUJALP-42 220.00 1	OPEN LINE FROM BUS 364021 [SHUJALPR-4 400.00] TO BUS 362068 [SHUJALP-42 220.00] CKT 2	214.81	307.52	315	97.62	SC-4
113.	524044 HIRY 400.00 522044 HIRY 220.00 1	OPEN LINE FROM BUS 524044 [HIRY 400.00] TO BUS 522044 [HIRY 220.00] CKT 3	209.1	305.54	315	97	SC-4
114.	354021 KASOR4 400.00 352021 KASOR2 220.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354009 [GPEC4 400.00] CKT 1	234.54	303.88	315	96.47	SC-4
115.	114422 KISHENPUR 400.00 112235 KISHENPUR 220.00 1	OPEN LINE FROM BUS 114422 [KISHENPUR 400.00] TO BUS 112235 [KISHENPUR 220.00] CKT 2	242.33	301.86	315	95.83	SC-4
116.	174431 KANPUR 400.00 172103 KANPU-PG 220.00 1	OPEN LINE FROM BUS 174431 [KANPUR 400.00] TO BUS 172103 [KANPU-PG 220.00] CKT 2	238.88	295.49	315	93.81	SC-4
117.	164415 DEEDWANA 400.00 162093 DEEDWANA-42 220.00 1	OPEN LINE FROM BUS 164415 [DEEDWANA 400.00] TO BUS 162093 [DEEDWANA-42 220.00] CKT 2	195.75	294.71	315	93.56	SC-4
118.	354050 PRANTIJ 400.00 352151 PRANTIJ2 220.00 1	OPEN LINE FROM BUS 354050 [PRANTIJ 400.00] TO BUS 352151 [PRANTIJ2 220.00] CKT 2	312.08	466.55	500	93.31	SC-4
119.	354150 DHOLERASP 400.00 352327 DHOLERASP2 220.00 1	OPEN LINE FROM BUS 354150 [DHOLERASP 400.00] TO BUS 352327 [DHOLERASP2 220.00] CKT 2	303.5	465.25	500	93.05	SC-4
120.	374066 MALEGAON400 400.00 372435 MALEGAON220 220.00 1	OPEN LINE FROM BUS 374066 [MALEGAON400 400.00] TO BUS 372435 [MALEGAON220 220.00] CKT 2	308.29	462.04	500	92.41	SC-4
121.	174497 JAUNPUR 400.00 172497 JAUNPUR 220.00 1	OPEN LINE FROM BUS 174497 [JAUNPUR 400.00] TO BUS 172497 [JAUNPUR 220.00] CKT 2	304.62	461.97	500	92.39	SC-4
122.	364009 JABALPUR-4 400.00 362067 JABALPUR-42 220.00 1	OPEN LINE FROM BUS 364009 [JABALPUR-4 400.00] TO BUS 362067 [JABALPUR-42 220.00] CKT 3	201.68	290.18	315	92.12	SC-4
123.	164498 BHADLA-2 400.00 162499 BHAD-2 SPLT 220.00 1	OPEN LINE FROM BUS 164404 [BHADLA 400.00] TO BUS 164456 [BIKANE-4 400.00] CKT 1	1347.53	1363.75	1500	90.92	SC-4
124.	374018 BOISAR 400.00 372066 BOISAR-P 220.00 1	OPEN LINE FROM BUS 374018 [BOISAR 400.00] TO BUS 372066 [BOISAR-P 220.00] CKT 3	240.84	284.58	315	90.34	SC-4

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
125.	194467 KASHIPU4 400.00 192221 KASHIPU2 220.00 1	OPEN LINE FROM BUS 194467 [KASHIPU4 400.00] TO BUS 192221 [KASHIPU2 220.00] CKT 2	183.3	282	315	89.52	SC-4
126.	374070 VELGAON4 400.00 372471 VELGAON 220.00 1	OPEN LINE FROM BUS 374070 [VELGAON4 400.00] TO BUS 372471 [VELGAON 220.00] CKT 2	377.18	446.41	500	89.28	SC-4
127.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	424.1	915.6	500	183.12	SC-5
128.	524016 GULBRG 400.00 523090 GLBRGA220 220.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 523090 [GLBRGA220 220.00] CKT 2	496.77	909.64	500	181.93	SC-5
129.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	531.03	768.73	500	153.75	SC-5
130.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	512.08	746.7	500	149.34	SC-5
131.	504084 KAKINADA SEZ400.00 502284 KAKINADASEZ 220.00 1	OPEN LINE FROM BUS 504084 [KAKINADA SEZ400.00] TO BUS 502284 [KAKINADASEZ 220.00] CKT 2	370.28	622.8	500	124.56	SC-5
132.	174497 JAUNPUR 400.00 172497 JAUNPUR 220.00 1	OPEN LINE FROM BUS 174497 [JAUNPUR 400.00] TO BUS 172497 [JAUNPUR 220.00] CKT 2	402	610.55	500	122.11	SC-5
133.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	249.24	375.91	315	119.34	SC-5
134.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	612.84	711.58	600	118.6	SC-5
135.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	206.01	369.95	315	117.44	SC-5
136.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	189.36	217.69	190	114.57	SC-5
137.	174265 REWA 400.00 172112 REWAROAD 220.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 1	324.39	359.81	315	114.23	SC-5

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
138.	174995 NOIDA-SEC123400.00 172582 NOIDA-SEC123220.00 1	OPEN LINE FROM BUS 174995 [NOIDA-SEC123400.00] TO BUS 172582 [NOIDA-SEC123220.00] CKT 2	173.71	227.63	200	113.81	SC-5
139.	314054 DHARDEHI 400.00 312053 DHARDEHI 220.00 1	OPEN LINE FROM BUS 314054 [DHARDEHI 400.00] TO BUS 312053 [DHARDEHI 220.00] CKT 2	268.76	356.43	315	113.15	SC-5
140.	134323 DHANANSU 400.00 132324 DHANANSU 220.00 1	OPEN LINE FROM BUS 134323 [DHANANSU 400.00] TO BUS 132324 [DHANANSU 220.00] CKT 2	281.98	352.57	315	111.93	SC-5
141.	134917 LUDHIANA 400.00 132913 LUDHIANA 220.00 1	OPEN LINE FROM BUS 134917 [LUDHIANA 400.00] TO BUS 132913 [LUDHIANA 220.00] CKT 4	286.11	351.77	315	111.67	SC-5
142.	174466 PANKI4 400.00 172056 PANKI2 220.00 1	OPEN LINE FROM BUS 174466 [PANKI4 400.00] TO BUS 172056 [PANKI2 220.00] CKT 2	277.66	351.1	315	111.46	SC-5
143.	174922 AGRA 400.00 172115 AGRA-PG 220.00 1	OPEN LINE FROM BUS 174922 [AGRA 400.00] TO BUS 172115 [AGRA-PG 220.00] CKT 2	268.28	350.08	315	111.14	SC-5
144.	504033 ASPIRI 400.00 502090 ASPIRI 220.00 1	OPEN LINE FROM BUS 504033 [ASPIRI 400.00] TO BUS 502090 [ASPIRI 220.00] CKT 2	232.95	349.22	315	110.86	SC-5
145.	144483 KURUKSHETR 400.00 142287 KURUKSHETRA 220.00 1	OPEN LINE FROM BUS 144483 [KURUKSHETR 400.00] TO BUS 142287 [KURUKSHETRA 220.00] CKT 2	407.92	550.46	500	110.09	SC-5
146.	164428 CHITTOR4 400.00 162228 CHITTOR-42 220.00 1	OPEN LINE FROM BUS 164428 [CHITTOR4 400.00] TO BUS 162228 [CHITTOR-42 220.00] CKT 2	243.23	346.44	315	109.98	SC-5
147.	144410 NUHIYANWALI 400.00 142263 NUHIYANWALI 220.00 1	OPEN LINE FROM BUS 144410 [NUHIYANWALI 400.00] TO BUS 142263 [NUHIYANWALI 220.00] CKT 2	232.05	344.78	315	109.45	SC-5
148.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	242.28	334.85	315	106.3	SC-5
149.	174467 SHAHJ-PG 400.00 172107 SHAHJAHAN4 220.00 1	OPEN LINE FROM BUS 174467 [SHAHJ-PG 400.00] TO BUS 172107 [SHAHJAHAN4 220.00] CKT 2	223.74	332.95	315	105.7	SC-5
150.	314013 JINDAL-B2 400.00 312013 JINDAL-B2 220.00 1	OPEN LINE FROM BUS 314013 [JINDAL-B2 400.00] TO BUS 312013 [JINDAL-B2 220.00] CKT 2	211.64	331.35	315	105.19	SC-5

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
151.	164457 SURATG-4 400.00 162257 SURATGARH-42220.00 1	OPEN LINE FROM BUS 164457 [SURATG-4 400.00] TO BUS 162257 [SURATGARH-42220.00] CKT 2	238.49	329.21	315	104.51	SC-5
152.	374057 DOLVI 400.00 372244 NDIL 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	483.44	490.12	500	98.02	SC-5
153.	374029 CHAKAN 400.00 372234 CHAKNII2 220.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 372234 [CHAKNII2 220.00] CKT 2	228.44	308.32	315	97.88	SC-5
154.	164420 KOTA 400.00 162919 KOTA 220.00 1	OPEN LINE FROM BUS 164420 [KOTA 400.00] TO BUS 162919 [KOTA 220.00] CKT 2	238.66	307.11	315	97.5	SC-5
155.	504035 RACHAGUNNERI400.00 502029 RACHAGUNNERI220.00 1	OPEN LINE FROM BUS 504035 [RACHAGUNNERI400.00] TO BUS 502029 [RACHAGUNNERI220.00] CKT 2	224.63	304.43	315	96.65	SC-5
156.	174512 ALIGARH 400.00 172087 ALIGARH 220.00 1	OPEN LINE FROM BUS 174512 [ALIGARH 400.00] TO BUS 172087 [ALIGARH 220.00] CKT 2	336.65	480.43	500	96.09	SC-5
157.	374052 KUDUS 400.00 372254 KUDUS220 220.00 1	OPEN LINE FROM BUS 374052 [KUDUS 400.00] TO BUS 372254 [KUDUS220 220.00] CKT 2	398.65	480.27	500	96.05	SC-5
158.	174462 MAINPURI 400.00 172099 MAINPURI-PG 220.00 1	OPEN LINE FROM BUS 174462 [MAINPURI 400.00] TO BUS 172099 [MAINPURI-PG 220.00] CKT 3	213.38	301.85	315	95.82	SC-5
159.	174408 PARICHHA 400.00 172054 PARICHA2 220.00 1	OPEN LINE FROM BUS 174408 [PARICHHA 400.00] TO BUS 172054 [PARICHA2 220.00] CKT 2	205.47	300.08	315	95.26	SC-5
160.	534049 KASRGODE4 400.00 532956 KASRGODE2 220.00 1	OPEN LINE FROM BUS 534049 [KASRGODE4 400.00] TO BUS 532956 [KASRGODE2 220.00] CKT 2	183.13	298.92	315	94.89	SC-5
161.	124419 DEHAR 400.00 122218 DEHAR 220.00 1	OPEN LINE FROM BUS 124419 [DEHAR 400.00] TO BUS 144460 [PANCH-PG 400.00] CKT 1	250.79	297.12	315	94.32	SC-5
162.	354004 WANAKBORI 400.00 352004 WANAKBORI 220.00 1	OPEN LINE FROM BUS 354001 [ASOJ4 400.00] TO BUS 354004 [WANAKBORI 400.00] CKT 1	267.28	296.18	315	94.03	SC-5
163.	174472 OBRA4 400.00 172062 OBRA2 220.00 1	OPEN LINE FROM BUS 174472 [OBRA4 400.00] TO BUS 172062 [OBRA2 220.00] CKT 2	228.01	293.41	315	93.15	SC-5

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
164.	164921 BHIWADI 400.00 162330 BHIWADI 220.00 1	OPEN LINE FROM BUS 164921 [BHIWADI 400.00] TO BUS 162330 [BHIWADI 220.00] CKT 2	251.93	292.92	315	92.99	SC-5
165.	164401 AKAL-4 400.00 162280 AKAL-2 220.00 1	OPEN LINE FROM BUS 164401 [AKAL-4 400.00] TO BUS 162280 [AKAL-2 220.00] CKT 2	372.22	464.51	500	92.9	SC-5
166.	194467 KASHIPU4 400.00 192221 KASHIPU2 220.00 1	OPEN LINE FROM BUS 194467 [KASHIPU4 400.00] TO BUS 192221 [KASHIPU2 220.00] CKT 2	190.48	291.56	315	92.56	SC-5
167.	164416 AJMER 400.00 162329 AJMER42 220.00 1	OPEN LINE FROM BUS 164416 [AJMER 400.00] TO BUS 162329 [AJMER42 220.00] CKT 2	209.75	291.55	315	92.55	SC-5
168.	354012 SUGEN 400.00 352012 SUGEN 220.00 1	OPEN LINE FROM BUS 354012 [SUGEN 400.00] TO BUS 352012 [SUGEN 220.00] CKT 2	235.56	290.64	315	92.27	SC-5
169.	134405 NAKODAR 400.00 132214 NAKODARPG 220.00 1	OPEN LINE FROM BUS 134405 [NAKODAR 400.00] TO BUS 132214 [NAKODARPG 220.00] CKT 2	228.47	289.13	315	91.79	SC-5
170.	524011 KOLAR 400.00 522011 KOLR 220.00 1	OPEN LINE FROM BUS 524011 [KOLAR 400.00] TO BUS 522011 [KOLR 220.00] CKT 2	227.71	458.2	500	91.64	SC-5
171.	164405 BHINMAL 400.00 162914 BHINM-PG 220.00 1	OPEN LINE FROM BUS 164405 [BHINMAL 400.00] TO BUS 162914 [BHINM-PG 220.00] CKT 2	185.29	286.28	315	90.88	SC-5
172.	134918 JALANDHA 400.00 132918 JALAN-PG 220.00 1	OPEN LINE FROM BUS 134918 [JALANDHA 400.00] TO BUS 132918 [JALAN-PG 220.00] CKT 3	223.93	285.43	315	90.61	SC-5
173.	154928 MAHARANIBAGH400.00 152234 MAHARANIBAGH220.00 1	OPEN LINE FROM BUS 154928 [MAHARANIBAGH400.00] TO BUS 152234 [MAHARANIBAGH220.00] CKT 2	237.66	284.13	315	90.2	SC-5
174.	314021 RAITA 400.00 312021 RAITA 220.00 1	OPEN LINE FROM BUS 314021 [RAITA 400.00] TO BUS 312021 [RAITA 220.00] CKT 3	228.79	282.9	315	89.81	SC-5
175.	314004 BH14 400.00 312004 BHILAI 220.00 1	OPEN LINE FROM BUS 314004 [BH14 400.00] TO BUS 312004 [BHILAI 220.00] CKT 2	240.57	280.59	315	89.08	SC-5
176.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	366.46	773.23	500	154.65	SC-6
177.	524016 GULBRG 400.00 523090 GLBRGA220 220.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 523090 [GLBRGA220 220.00] CKT 2	393.13	716.27	500	143.25	SC-6

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
178.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	490.27	709.02	500	141.8	SC-6
179.	164428 CHITTOR4 400.00 162228 CHITTOR-42 220.00 1	OPEN LINE FROM BUS 164428 [CHITTOR4 400.00] TO BUS 162228 [CHITTOR-42 220.00] CKT 2	276.45	394.47	315	125.23	SC-6
180.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	252.08	381.02	315	120.96	SC-6
181.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	390.42	569.06	500	113.81	SC-6
182.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	182.65	209.86	190	110.45	SC-6
183.	164420 KOTA 400.00 162919 KOTA 220.00 1	OPEN LINE FROM BUS 164420 [KOTA 400.00] TO BUS 162919 [KOTA 220.00] CKT 2	268.43	345.75	315	109.76	SC-6
184.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	246.21	340.39	315	108.06	SC-6
185.	174922 AGRA 400.00 172115 AGRA-PG 220.00 1	OPEN LINE FROM BUS 174922 [AGRA 400.00] TO BUS 172115 [AGRA-PG 220.00] CKT 2	254.26	331.82	315	105.34	SC-6
186.	314013 JINDAL-B2 400.00 312013 JINDAL-B2 220.00 1	OPEN LINE FROM BUS 314013 [JINDAL-B2 400.00] TO BUS 312013 [JINDAL-B2 220.00] CKT 2	211.04	329.82	315	104.7	SC-6
187.	164416 AJMER 400.00 162329 AJMER42 220.00 1	OPEN LINE FROM BUS 164416 [AJMER 400.00] TO BUS 162329 [AJMER42 220.00] CKT 2	237.3	329.82	315	104.7	SC-6
188.	164457 SURATG-4 400.00 162257 SURATGARH-42220.00 1	OPEN LINE FROM BUS 164457 [SURATG-4 400.00] TO BUS 162257 [SURATGARH-42220.00] CKT 2	237.33	326.85	315	103.76	SC-6
189.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	535.13	618.54	600	103.09	SC-6
190.	174497 JAUNPUR 400.00 172497 JAUNPUR 220.00 1	OPEN LINE FROM BUS 174497 [JAUNPUR 400.00] TO BUS 172497 [JAUNPUR 220.00] CKT 2	336.08	509.14	500	101.83	SC-6

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
191.	314054 DHARDEHI 400.00 312053 DHARDEHI 220.00 1	OPEN LINE FROM BUS 314054 [DHARDEHI 400.00] TO BUS 312053 [DHARDEHI 220.00] CKT 2	239.3	317.27	315	100.72	SC-6
192.	164405 BHINMAL 400.00 162914 BHINM-PG 220.00 1	OPEN LINE FROM BUS 164405 [BHINMAL 400.00] TO BUS 162914 [BHINM-PG 220.00] CKT 2	199.93	309.21	315	98.16	SC-6
193.	504033 ASPIRI 400.00 502090 ASPIRI 220.00 1	OPEN LINE FROM BUS 504033 [ASPIRI 400.00] TO BUS 502090 [ASPIRI 220.00] CKT 2	204.01	305.87	315	97.1	SC-6
194.	174995 NOIDA-SEC123400.00 172582 NOIDA-SEC123220.00 1	OPEN LINE FROM BUS 174995 [NOIDA-SEC123400.00] TO BUS 172582 [NOIDA-SEC123220.00] CKT 2	147.41	193.15	200	96.57	SC-6
195.	194467 KASHIPU4 400.00 192221 KASHIPU2 220.00 1	OPEN LINE FROM BUS 194467 [KASHIPU4 400.00] TO BUS 192221 [KASHIPU2 220.00] CKT 2	196.69	301.73	315	95.79	SC-6
196.	174265 REWA 400.00 172112 REWAROAD 220.00 1	OPEN LINE FROM BUS 174474 [ALLAHABA 400.00] TO BUS 172100 [ALLAHABA 220.00] CKT 1	265.89	296.02	315	93.98	SC-6
197.	374029 CHAKAN 400.00 372234 CHAKNII2 220.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 372234 [CHAKNII2 220.00] CKT 2	218.15	293.54	315	93.19	SC-6
198.	164410 BHILWA-4 400.00 162288 BHILWA-4 220.00 1	OPEN LINE FROM BUS 164410 [BHILWA-4 400.00] TO BUS 162288 [BHILWA-4 220.00] CKT 2	216.89	288.19	315	91.49	SC-6
199.	174466 PANKI4 400.00 172056 PANKI2 220.00 1	OPEN LINE FROM BUS 174466 [PANKI4 400.00] TO BUS 172056 [PANKI2 220.00] CKT 2	228.9	286.2	315	90.86	SC-6
200.	374057 DOLVI 400.00 372244 NDIL 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	444.75	448.64	500	89.73	SC-6
201.	374052 KUDUS 400.00 372254 KUDUS220 220.00 1	OPEN LINE FROM BUS 374052 [KUDUS 400.00] TO BUS 372254 [KUDUS220 220.00] CKT 2	372.99	448.64	500	89.73	SC-6
202.	164422 RAMG-I 400.00 162422 RAMGARH-I 220.00 1	OPEN LINE FROM BUS 164422 [RAMG-I 400.00] TO BUS 162422 [RAMGARH-I 220.00] CKT 2	448.27	897.66	500	179.53	SC-7
203.	504084 KAKINADA SEZ400.00 502284 KAKINADASEZ 220.00 1	OPEN LINE FROM BUS 504084 [KAKINADA SEZ400.00] TO BUS 502284 [KAKINADASEZ 220.00] CKT 2	525.36	891.67	500	178.33	SC-7

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
204.	174959 MAHEBA 400.00 172303 MAHEBA2 220.00 1	OPEN LINE FROM BUS 174959 [MAHEBA 400.00] TO BUS 172303 [MAHEBA2 220.00] CKT 2	408.99	820.33	500	164.07	SC-7
205.	364012 SATNA-74 400.00 362022 SATNAPG-742 220.00 1	OPEN LINE FROM BUS 364012 [SATNA-74 400.00] TO BUS 362022 [SATNAPG-742 220.00] CKT 3	354.41	516.35	315	163.92	SC-7
206.	164458 BIKANER-NW 400.00 162458 BIKANER 220.00 1	OPEN LINE FROM BUS 164458 [BIKANER-NW 400.00] TO BUS 162458 [BIKANER 220.00] CKT 2	402.21	805.63	500	161.13	SC-7
207.	164459 BHADLA PG 400.00 162659 BHADLA-SPLT 220.00 1	OPEN LINE FROM BUS 164459 [BHADLA PG 400.00] TO BUS 162659 [BHADLA-SPLT 220.00] CKT 2	370.26	740.55	500	148.11	SC-7
208.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	333.22	460.86	315	146.3	SC-7
209.	364021 SHUJALPR-4 400.00 362068 SHUJALP-42 220.00 1	OPEN LINE FROM BUS 364021 [SHUJALPR-4 400.00] TO BUS 362068 [SHUJALP-42 220.00] CKT 2	317.92	455.22	315	144.52	SC-7
210.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	238.68	274.16	190	144.3	SC-7
211.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	341.1	705.41	500	141.08	SC-7
212.	174964 GURUSARAI400400.00 172301 GURUSARAI2 220.00 1	OPEN LINE FROM BUS 174964 [GURUSARAI400400.00] TO BUS 172301 [GURUSARAI2 220.00] CKT 2	450.69	678.01	500	135.6	SC-7
213.	364039 MANDSAUR-4 400.00 362113 MANDSOUR-42 220.00 1	OPEN LINE FROM BUS 364039 [MANDSAUR-4 400.00] TO BUS 362113 [MANDSOUR-42 220.00] CKT 2	294.77	417.6	315	132.57	SC-7
214.	534049 KASRGODE4 400.00 532956 KASRGODE2 220.00 1	OPEN LINE FROM BUS 534049 [KASRGODE4 400.00] TO BUS 532956 [KASRGODE2 220.00] CKT 2	252.85	412.9	315	131.08	SC-7
215.	364009 JABALPUR-4 400.00 362067 JABALPUR-42 220.00 1	OPEN LINE FROM BUS 364009 [JABALPUR-4 400.00] TO BUS 362067 [JABALPUR-42 220.00] CKT 3	278.4	399.56	315	126.84	SC-7
216.	164757 POKARAN 400.00 162757 POKARAN-S 220.00 1	OPEN LINE FROM BUS 164757 [POKARAN 400.00] TO BUS 162757 [POKARAN-S 220.00] CKT 2	385.21	616.27	500	123.25	SC-7

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
217.	164481 FATEHG-3 400.00 162481 FATEHG-3 220.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 162481 [FATEHG-3 220.00] CKT 2	490.98	613.7	500	122.74	SC-7
218.	364042 SAGAR-4 400.00 362053 SAGAR-2 220.00 1	OPEN LINE FROM BUS 364042 [SAGAR-4 400.00] TO BUS 362053 [SAGAR-2 220.00] CKT 2	268.21	382.48	315	121.42	SC-7
219.	164480 FATEHG-2 400.00 162480 FATEH-2 220.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 162480 [FATEH-2 220.00] CKT 2	484.38	605.45	500	121.09	SC-7
220.	164480 FATEHG-2 400.00 163480 FATEH-SPL 2 220.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 163480 [FATEH-SPL 2 220.00] CKT 2	480.5	600.58	500	120.12	SC-7
221.	164498 BHADLA-2 400.00 162498 BHADLA-2 220.00 1	OPEN LINE FROM BUS 164498 [BHADLA-2 400.00] TO BUS 162498 [BHADLA-2 220.00] CKT 2	475.66	594.21	500	118.84	SC-7
222.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	408.46	591.78	500	118.36	SC-7
223.	364007 GWALIOR-4 400.00 362009 GWALIOR-742 220.00 1	OPEN LINE FROM BUS 364007 [GWALIOR-4 400.00] TO BUS 362009 [GWALIOR-742 220.00] CKT 2	290.07	366.68	315	116.41	SC-7
224.	374029 CHAKAN 400.00 372234 CHAKNI2 220.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 372234 [CHAKNI2 220.00] CKT 2	273.56	366.31	315	116.29	SC-7
225.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	241.8	365.22	315	115.94	SC-7
226.	354024 BACHAU 400.00 352024 BHIMASAR 220.00 1	OPEN LINE FROM BUS 354024 [BACHAU 400.00] TO BUS 352024 [BHIMASAR 220.00] CKT 2	247.74	356.58	315	113.2	SC-7
227.	374066 MALEGAON400 400.00 372435 MALEGAON220 220.00 1	OPEN LINE FROM BUS 374066 [MALEGAON400 400.00] TO BUS 372435 [MALEGAON220 220.00] CKT 2	376.03	563.44	500	112.69	SC-7
228.	164461 FATEHG-3 SPL400.00 162361 RAMG-II 220.00 1	OPEN LINE FROM BUS 164461 [FATEHG-3 SPL400.00] TO BUS 162361 [RAMG-II 220.00] CKT 2	441.28	551.96	500	110.39	SC-7
229.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	192.89	345.15	315	109.57	SC-7

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
230.	164459 BHADLA PG 400.00 162359 BHADLA-PG 220.00 1	OPEN LINE FROM BUS 164459 [BHADLA PG 400.00] TO BUS 162359 [BHADLA-PG 220.00] CKT 2	455.94	547.24	500	109.45	SC-7
231.	164484 BHADLA-3 400.00 162484 BHADLA-3 220.00 1	OPEN LINE FROM BUS 164484 [BHADLA-3 400.00] TO BUS 162484 [BHADLA-3 220.00] CKT 2	434.3	543.16	500	108.63	SC-7
232.	504007 CUDP 400.00 502216 CHINAKAMPALL220.00 1	OPEN LINE FROM BUS 504007 [CUDP 400.00] TO BUS 502216 [CHINAKAMPALL220.00] CKT 3	240.25	340.04	315	107.95	SC-7
233.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	557.52	644.7	600	107.45	SC-7
234.	354035 VADODARA 400.00 352210 VADODARAPG 220.00 1	OPEN LINE FROM BUS 354035 [VADODARA 400.00] TO BUS 352210 [VADODARAPG 220.00] CKT 2	392.88	537.04	500	107.41	SC-7
235.	164482 FATEHG-4 400.00 162482 FATEHG-4 220.00 1	OPEN LINE FROM BUS 164482 [FATEHG-4 400.00] TO BUS 162482 [FATEHG-4 220.00] CKT 2	425.88	531.99	500	106.4	SC-7
236.	374052 KUDUS 400.00 372254 KUDUS220 220.00 1	OPEN LINE FROM BUS 374052 [KUDUS 400.00] TO BUS 372254 [KUDUS220 220.00] CKT 2	436.56	524.48	500	104.9	SC-7
237.	364032 JULWNIA-4 400.00 362085 JULWANIA-42 220.00 1	OPEN LINE FROM BUS 364032 [JULWNIA-4 400.00] TO BUS 362085 [JULWANIA-42 220.00] CKT 2	213.19	327.98	315	104.12	SC-7
238.	374018 BOISAR 400.00 372066 BOISAR-P 220.00 1	OPEN LINE FROM BUS 374018 [BOISAR 400.00] TO BUS 372066 [BOISAR-P 220.00] CKT 3	277.2	327.12	315	103.85	SC-7
239.	354019 ZERDA 400.00 352019 ZERDA2 220.00 1	OPEN LINE FROM BUS 354019 [ZERDA 400.00] TO BUS 352019 [ZERDA2 220.00] CKT 2	251.22	311.65	315	98.94	SC-7
240.	354150 DHOLERASP 400.00 352327 DHOLERASP2 220.00 1	OPEN LINE FROM BUS 354150 [DHOLERASP 400.00] TO BUS 352327 [DHOLERASP2 220.00] CKT 2	318.52	494.39	500	98.88	SC-7
241.	374070 VELGAON4 400.00 372471 VELGAON 220.00 1	OPEN LINE FROM BUS 374070 [VELGAON4 400.00] TO BUS 372471 [VELGAON 220.00] CKT 2	412.19	486.64	500	97.33	SC-7
242.	354012 SUGEN 400.00 352012 SUGEN 220.00 1	OPEN LINE FROM BUS 354010 [VAPI4 400.00] TO BUS 354012 [SUGEN 400.00] CKT 1	246.11	306.13	315	97.18	SC-7

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
243.	164420 KOTA 400.00 162919 KOTA 220.00 1	OPEN LINE FROM BUS 164420 [KOTA 400.00] TO BUS 162919 [KOTA 220.00] CKT 2	234.56	302.75	315	96.11	SC-7
244.	194467 KASHIPU4 400.00 192221 KASHIPU2 220.00 1	OPEN LINE FROM BUS 194467 [KASHIPU4 400.00] TO BUS 192221 [KASHIPU2 220.00] CKT 2	195.75	301.5	315	95.71	SC-7
245.	164404 BHADLA 400.00 162285 BHADLA-S 220.00 1	OPEN LINE FROM BUS 164404 [BHADLA 400.00] TO BUS 162285 [BHADLA-S 220.00] CKT 2	381.57	478.44	500	95.69	SC-7
246.	534048 KOTTAYAM4 400.00 532259 KOTTAYAM2 220.00 1	OPEN LINE FROM BUS 534048 [KOTTAYAM4 400.00] TO BUS 532259 [KOTTAYAM2 220.00] CKT 2	233.36	301.06	315	95.58	SC-7
247.	374042 PUNE-PG-AIS 400.00 372275 PUNEPG22 220.00 1	OPEN LINE FROM BUS 374042 [PUNE-PG-AIS 400.00] TO BUS 372275 [PUNEPG22 220.00] CKT 2	241.5	300.23	315	95.31	SC-7
248.	524169 PEENYA4 400.00 522363 PENYA22 220.00 1	OPEN LINE FROM BUS 524169 [PEENYA4 400.00] TO BUS 522363 [PENYA22 220.00] CKT 2	325.93	469.2	500	93.84	SC-7
249.	364084 MORENA-4 400.00 362106 MORENA-42 220.00 1	OPEN LINE FROM BUS 364084 [MORENA-4 400.00] TO BUS 362106 [MORENA-42 220.00] CKT 3	204.15	295.05	315	93.67	SC-7
250.	164498 BHADLA-2 400.00 162499 BHAD-2 SPLT 220.00 1	OPEN LINE FROM BUS 164405 [BHINMAL 400.00] TO BUS 354019 [ZERDA 400.00] CKT 2	1390.18	1403.14	1500	93.54	SC-7
251.	314054 DHARDEHI 400.00 312053 DHARDEHI 220.00 1	OPEN LINE FROM BUS 314054 [DHARDEHI 400.00] TO BUS 312053 [DHARDEHI 220.00] CKT 2	220.42	292.3	315	92.79	SC-7
252.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	318.07	463.16	500	92.63	SC-7
253.	114422 KISHENPUR 400.00 112235 KISHENPUR 220.00 1	OPEN LINE FROM BUS 114422 [KISHENPUR 400.00] TO BUS 112235 [KISHENPUR 220.00] CKT 2	230.91	287.66	315	91.32	SC-7
254.	364004 BINA-4 400.00 362001 BINA-42 220.00 1	OPEN LINE FROM BUS 364004 [BINA-4 400.00] TO BUS 362001 [BINA-42 220.00] CKT 2	237.06	282.19	315	89.59	SC-7
255.	354140 CHARANKA 400.00 352141 CHARANKA 220.00 1	OPEN LINE FROM BUS 354140 [CHARANKA 400.00] TO BUS 352141 [CHARANKA 220.00] CKT 2	174.41	281.31	315	89.31	SC-7

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
256.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	567.43	820.56	500	164.11	SC-8
257.	524016 GULBRG 400.00 523090 GLBRGA220 220.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 523090 [GLBRGA220 220.00] CKT 2	409.11	758.73	500	151.75	SC-8
258.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	323.09	675.76	500	135.15	SC-8
259.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	296.73	410.48	315	130.31	SC-8
260.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	189.47	217.7	190	114.58	SC-8
261.	364012 SATNA-74 400.00 362022 SATNAPG-742 220.00 1	OPEN LINE FROM BUS 364012 [SATNA-74 400.00] TO BUS 362022 [SATNAPG-742 220.00] CKT 3	248.18	360.36	315	114.4	SC-8
262.	374012 PADGH4 400.00 372163 PADGHE22 220.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 372163 [PADGHE22 220.00] CKT 5	560.01	648.42	600	108.07	SC-8
263.	364032 JULWNIA-4 400.00 362085 JULWANIA-42 220.00 1	OPEN LINE FROM BUS 364032 [JULWNIA-4 400.00] TO BUS 362085 [JULWANIA-42 220.00] CKT 2	218.37	335.27	315	106.43	SC-8
264.	164457 SURATG-4 400.00 162257 SURATGARH-42220.00 1	OPEN LINE FROM BUS 164457 [SURATG-4 400.00] TO BUS 162257 [SURATGARH-42220.00] CKT 2	239.94	332.54	315	105.57	SC-8
265.	164420 KOTA 400.00 162919 KOTA 220.00 1	OPEN LINE FROM BUS 164420 [KOTA 400.00] TO BUS 162919 [KOTA 220.00] CKT 2	256.34	330.69	315	104.98	SC-8
266.	374029 CHAKAN 400.00 372234 CHAKNII2 220.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 372234 [CHAKNII2 220.00] CKT 2	245.59	330.26	315	104.84	SC-8
267.	164409 HINDAU-4 400.00 162207 HINDAU-4 220.00 1	OPEN LINE FROM BUS 164409 [HINDAU-4 400.00] TO BUS 162207 [HINDAU-4 220.00] CKT 2	215.32	324.72	315	103.08	SC-8
268.	324002 MAGARWADA-DD400.00 322002 MAGARWADA 220.00 1	OPEN LINE FROM BUS 324002 [MAGARWADA-DD400.00] TO BUS 322002 [MAGARWADA 220.00] CKT 2	172.39	309.22	315	98.16	SC-8

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
269.	374057 DOLVI 400.00 372244 NDIL 220.00 1	OPEN LINE FROM BUS 374028 [NAGOTHANE 400.00] TO BUS 372150 [NAGOTHA2 220.00] CKT 2	483.71	489.79	500	97.96	SC-8
270.	524011 KOLAR 400.00 522011 KOLR 220.00 1	OPEN LINE FROM BUS 524011 [KOLAR 400.00] TO BUS 522011 [KOLR 220.00] CKT 2	237.94	479.03	500	95.81	SC-8
271.	164428 CHITTOR4 400.00 162228 CHITTOR-42 220.00 1	OPEN LINE FROM BUS 164428 [CHITTOR4 400.00] TO BUS 162228 [CHITTOR-42 220.00] CKT 2	210.48	300.53	315	95.41	SC-8
272.	364009 JABALPUR-4 400.00 362067 JABALPUR-42 220.00 1	OPEN LINE FROM BUS 364009 [JABALPUR-4 400.00] TO BUS 362067 [JABALPUR-42 220.00] CKT 3	207.9	297.96	315	94.59	SC-8
273.	374052 KUDUS 400.00 372254 KUDUS220 220.00 1	OPEN LINE FROM BUS 374052 [KUDUS 400.00] TO BUS 372254 [KUDUS220 220.00] CKT 2	392.09	471.92	500	94.38	SC-8
274.	374066 MALEGAON400 400.00 372435 MALEGAON220 220.00 1	OPEN LINE FROM BUS 374066 [MALEGAON400 400.00] TO BUS 372435 [MALEGAON220 220.00] CKT 2	313.4	469.77	500	93.95	SC-8
275.	354004 WANAKBORI 400.00 352004 WANAKBORI 220.00 1	OPEN LINE FROM BUS 354001 [ASOJ4 400.00] TO BUS 354004 [WANAKBORI 400.00] CKT 1	243.55	293.95	315	93.32	SC-8
276.	364031 PITHAMPUR-4 400.00 362029 PITHAMPUR-42220.00 1	OPEN LINE FROM BUS 364031 [PITHAMPUR-4 400.00] TO BUS 362029 [PITHAMPUR-42220.00] CKT 2	218.48	291.52	315	92.55	SC-8
277.	374062 NANDED40 400.00 372325 KUMBHARGAON2220.00 1	OPEN LINE FROM BUS 374062 [NANDED40 400.00] TO BUS 372325 [KUMBHARGAON2220.00] CKT 2	290.54	457.57	500	91.51	SC-8
278.	174265 REWA 400.00 172112 REWAROAD 220.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 1	251.68	287.97	315	91.42	SC-8
279.	374018 BOISAR 400.00 372066 BOISAR-P 220.00 1	OPEN LINE FROM BUS 374018 [BOISAR 400.00] TO BUS 372066 [BOISAR-P 220.00] CKT 3	242.83	286.9	315	91.08	SC-8
280.	144006 SONAROAD 400.00 142212 SOHNAROAD 220.00 1	OPEN LINE FROM BUS 144006 [SONAROAD 400.00] TO BUS 142212 [SOHNAROAD 220.00] CKT 2	309.38	450.61	500	90.12	SC-8
281.	364042 SAGAR-4 400.00 362053 SAGAR-2 220.00 1	OPEN LINE FROM BUS 364042 [SAGAR-4 400.00] TO BUS 362053 [SAGAR-2 220.00] CKT 2	197.72	282.67	315	89.74	SC-8

S.No	Monitored Element	Contingency	Base Flow	Flow under Contingency	MVA rating	% loading	Scenario
282.	374038 KORADI-II 400.00 372393 KORADI-II 220.00 1	OPEN LINE FROM BUS 374038 [KORADI-II 400.00] TO BUS 372393 [KORADI-II 220.00] CKT 2	442.92	641.76	500	128.35	SC-9
283.	354022 HAZIRA4 400.00 352022 HAZIRA2 220.00 1	OPEN LINE FROM BUS 354022 [HAZIRA4 400.00] TO BUS 352022 [HAZIRA2 220.00] CKT 2	292.06	605.95	500	121.19	SC-9
284.	524016 GULBRG 400.00 523090 GLBRGA220 220.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 523090 [GLBRGA220 220.00] CKT 2	280.46	520.03	500	104.01	SC-9
285.	374040 SOLAPUR-PG 400.00 372333 SOLPR-PG22 220.00 1	OPEN LINE FROM BUS 374040 [SOLAPUR-PG 400.00] TO BUS 372333 [SOLPR-PG22 220.00] CKT 2	232.98	322.53	315	102.39	SC-9
286.	374217 NAVI-MUM 400.00 372365 NAVI-MUM220 220.00 1	OPEN LINE FROM BUS 374217 [NAVI-MUM 400.00] TO BUS 372365 [NAVI-MUM220 220.00] CKT 2	167.76	192.71	190	101.42	SC-9
287.	364012 SATNA-74 400.00 362022 SATNAPG-742 220.00 1	OPEN LINE FROM BUS 364012 [SATNA-74 400.00] TO BUS 362022 [SATNAPG-742 220.00] CKT 3	207.72	301.92	315	95.85	SC-9
288.	534049 KASRGODE4 400.00 532956 KASRGODE2 220.00 1	OPEN LINE FROM BUS 534049 [KASRGODE4 400.00] TO BUS 532956 [KASRGODE2 220.00] CKT 2	183.96	299.58	315	95.11	SC-9
289.	354004 WANAKBORI 400.00 352004 WANAKBORI 220.00 1	OPEN LINE FROM BUS 354001 [ASOJ4 400.00] TO BUS 354004 [WANAKBORI 400.00] CKT 1	239.4	285.1	315	90.51	SC-9
290.	374029 CHAKAN 400.00 372234 CHAKNII2 220.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 372234 [CHAKNII2 220.00] CKT 2	208.57	280.4	315	89.02	SC-9

Page intentionally left blank.

Annex-7.4.2

N-1 Contingency of 765 kV Transmission Lines

S.No	Monitored Element	Contingency	Maximum Flow	Flow under Contingency	Rate	% loading	Scenario
1.	358135 BHUJ POOL 765.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 358135 [BHUJ POOL 765.00] TO BUS 358299 [KHAVDA2 765.00] CKT 2	4224.54	4390.18	3500	125.43	SC-1
2.	358147 LAKADIA 765 765.00 358202 KHAVDA-II 765.00 1	OPEN LINE FROM BUS 358147 [LAKADIA 765 765.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 2	4010.85	4189.59	3500	119.7	SC-1
3.	157708 JHATI-PG 765.00 167774 KHETRI 765.00 1	OPEN LINE FROM BUS 157708 [JHATI-PG 765.00] TO BUS 167774 [KHETRI 765.00] CKT 2	3511.42	3826.45	3500	109.33	SC-1
4.	358200 KHAVDA 765 765.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 358147 [LAKADIA 765 765.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 1	3512.4	3670.72	3500	104.88	SC-1
5.	167484 BHADLA-3 765.00 167497 SIKAR NEW 765.00 1	OPEN LINE FROM BUS 167481 [FATEHG-3 765.00] TO BUS 167502 [BEAWAR 765.00] CKT 1	3330.81	3665.22	3500	104.72	SC-1
6.	167458 BIKANER-NW 765.00 167459 BHADLA PG 765.00 1	OPEN LINE FROM BUS 167458 [BIKANER-NW 765.00] TO BUS 167459 [BHADLA PG 765.00] CKT 2	3101.99	3303.05	3500	94.37	SC-1
7.	358202 KHAVDA-II 765.00 358203 KHAVDA-III 765.00 1	OPEN LINE FROM BUS 358202 [KHAVDA-II 765.00] TO BUS 358203 [KHAVDA-III 765.00] CKT 2	3185.59	3276.06	3500	93.6	SC-1
8.	167999 DAUSA 765.00 368007 GWALIOR 765.00 1	OPEN LINE FROM BUS 167999 [DAUSA 765.00] TO BUS 368007 [GWALIOR 765.00] CKT 2	3108.05	3236.91	3500	92.48	SC-1
9.	548087 TIRUVLM 765.00 548127 ARIYALUR7 765.00 1	OPEN LINE FROM BUS 548087 [TIRUVLM 765.00] TO BUS 548127 [ARIYALUR7 765.00] CKT 2	3997.43	3956.05	3500	113.03	SC-2
10.	177000 VARNASI8 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 177000 [VARNASI8 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3662.59	3644.14	3500	104.12	SC-2
11.	368024 SASAN 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 368024 [SASAN 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3816.26	3625.89	3500	103.6	SC-2

S.No	Monitored Element	Contingency	Maximum Flow	Flow under Contingency	Rate	% loading	Scenario
12.	368024 SASAN 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 368024 [SASAN 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3654.05	3654.05	3500	104.4	SC-3
13.	548087 TIRUVLM 765.00 548127 ARIYALUR7 765.00 1	OPEN LINE FROM BUS 548087 [TIRUVLM 765.00] TO BUS 548127 [ARIYALUR7 765.00] CKT 2	3427	3414.4	3500	97.55	SC-3
14.	177000 VARNASI8 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 177000 [VARNASI8 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3270.65	3318.23	3500	94.81	SC-3
15.	358135 BHUJ POOL 765.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 358135 [BHUJ POOL 765.00] TO BUS 358299 [KHAVDA2 765.00] CKT 2	4417.19	4533.92	3000	151.13	SC-4
16.	358147 LAKADIA 765 765.00 358202 KHAVDA-II 765.00 1	OPEN LINE FROM BUS 358147 [LAKADIA 765 765.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 2	4353.82	4491.91	3000	149.73	SC-4
17.	157708 JHATI-PG 765.00 167774 KHETRI 765.00 1	OPEN LINE FROM BUS 157708 [JHATI-PG 765.00] TO BUS 167774 [KHETRI 765.00] CKT 2	3470.07	3812.22	3000	127.07	SC-4
18.	358200 KHAVDA 765 765.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 358147 [LAKADIA 765 765.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 1	3681.13	3801.32	3000	126.71	SC-4
19.	167484 BHADLA-3 765.00 167497 SIKAR NEW 765.00 1	OPEN LINE FROM BUS 167481 [FATEHG-3 765.00] TO BUS 167502 [BEAWAR 765.00] CKT 1	3207.71	3671.22	3000	122.37	SC-4
20.	358202 KHAVDA-II 765.00 358203 KHAVDA-III 765.00 1	OPEN LINE FROM BUS 358202 [KHAVDA-II 765.00] TO BUS 358203 [KHAVDA-III 765.00] CKT 2	3363.2	3445.45	3000	114.85	SC-4
21.	167458 BIKANER-NW 765.00 167459 BHADLA PG 765.00 1	OPEN LINE FROM BUS 167458 [BIKANER-NW 765.00] TO BUS 167459 [BHADLA PG 765.00] CKT 2	3128.02	3354.77	3000	111.83	SC-4
22.	548087 TIRUVLM 765.00 548127 ARIYALUR7 765.00 1	OPEN LINE FROM BUS 548087 [TIRUVLM 765.00] TO BUS 548127 [ARIYALUR7 765.00] CKT 2	3698.55	3685.04	3500	105.29	SC-5
23.	368024 SASAN 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 368024 [SASAN 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3499.7	3323.75	3500	94.96	SC-5
24.	177000 VARNASI8 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 177000 [VARNASI8 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3328.94	3288.65	3500	93.96	SC-5

S.No	Monitored Element	Contingency	Maximum Flow	Flow under Contingency	Rate	% loading	Scenario
25.	318031 TAMNAR 765.00 318998 DHRAM_SPL 765.00 1	OPEN LINE FROM BUS 318031 [TAMNAR 765.00] TO BUS 318998 [DHRAM_SPL 765.00] CKT 2	3206.32	3175.91	3500	90.74	SC-5
26.	177000 VARNASI8 765.00 368025 VIN- POOL 765.00 1	OPEN LINE FROM BUS 177000 [VARNASI8 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3513.67	3565.7	3500	101.88	SC-6
27.	318031 TAMNAR 765.00 318998 DHRAM_SPL 765.00 1	OPEN LINE FROM BUS 318031 [TAMNAR 765.00] TO BUS 318998 [DHRAM_SPL 765.00] CKT 2	3494.41	3519.02	3500	100.54	SC-6
28.	368024 SASAN 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 368024 [SASAN 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3516.37	3516.36	3500	100.47	SC-6
29.	548087 TIRUVM 765.00 548127 ARIYALUR7 765.00 1	OPEN LINE FROM BUS 548087 [TIRUVM 765.00] TO BUS 548127 [ARIYALUR7 765.00] CKT 2	3492.36	3503.76	3500	100.11	SC-6
30.	358135 BHUJ POOL 765.00 358299 KHAVDA2 765.00 1	OPEN LINE FROM BUS 358135 [BHUJ POOL 765.00] TO BUS 358299 [KHAVDA2 765.00] CKT 2	3747.02	3899.25	3500	111.41	SC-7
31.	167429 CHIT-NEW 765.00 167502 BEAWAR 765.00 1	OPEN LINE FROM BUS 167429 [CHIT-NEW 765.00] TO BUS 167502 [BEAWAR 765.00] CKT 2	3492.11	3749.79	3500	107.14	SC-7
32.	167484 BHADLA-3 765.00 167497 SIKAR NEW 765.00 1	OPEN LINE FROM BUS 167481 [FATEHG-3 765.00] TO BUS 167502 [BEAWAR 765.00] CKT 1	3361.23	3651.87	3500	104.34	SC-7
33.	157708 JHATI-PG 765.00 167774 KHETRI 765.00 1	OPEN LINE FROM BUS 157708 [JHATI-PG 765.00] TO BUS 167774 [KHETRI 765.00] CKT 2	3396.65	3575.63	3500	102.16	SC-7
34.	358147 LAKADIA 765 765.00 358202 KHAVDA-II 765.00 1	OPEN LINE FROM BUS 358147 [LAKADIA 765 765.00] TO BUS 358202 [KHAVDA-II 765.00] CKT 2	3250.94	3380.59	3500	96.59	SC-7
35.	368024 SASAN 765.00 368025 VIN-POOL 765.00 1	OPEN LINE FROM BUS 368024 [SASAN 765.00] TO BUS 368025 [VIN-POOL 765.00] CKT 2	3037.19	3037.19	3500	86.78	SC-9

N-1 Contingency of 400 kV Transmission Lines

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
1.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	2533.21	857	295.59	SC-1
2.	164774 KHETRI 400.00 164921 BHIWADI 400.00 1	OPEN LINE FROM BUS 164774 [KHETRI 400.00] TO BUS 164921 [BHIWADI 400.00] CKT 2	1650.66	857	192.61	SC-1
3.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	1643.56	857	191.78	SC-1
4.	154496 GOPAL PUR 400.00 154501 NARELA ISTS 400.00 1	OPEN LINE FROM BUS 154496 [GOPAL PUR 400.00] TO BUS 154501 [NARELA ISTS 400.00] CKT 2	1586.41	857	185.11	SC-1
5.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1514.53	857	176.72	SC-1
6.	164445 NEEMR-PG 400.00 164497 SIKAR NEW 400.00 1	OPEN LINE FROM BUS 164445 [NEEMR-PG 400.00] TO BUS 164497 [SIKAR NEW 400.00] CKT 2	1271.11	857	148.32	SC-1
7.	514051 MAILARM4 400.00 514100 NARSAPUR 400.00 1	OPEN LINE FROM BUS 514051 [MAILARM4 400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 2	1180.98	852	138.61	SC-1
8.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	1142.01	857	133.26	SC-1
9.	374012 PADGH4 400.00 374052 KUDUS 400.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 374052 [KUDUS 400.00] CKT 2	1112.71	857	129.84	SC-1
10.	164402 BARMER-4 400.00 164405 BHINMAL 400.00 1	OPEN LINE FROM BUS 164402 [BARMER-4 400.00] TO BUS 164405 [BHINMAL 400.00] CKT 2	1101.51	857	128.53	SC-1
11.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	1094.28	852	128.44	SC-1
12.	424033 PANDIABILI 400.00 424038 BEGUNIA 400.00 1	OPEN LINE FROM BUS 424033 [PANDIABILI 400.00] TO BUS 424038 [BEGUNIA 400.00] CKT 2	1394.63	1093	127.6	SC-1
13.	164458 BIKANER-NW 400.00 164495 BIKANER-II 400.00 1	OPEN LINE FROM BUS 164458 [BIKANER-NW 400.00] TO BUS 164495 [BIKANER-II 400.00] CKT 2	1042.28	857	121.62	SC-1
14.	164110 JAISALMER-2 400.00 164434 JODH KANKANI400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164434 [JODH KANKANI400.00] CKT 2	1032.57	857	120.49	SC-1
15.	214010 MISA-PG 400.00 214030 BALIPARA-PG 400.00 1	OPEN LINE FROM BUS 214010 [MISA-PG 400.00] TO BUS 214030 [BALIPARA-PG 400.00] CKT 2	992.61	850	116.78	SC-1
16.	314001 KNTPC 400.00 314003 KORBA-WEST 400.00 1	OPEN LINE FROM BUS 314001 [KNTPC 400.00] TO BUS 314005 [BHATP4 400.00] CKT 1	964.39	857	112.53	SC-1
17.	164400 MERTA 400.00 164434 JODH KANKANI400.00 1	OPEN LINE FROM BUS 167773 [JAIPUR 765.00] TO BUS 167799 [JODH KANKANI765.00] CKT 1	927.38	857	108.21	SC-1
18.	114422 KISHENPUR 400.00 114447 SAMBA 400.00 1	OPEN LINE FROM BUS 114422 [KISHENPUR 400.00] TO BUS 114447 [SAMBA 400.00] CKT 2	922.19	857	107.61	SC-1

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
19.	364005 NAGDA-4 400.00 364039 MANDSAUR-4 400.00 1	OPEN LINE FROM BUS 364005 [NAGDA-4 400.00] TO BUS 364039 [MANDSAUR-4 400.00] CKT 2	914.72	857	106.74	SC-1
20.	164110 JAISALMER-2 400.00 164402 BARMER-4 400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164402 [BARMER-4 400.00] CKT 2	911.42	857	106.35	SC-1
21.	164480 FATEHG-2 400.00 164484 BHADLA-3 400.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 164484 [BHADLA-3 400.00] CKT 2	909.2	857	106.09	SC-1
22.	144469 BHIWN-PG 400.00 144669 BHIWANI SR 400.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 147704 [BHIWN-PG 765.00] CKT 1	866.64	857	101.12	SC-1
23.	354003 DEHGM4 400.00 354005 SOJA4 400.00 1	OPEN LINE FROM BUS 354003 [DEHGM4 400.00] TO BUS 354005 [SOJA4 400.00] CKT 2	846.31	857	98.75	SC-1
24.	164419 RAPS_C4 400.00 364021 SHUJALPR-4 400.00 1	OPEN LINE FROM BUS 164419 [RAPS_C4 400.00] TO BUS 364021 [SHUJALPR-4 400.00] CKT 2	845.03	857	98.6	SC-1
25.	164495 BIKANER-II 400.00 164774 KHETRI 400.00 1	OPEN LINE FROM BUS 164495 [BIKANER-II 400.00] TO BUS 164774 [KHETRI 400.00] CKT 2	842.34	857	98.29	SC-1
26.	354052 FEDRA 400.00 354150 DHOLERASP 400.00 1	OPEN LINE FROM BUS 354052 [FEDRA 400.00] TO BUS 354150 [DHOLERASP 400.00] CKT 2	826.79	857	96.47	SC-1
27.	504082 MAILAVARAM 400.00 504132 KONDPRM 400.00 1	OPEN LINE FROM BUS 504082 [MAILAVARAM 400.00] TO BUS 504132 [KONDPRM 400.00] CKT 2	812.02	857	94.75	SC-1
28.	164418 KANKROLI 400.00 164433 JODH SURPURA400.00 1	OPEN LINE FROM BUS 167773 [JAIPUR 765.00] TO BUS 167799 [JODH KANKANI765.00] CKT 1	811.92	857	94.74	SC-1
29.	514029 KAKTIA-G 400.00 514079 WARN4 400.00 1	OPEN LINE FROM BUS 514029 [KAKTIA-G 400.00] TO BUS 514079 [WARN4 400.00] CKT 2	803.67	852	94.33	SC-1
30.	354002 GANCS4 400.00 354009 GPEC4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 1	805.42	857	93.98	SC-1
31.	354009 GPEC4 400.00 354021 KASOR4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 1	805.17	857	93.95	SC-1
32.	514101 MAHESWRM 400.00 514104 MAHESH-TS 400.00 1	OPEN LINE FROM BUS 514101 [MAHESWRM 400.00] TO BUS 514104 [MAHESH-TS 400.00] CKT 2	2045.97	2186	93.59	SC-1
33.	514006 KACHAPU-A LI400.00 514007 KACHAPU-B LI400.00 1	OPEN LINE FROM BUS 514007 [KACHAPU-B LI400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 1	802.05	857	93.59	SC-1
34.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	794.15	852	93.21	SC-1
35.	164999 DAUSA 400.00 174922 AGRA 400.00 1	OPEN LINE FROM BUS 164999 [DAUSA 400.00] TO BUS 174922 [AGRA 400.00] CKT 2	797.24	857	93.03	SC-1
36.	164481 FATEHG-3 400.00 164482 FATEHG-4 400.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 164482 [FATEHG-4 400.00] CKT 2	2026.65	2186	92.71	SC-1
37.	144420 BHIWANI 400.00 144469 BHIWN-PG 400.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 144480 [JINDPG 400.00] CKT 1	792.76	857	92.5	SC-1

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
38.	144404 JHAJAR_N 400.00 144408 DHANONDA 400.00 1	OPEN LINE FROM BUS 144404 [JHAJAR_N 400.00] TO BUS 144408 [DHANONDA 400.00] CKT 2	789.95	857	92.18	SC-1
39.	354050 PRANTIJ 400.00 354137 SANKHARI 400.00 1	OPEN LINE FROM BUS 354050 [PRANTIJ 400.00] TO BUS 354137 [SANKHARI 400.00] CKT 2	789.01	857	92.07	SC-1
40.	144408 DHANONDA 400.00 144599 MOH-DHA SR 400.00 1	OPEN LINE FROM BUS 144408 [DHANONDA 400.00] TO BUS 144598 [MOH-DHA SR1 400.00] CKT 2	786.3	857	91.75	SC-1
41.	144459 MAHIN_HV 400.00 144599 MOH-DHA SR 400.00 1	OPEN LINE FROM BUS 144408 [DHANONDA 400.00] TO BUS 144598 [MOH-DHA SR1 400.00] CKT 2	785.02	857	91.6	SC-1
42.	174058 ORAI 400.00 174258 ORAI 400.00 1	OPEN LINE FROM BUS 174058 [ORAI 400.00] TO BUS 174258 [ORAI 400.00] CKT 2	772.82	857	90.18	SC-1
43.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	771.32	857	90	SC-1
44.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1515.08	857	176.79	SC-2
45.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	1460.74	857	170.45	SC-2
46.	424033 PANDIABILI 400.00 424038 BEGUNIA 400.00 1	OPEN LINE FROM BUS 424033 [PANDIABILI 400.00] TO BUS 424038 [BEGUNIA 400.00] CKT 2	1815.1	1093	166.07	SC-2
47.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	1260.35	857	147.07	SC-2
48.	174468 ANPARA4 400.00 174923 SINGRL4 400.00 1	OPEN LINE FROM BUS 174437 [LUCKN_UP 400.00] TO BUS 174923 [SINGRL4 400.00] CKT 1	1097.6	857	128.07	SC-2
49.	314023 KWPC 400.00 314029 RAIGARH POOL400.00 1	OPEN LINE FROM BUS 314023 [KWPC 400.00] TO BUS 314029 [RAIGARH POOL400.00] CKT 2	1080.54	857	126.08	SC-2
50.	134406 RAJPURA_TH 400.00 134407 RAJPURA 400.00 1	OPEN LINE FROM BUS 134406 [RAJPURA_TH 400.00] TO BUS 134407 [RAJPURA 400.00] CKT 2	1030.11	857	120.2	SC-2
51.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	994.26	852	116.7	SC-2
52.	174000 MEJA 400.00 174263 BARA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174263 [BARA 400.00] CKT 2	976.08	857	113.89	SC-2
53.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	940.51	852	110.39	SC-2
54.	374004 KARAD4 400.00 374065 KESURDI400 400.00 1	OPEN LINE FROM BUS 374015 [JEJ4 400.00] TO BUS 374026 [KOY4-4 400.00] CKT 1	940.42	857	109.73	SC-2
55.	214030 BALIPARA-PG 400.00 214195 BON-BAL-FSC1400.00 1	OPEN LINE FROM BUS 214180 [BORNAGAR 400.00] TO BUS 214196 [BON-BAL-FSC2400.00] CKT 4	938.57	857	109.52	SC-2
56.	214030 BALIPARA-PG 400.00 214196 BON-BAL-FSC2400.00 1	OPEN LINE FROM BUS 214180 [BORNAGAR 400.00] TO BUS 214195 [BON-BAL-FSC1400.00] CKT 3	938.57	857	109.52	SC-2

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
57.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	937.89	857	109.44	SC-2
58.	194001 KANPRAYAG 400.00 194054 PIPALKOTI SW400.00 1	OPEN LINE FROM BUS 194001 [KANPRAYAG 400.00] TO BUS 194054 [PIPALKOTI SW400.00] CKT 2	934.94	857	109.09	SC-2
59.	194001 KANPRAYAG 400.00 194052 SRINAGAR PT 400.00 1	OPEN LINE FROM BUS 194001 [KANPRAYAG 400.00] TO BUS 194052 [SRINAGAR PT 400.00] CKT 2	933.12	857	108.88	SC-2
60.	174058 ORAI 400.00 174258 ORAI 400.00 1	OPEN LINE FROM BUS 174058 [ORAI 400.00] TO BUS 174258 [ORAI 400.00] CKT 2	915.14	857	106.78	SC-2
61.	374024 RGPPL 400.00 374028 NAGOTHANE 400.00 1	OPEN LINE FROM BUS 374024 [RGPPL 400.00] TO BUS 374028 [NAGOTHANE 400.00] CKT 2	898.85	857	104.88	SC-2
62.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	890.13	857	103.87	SC-2
63.	314001 KNTPC 400.00 314003 KORBA-WEST 400.00 1	OPEN LINE FROM BUS 314001 [KNTPC 400.00] TO BUS 314005 [BHATP4 400.00] CKT 1	882.36	857	102.96	SC-2
64.	214560 SILCHAR-PG 400.00 274001 PKBARI-ISTS 400.00 1	OPEN LINE FROM BUS 214560 [SILCHAR-PG 400.00] TO BUS 274001 [PKBARI-ISTS 400.00] CKT 2	1114.24	1089	102.32	SC-2
65.	424044 BARIPADA 400.00 444018 KHARAGPR-WB 400.00 1	OPEN LINE FROM BUS 448001 [MEDINIPUR7 765.00] TO BUS 478046 [RANCHI-NEW 765.00] CKT 1	866.57	850	101.95	SC-2
66.	524003 RAIC 400.00 524082 BELLARY TPP 400.00 1	OPEN LINE FROM BUS 524002 [MNRB 400.00] TO BUS 524003 [RAIC 400.00] CKT 1	859.77	850	101.15	SC-2
67.	174264 KARCHNA 400.00 174265 REWA 400.00 1	OPEN LINE FROM BUS 174264 [KARCHNA 400.00] TO BUS 174265 [REWA 400.00] CKT 2	861.76	857	100.56	SC-2
68.	134325 MALKANA 400.00 134401 TALWANDISABO400.00 1	OPEN LINE FROM BUS 134401 [TALWANDISABO400.00] TO BUS 134404 [MUKATSAR 400.00] CKT 1	858.95	857	100.23	SC-2
69.	154426 BAWANA-G 400.00 154427 BAWANA 400.00 1	OPEN LINE FROM BUS 154426 [BAWANA-G 400.00] TO BUS 154427 [BAWANA 400.00] CKT 2	856.23	857	99.91	SC-2
70.	274001 PKBARI-ISTS 400.00 274160 PURBANOAGAON400.00 1	OPEN LINE FROM BUS 274001 [PKBARI-ISTS 400.00] TO BUS 274160 [PURBANOAGAON400.00] CKT 2	1088.87	1093	99.62	SC-2
71.	274002 SURAJMANI NG400.00 274160 PURBANOAGAON400.00 1	OPEN LINE FROM BUS 274002 [SURAJMANI NG400.00] TO BUS 274160 [PURBANOAGAON400.00] CKT 2	1078.62	1093	98.68	SC-2
72.	444030 ARAMBAGH 400.00 444074 PPSP_NEW 400.00 1	OPEN LINE FROM BUS 444030 [ARAMBAGH 400.00] TO BUS 444074 [PPSP_NEW 400.00] CKT 2	833.99	850	98.12	SC-2
73.	174000 MEJA 400.00 174474 ALLAHABA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 2	823.45	857	96.09	SC-2
74.	174268 GAZIABAD 400.00 174445 MUZAFRN4 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174436 [GNIDA4 400.00] CKT 1	812.73	857	94.83	SC-2
75.	514051 MAILARM4 400.00 514100 NARSAPUR 400.00 1	OPEN LINE FROM BUS 514051 [MAILARM4 400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 2	790.18	852	92.74	SC-2

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
76.	424027 STERLITE 400.00 424050 LAPANGA 400.00 1	OPEN LINE FROM BUS 424027 [STERLITE 400.00] TO BUS 424050 [LAPANGA 400.00] CKT 2	1007.08	1093	92.14	SC-2
77.	504016 VIZPOOL 400.00 504098 HINDJ-OA 400.00 1	OPEN LINE FROM BUS 504016 [VIZPOOL 400.00] TO BUS 504098 [HINDJ-OA 400.00] CKT 2	872.57	948	92.04	SC-2
78.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1514.56	857	176.73	SC-3
79.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	1500.24	857	175.06	SC-3
80.	424033 PANDIABILI 400.00 424038 BEGUNIA 400.00 1	OPEN LINE FROM BUS 424033 [PANDIABILI 400.00] TO BUS 424038 [BEGUNIA 400.00] CKT 2	1839.55	1093	168.3	SC-3
81.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	1090.35	852	127.98	SC-3
82.	314023 KWPC 400.00 314029 RAIGARH POOL400.00 1	OPEN LINE FROM BUS 314023 [KWPC 400.00] TO BUS 314029 [RAIGARH POOL400.00] CKT 2	1079.79	857	126	SC-3
83.	514051 MAILARM4 400.00 514100 NARSAPUR 400.00 1	OPEN LINE FROM BUS 514051 [MAILARM4 400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 2	1032.83	852	121.22	SC-3
84.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	950.92	857	110.96	SC-3
85.	174058 ORAI 400.00 174258 ORAI 400.00 1	OPEN LINE FROM BUS 174058 [ORAI 400.00] TO BUS 174258 [ORAI 400.00] CKT 2	950.79	857	110.94	SC-3
86.	174000 MEJA 400.00 174263 BARA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174263 [BARA 400.00] CKT 2	945.03	857	110.27	SC-3
87.	314001 KNTPC 400.00 314003 KORBA-WEST 400.00 1	OPEN LINE FROM BUS 314001 [KNTPC 400.00] TO BUS 314005 [BHATP4 400.00] CKT 1	940.14	857	109.7	SC-3
88.	154426 BAWANA-G 400.00 154427 BAWANA 400.00 1	OPEN LINE FROM BUS 154426 [BAWANA-G 400.00] TO BUS 154427 [BAWANA 400.00] CKT 2	936.42	857	109.27	SC-3
89.	144404 JHAJAR_N 400.00 144408 DHANONDA 400.00 1	OPEN LINE FROM BUS 144404 [JHAJAR_N 400.00] TO BUS 144408 [DHANONDA 400.00] CKT 2	883	857	103.03	SC-3
90.	174264 KARCHNA 400.00 174265 REWA 400.00 1	OPEN LINE FROM BUS 174264 [KARCHNA 400.00] TO BUS 174265 [REWA 400.00] CKT 2	879.72	857	102.65	SC-3
91.	174439 DADRI SPLT 400.00 174488 MURADNAG-2 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174436 [GNOIDA4 400.00] CKT 1	875.87	857	102.2	SC-3
92.	134406 RAJPURA_TH 400.00 134407 RAJPURA 400.00 1	OPEN LINE FROM BUS 134406 [RAJPURA_TH 400.00] TO BUS 134407 [RAJPURA 400.00] CKT 2	830.72	857	96.93	SC-3
93.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	797.32	852	93.58	SC-3
94.	424027 STERLITE 400.00 424050 LAPANGA 400.00 1	OPEN LINE FROM BUS 424027 [STERLITE 400.00] TO BUS 424050 [LAPANGA 400.00] CKT 2	1019.83	1093	93.31	SC-3

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
95.	144401 KHEDAR 400.00 144403 KIRORI 400.00 1	OPEN LINE FROM BUS 144401 [KHEDAR 400.00] TO BUS 144403 [KIRORI 400.00] CKT 2	798.66	857	93.19	SC-3
96.	174268 GAZIABAD 400.00 174445 MUZAFRN4 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174436 [GNOIDA4 400.00] CKT 1	790.21	857	92.21	SC-3
97.	154427 BAWANA 400.00 184498 TIKRI KHURD 400.00 1	OPEN LINE FROM BUS 154427 [BAWANA 400.00] TO BUS 184498 [TIKRI KHURD 400.00] CKT 2	788.8	857	92.04	SC-3
98.	514006 KACHAPU-A LI400.00 514007 KACAHPU-B LI400.00 1	OPEN LINE FROM BUS 514007 [KACAHPU-B LI400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 1	788.54	857	92.01	SC-3
99.	374004 KARAD4 400.00 374065 KESURDI400 400.00 1	OPEN LINE FROM BUS 374015 [JEJ4 400.00] TO BUS 374026 [KOY4-4 400.00] CKT 1	784.47	857	91.54	SC-3
100.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	2834.57	857	330.76	SC-4
101.	374012 PADGH4 400.00 374052 KUDUS 400.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 374052 [KUDUS 400.00] CKT 2	2032.61	857	237.18	SC-4
102.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	2006.27	857	234.1	SC-4
103.	164774 KHETRI 400.00 164921 BHIWADI 400.00 1	OPEN LINE FROM BUS 164774 [KHETRI 400.00] TO BUS 164921 [BHIWADI 400.00] CKT 2	1712.13	857	199.78	SC-4
104.	154496 GOPAL PUR 400.00 154501 NARELA ISTS 400.00 1	OPEN LINE FROM BUS 154496 [GOPAL PUR 400.00] TO BUS 154501 [NARELA ISTS 400.00] CKT 2	1631.22	857	190.34	SC-4
105.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1514.53	857	176.72	SC-4
106.	164445 NEEMR-PG 400.00 164497 SIKAR NEW 400.00 1	OPEN LINE FROM BUS 164445 [NEEMR-PG 400.00] TO BUS 164497 [SIKAR NEW 400.00] CKT 2	1340.57	857	156.43	SC-4
107.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	1333.86	857	155.64	SC-4
108.	424033 PANDIABILI 400.00 424038 BEGUNIA 400.00 1	OPEN LINE FROM BUS 424033 [PANDIABILI 400.00] TO BUS 424038 [BEGUNIA 400.00] CKT 2	1483.6	1093	135.74	SC-4
109.	354002 GANCS4 400.00 354022 HAZIRA4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354022 [HAZIRA4 400.00] CKT 2	1136.61	857	132.63	SC-4
110.	164402 BARMER-4 400.00 164405 BHINMAL 400.00 1	OPEN LINE FROM BUS 164402 [BARMER-4 400.00] TO BUS 164405 [BHINMAL 400.00] CKT 2	1083.61	857	126.44	SC-4
111.	514051 MAILARM4 400.00 514100 NARSAPUR 400.00 1	OPEN LINE FROM BUS 514051 [MAILARM4 400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 2	1066.96	852	125.23	SC-4
112.	164458 BIKANER-NW 400.00 164495 BIKANER-II 400.00 1	OPEN LINE FROM BUS 164458 [BIKANER-NW 400.00] TO BUS 164495 [BIKANER-II 400.00] CKT 2	1066.67	857	124.47	SC-4
113.	424044 BARIPADA 400.00 444018 KHARAGPR-WB 400.00 1	OPEN LINE FROM BUS 444018 [KHARAGPR-WB 400.00] TO BUS 474062 [CHAIBASA 400.00] CKT 1	1024.33	850	120.51	SC-4

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
114.	354002 GANCS4 400.00 354009 GPEC4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 1	1020.74	857	119.11	SC-4
115.	354009 GPEC4 400.00 354021 KASOR4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 1	1019.62	857	118.98	SC-4
116.	164110 JAISALMER-2 400.00 164434 JODH KANKANI400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164434 [JODH KANKANI400.00] CKT 2	1013.09	857	118.21	SC-4
117.	174058 ORAI 400.00 174258 ORAI 400.00 1	OPEN LINE FROM BUS 174058 [ORAI 400.00] TO BUS 174258 [ORAI 400.00] CKT 2	982.2	857	114.61	SC-4
118.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	969.99	852	113.85	SC-4
119.	114422 KISHENPUR 400.00 114447 SAMBA 400.00 1	OPEN LINE FROM BUS 114422 [KISHENPUR 400.00] TO BUS 114447 [SAMBA 400.00] CKT 2	969.8	857	113.16	SC-4
120.	144469 BHIWN-PG 400.00 144669 BHIWANI SR 400.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 147704 [BHIWN-PG 765.00] CKT 1	942.46	857	109.97	SC-4
121.	354050 PRANTIJ SANKHARI 400.00 1	OPEN LINE FROM BUS 354050 [PRANTIJ 400.00] TO BUS 354137 [SANKHARI 400.00] CKT 2	931.21	857	108.66	SC-4
122.	374002 KHARGAR 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	927.3	857	108.2	SC-4
123.	374001 KALWA4 400.00 374012 PADGH4 400.00 1	OPEN LINE FROM BUS 374001 [KALWA4 400.00] TO BUS 374012 [PADGH4 400.00] CKT 2	918.73	857	107.2	SC-4
124.	164400 MERTA 400.00 164434 JODH KANKANI400.00 1	OPEN LINE FROM BUS 167773 [JAIPUR 765.00] TO BUS 167799 [JODH KANKANI765.00] CKT 1	917.97	857	107.11	SC-4
125.	164480 FATEHG-2 400.00 164484 BHADLA-3 400.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 164484 [BHADLA-3 400.00] CKT 2	910.94	857	106.29	SC-4
126.	354052 FEDRA 400.00 354150 DHOLERASP 400.00 1	OPEN LINE FROM BUS 354052 [FEDRA 400.00] TO BUS 354150 [DHOLERASP 400.00] CKT 2	910.16	857	106.2	SC-4
127.	364005 NAGDA-4 400.00 364039 MANDSAUR-4 400.00 1	OPEN LINE FROM BUS 364005 [NAGDA-4 400.00] TO BUS 364039 [MANDSAUR-4 400.00] CKT 2	909.17	857	106.09	SC-4
128.	164110 JAISALMER-2 400.00 164402 BARMER-4 400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164402 [BARMER-4 400.00] CKT 2	901.36	857	105.18	SC-4
129.	374004 KARAD4 400.00 374013 KOLHAPUR 400.00 1	OPEN LINE FROM BUS 374004 [KARAD4 400.00] TO BUS 374013 [KOLHAPUR 400.00] CKT 2	887.33	857	103.54	SC-4
130.	354029 KOSAMBA 400.00 354153 SAYAKHA 400.00 1	OPEN LINE FROM BUS 354029 [KOSAMBA 400.00] TO BUS 354153 [SAYAKHA 400.00] CKT 2	879.15	850	103.43	SC-4
131.	144420 BHIWANI 400.00 144469 BHIWN-PG 400.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 144480 [JINDPG 400.00] CKT 1	881.89	857	102.9	SC-4
132.	374029 CHAKAN 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374003 [LONIKAND I 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	881.61	857	102.87	SC-4

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
133.	144469 BHIWN-PG 400.00 144480 JINDPG 400.00 1	OPEN LINE FROM BUS 144469 [BHIWN-PG 400.00] TO BUS 144480 [JINDPG 400.00] CKT 2	871.3	857	101.67	SC-4
134.	354003 DEHGM4 400.00 354005 SOJA4 400.00 1	OPEN LINE FROM BUS 354003 [DEHGM4 400.00] TO BUS 354005 [SOJA4 400.00] CKT 2	858.84	857	100.21	SC-4
135.	504082 MAILAVARAM 400.00 504132 KONDPRM 400.00 1	OPEN LINE FROM BUS 504082 [MAILAVARAM 400.00] TO BUS 504132 [KONDPRM 400.00] CKT 2	856.51	857	99.94	SC-4
136.	174000 MEJA 400.00 174263 BARA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174263 [BARA 400.00] CKT 2	850.02	857	99.19	SC-4
137.	414010 KAHALGAON-B 400.00 444019 FARAKKA 400.00 1	OPEN LINE FROM BUS 414010 [KAHALGAON-B 400.00] TO BUS 444019 [FARAKKA 400.00] CKT 2	843.18	852	98.96	SC-4
138.	144404 JHAJAR_N 400.00 144408 DHANONDA 400.00 1	OPEN LINE FROM BUS 144404 [JHAJAR_N 400.00] TO BUS 144408 [DHANONDA 400.00] CKT 2	845.72	857	98.68	SC-4
139.	164495 BIKANER-II 400.00 164774 KHETRI 400.00 1	OPEN LINE FROM BUS 164495 [BIKANER-II 400.00] TO BUS 164774 [KHETRI 400.00] CKT 2	842.74	857	98.34	SC-4
140.	354002 GANCS4 400.00 354003 DEHGM4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 2	833.49	857	97.26	SC-4
141.	374002 KHARGAR 400.00 374051 PADGHEGIS 400.00 1	OPEN LINE FROM BUS 374051 [PADGHEGIS 400.00] TO BUS 374217 [NAVI-MUM 400.00] CKT 1	1642.79	1714	95.85	SC-4
142.	164419 RAPS_C4 400.00 364021 SHUJALPR-4 400.00 1	OPEN LINE FROM BUS 164419 [RAPS_C4 400.00] TO BUS 364021 [SHUJALPR-4 400.00] CKT 2	809.63	857	94.47	SC-4
143.	374051 PADGHEGIS 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	1610.28	1714	93.95	SC-4
144.	444030 ARAMBAGH 400.00 444074 PPSP NEW 400.00 1	OPEN LINE FROM BUS 444030 [ARAMBAGH 400.00] TO BUS 444074 [PPSP NEW 400.00] CKT 2	794.81	850	93.51	SC-4
145.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	794.15	852	93.21	SC-4
146.	374003 LONIKAND I 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	798.57	857	93.18	SC-4
147.	3 ASOJ-BYP-KOS400.00 354029 KOSAMBA 400.00 1	OPEN LINE FROM BUS 358044 [AHMDABAD PG 765.00] TO BUS 358208 [NAVSARI-NEW 765.00] CKT 2	794.73	857	92.73	SC-4
148.	354052 FEDRA 400.00 354153 SAYAKHA 400.00 1	OPEN LINE FROM BUS 354052 [FEDRA 400.00] TO BUS 354153 [SAYAKHA 400.00] CKT 2	784.95	850	92.35	SC-4
149.	214010 MISA-PG 400.00 214030 BALIPARA-PG 400.00 1	OPEN LINE FROM BUS 214010 [MISA-PG 400.00] TO BUS 214030 [BALIPARA-PG 400.00] CKT 2	781.1	850	91.89	SC-4
150.	164481 FATEHG-3 400.00 164482 FATEHG-4 400.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 164482 [FATEHG-4 400.00] CKT 2	1999.57	2186	91.47	SC-4
151.	164418 KANKROLI 400.00 164433 JODH SURPURA400.00 1	OPEN LINE FROM BUS 167773 [JAIPUR 765.00] TO BUS 167799 [JODH KANKANI765.00] CKT 1	783.55	857	91.43	SC-4

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
152.	354029 KOSAMBA 400.00 354047 VAV4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354009 [GPEC4 400.00] CKT 1	777.97	857	90.78	SC-4
153.	514006 KACHAPU-A LI400.00 514007 KACHAPU-B LI400.00 1	OPEN LINE FROM BUS 514007 [KACHAPU-B LI400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 1	773.01	857	90.2	SC-4
154.	504007 CUDP 400.00 504024 CHITOR 400.00 1	OPEN LINE FROM BUS 544084 [TIRUVLM SE-B400.00] TO BUS 544087 [TIRUVLM SE-A400.00] CKT 1	768.01	852	90.14	SC-4
155.	214030 BALIPARA-PG 400.00 214196 BON-BAL-FSC2400.00 1	OPEN LINE FROM BUS 214180 [BORNAGAR 400.00] TO BUS 214195 [BON-BAL-FSC1400.00] CKT 3	1847.44	857	215.57	SC-5
156.	214030 BALIPARA-PG 400.00 214195 BON-BAL-FSC1400.00 1	OPEN LINE FROM BUS 214180 [BORNAGAR 400.00] TO BUS 214196 [BON-BAL-FSC2400.00] CKT 4	1847.44	857	215.57	SC-5
157.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1516.03	857	176.9	SC-5
158.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	1446.36	857	168.77	SC-5
159.	424033 PANDIABILI 400.00 424038 BEGUNIA 400.00 1	OPEN LINE FROM BUS 424033 [PANDIABILI 400.00] TO BUS 424038 [BEGUNIA 400.00] CKT 2	1666.28	1093	152.45	SC-5
160.	174000 MEJA 400.00 174474 ALLAHABA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 2	1177.82	857	137.44	SC-5
161.	174058 ORAI 400.00 174258 ORAI 400.00 1	OPEN LINE FROM BUS 174058 [ORAI 400.00] TO BUS 174258 [ORAI 400.00] CKT 2	1122.54	857	130.98	SC-5
162.	314023 KWPC 400.00 314029 RAIGARH POOL400.00 1	OPEN LINE FROM BUS 314023 [KWPC 400.00] TO BUS 314029 [RAIGARH POOL400.00] CKT 2	1084.19	857	126.51	SC-5
163.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	1083.41	857	126.42	SC-5
164.	374012 PADGH4 400.00 374052 KUDUS 400.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 374052 [KUDUS 400.00] CKT 2	1082.83	857	126.35	SC-5
165.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	1065	857	124.27	SC-5
166.	314019 BALCO-CPP 400.00 314032 DHARAMJAIGAR400.00 1	OPEN LINE FROM BUS 314019 [BALCO-CPP 400.00] TO BUS 314032 [DHARAMJAIGAR400.00] CKT 2	1051.04	857	122.64	SC-5
167.	174468 ANPARA4 400.00 174923 SINGRL4 400.00 1	OPEN LINE FROM BUS 174437 [LUCKN UP 400.00] TO BUS 174923 [SINGRL4 400.00] CKT 1	1012.08	857	118.1	SC-5
168.	374004 KARAD4 400.00 374065 KESURDI400 400.00 1	OPEN LINE FROM BUS 374015 [JEJ4 400.00] TO BUS 374026 [KOY4-4 400.00] CKT 1	1009.14	857	117.75	SC-5
169.	354002 GANCS4 400.00 354022 HAZIRA4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354022 [HAZIRA4 400.00] CKT 2	984.1	857	114.83	SC-5
170.	374024 RGPPL 400.00 374028 NAGOTHANE 400.00 1	OPEN LINE FROM BUS 374024 [RGPPL 400.00] TO BUS 374028 [NAGOTHANE 400.00] CKT 2	963.52	857	112.43	SC-5

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
171.	134406 RAJPURA_TH 400.00 134407 RAJPURA 400.00 1	OPEN LINE FROM BUS 134406 [RAJPURA_TH 400.00] TO BUS 134407 [RAJPURA 400.00] CKT 2	957.92	857	111.78	SC-5
172.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	957.02	857	111.67	SC-5
173.	134325 MALKANA 400.00 134401 TALWANDISABO400.00 1	OPEN LINE FROM BUS 134401 [TALWANDISABO400.00] TO BUS 134404 [MUKATSAR 400.00] CKT 1	951.67	857	111.05	SC-5
174.	424044 BARIPADA 400.00 444018 KHARAGPR-WB 400.00 1	OPEN LINE FROM BUS 444018 [KHARAGPR-WB 400.00] TO BUS 474062 [CHAIBASA 400.00] CKT 1	925.34	850	108.86	SC-5
175.	194001 KANPRAYAG 400.00 194054 PIPALKOTI SW400.00 1	OPEN LINE FROM BUS 194001 [KANPRAYAG 400.00] TO BUS 194054 [PIPALKOTI SW400.00] CKT 2	919.43	857	107.28	SC-5
176.	194001 KANPRAYAG 400.00 194052 SRINAGAR_PT 400.00 1	OPEN LINE FROM BUS 194001 [KANPRAYAG 400.00] TO BUS 194052 [SRINAGAR_PT 400.00] CKT 2	917.25	857	107.03	SC-5
177.	524016 GULBRG 400.00 524083 YERAMRS TPP 400.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 524083 [YERAMRS TPP 400.00] CKT 3	981	948	103.48	SC-5
178.	174264 KARCHNA 400.00 174265 REWA 400.00 1	OPEN LINE FROM BUS 174264 [KARCHNA 400.00] TO BUS 174265 [REWA 400.00] CKT 2	868.84	857	101.38	SC-5
179.	374001 KALWA4 400.00 374012 PADGH4 400.00 1	OPEN LINE FROM BUS 374001 [KALWA4 400.00] TO BUS 374012 [PADGH4 400.00] CKT 2	854.21	857	99.67	SC-5
180.	414010 KAHALGAON-B 400.00 444019 FARAKKA 400.00 1	OPEN LINE FROM BUS 414010 [KAHALGAON-B 400.00] TO BUS 444019 [FARAKKA 400.00] CKT 2	835.13	852	98.02	SC-5
181.	524003 RAIC 400.00 524082 BELLARY TPP 400.00 1	OPEN LINE FROM BUS 524002 [MNRB 400.00] TO BUS 524003 [RAIC 400.00] CKT 1	825.96	850	97.17	SC-5
182.	374015 JEJ4 400.00 374026 KOY4-4 400.00 1	OPEN LINE FROM BUS 374004 [KARAD4 400.00] TO BUS 374065 [KESURDI400 400.00] CKT 1	812.63	857	94.82	SC-5
183.	374002 KHARGAR 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	811.92	857	94.74	SC-5
184.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	797.53	852	93.61	SC-5
185.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	793.81	852	93.17	SC-5
186.	114422 KISHENPUR 400.00 114447 SAMBA 400.00 1	OPEN LINE FROM BUS 114422 [KISHENPUR 400.00] TO BUS 114447 [SAMBA 400.00] CKT 2	791.01	857	92.3	SC-5
187.	374003 LONIKAND I 400.00 374026 KOY4-4 400.00 1	OPEN LINE FROM BUS 374015 [JEJ4 400.00] TO BUS 374026 [KOY4-4 400.00] CKT 1	791.01	857	92.3	SC-5
188.	154426 BAWANA-G 400.00 154427 BAWANA 400.00 1	OPEN LINE FROM BUS 154426 [BAWANA-G 400.00] TO BUS 154427 [BAWANA 400.00] CKT 2	786.65	857	91.79	SC-5
189.	444030 ARAMBAGH 400.00 444074 PPSP_NEW 400.00 1	OPEN LINE FROM BUS 444030 [ARAMBAGH 400.00] TO BUS 444074 [PPSP_NEW 400.00] CKT 2	770.34	850	90.63	SC-5

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
190.	164110 JAISALMER-2 400.00 164401 AKAL-4 400.00 1	OPEN LINE FROM BUS 164403 [RAMGARH 400.00] TO BUS 164404 [BHADLA 400.00] CKT 1	775.02	857	90.43	SC-5
191.	424018 ANGUL-A 400.00 424030 JINDAL-JITPL400.00 1	OPEN LINE FROM BUS 424018 [ANGUL-A 400.00] TO BUS 424030 [JINDAL-JITPL400.00] CKT 2	986.21	1093	90.23	SC-5
192.	174468 ANPARA4 400.00 174923 SINGRL4 400.00 1	OPEN LINE FROM BUS 174465 [FATEH-PG 400.00] TO BUS 174923 [SINGRL4 400.00] CKT 1	1299.11	857	151.59	SC-6
193.	424033 PANDIABILI 400.00 424038 BEGUNIA 400.00 1	OPEN LINE FROM BUS 424033 [PANDIABILI 400.00] TO BUS 424038 [BEGUNIA 400.00] CKT 2	1607.79	1093	147.1	SC-6
194.	314023 KWPC 400.00 314029 RAIGARH POOL400.00 1	OPEN LINE FROM BUS 314023 [KWPC 400.00] TO BUS 314029 [RAIGARH POOL400.00] CKT 2	1084.09	857	126.5	SC-6
195.	424044 BARIPADA 400.00 444018 KHARAGPR-WB 400.00 1	OPEN LINE FROM BUS 444018 [KHARAGPR-WB 400.00] TO BUS 474062 [CHAIBASA 400.00] CKT 1	1062.07	850	124.95	SC-6
196.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	1035.05	857	120.78	SC-6
197.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	1024.24	857	119.51	SC-6
198.	174058 ORAI 400.00 174258 ORAI 400.00 1	OPEN LINE FROM BUS 174058 [ORAI 400.00] TO BUS 174258 [ORAI 400.00] CKT 2	940.99	857	109.8	SC-6
199.	134406 RAJPURA_TH 400.00 134407 RAJPURA 400.00 1	OPEN LINE FROM BUS 134406 [RAJPURA_TH 400.00] TO BUS 134407 [RAJPURA 400.00] CKT 2	922.57	857	107.65	SC-6
200.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	912.21	852	107.07	SC-6
201.	174000 MEJA 400.00 174474 ALLAHABA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 2	916.19	857	106.91	SC-6
202.	514051 MAILARM4 400.00 514100 NARSAPUR 400.00 1	OPEN LINE FROM BUS 514051 [MAILARM4 400.00] TO BUS 514100 [NARSAPUR 400.00] CKT 2	897.9	852	105.39	SC-6
203.	374004 KARAD4 400.00 374065 KESURDI400 400.00 1	OPEN LINE FROM BUS 374015 [JEJ4 400.00] TO BUS 374026 [KOY4-4 400.00] CKT 1	859.57	857	100.3	SC-6
204.	314008 SIPAT4 400.00 474049 RNC-SIPT FSC400.00 1	OPEN LINE FROM BUS 474046 [RANCHI 400.00] TO BUS 474048 [RNC-SIPT FSC400.00] CKT 2	825.55	857	96.33	SC-6
205.	354002 GANCS4 400.00 354022 HAZIRA4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354022 [HAZIRA4 400.00] CKT 2	803.6	857	93.77	SC-6
206.	474046 RANCHI 400.00 474049 RNC-SIPT FSC400.00 1	OPEN LINE FROM BUS 474046 [RANCHI 400.00] TO BUS 474048 [RNC-SIPT FSC400.00] CKT 2	788.41	850	92.75	SC-6
207.	144401 KHEDAR 400.00 144403 KIRORI 400.00 1	OPEN LINE FROM BUS 144401 [KHEDAR 400.00] TO BUS 144403 [KIRORI 400.00] CKT 2	792.95	857	92.53	SC-6
208.	174264 KARCHNA 400.00 174265 REWA 400.00 1	OPEN LINE FROM BUS 174264 [KARCHNA 400.00] TO BUS 174265 [REWA 400.00] CKT 2	784.42	857	91.53	SC-6

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
209.	374002 KHARGAR 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	781.74	857	91.22	SC-6
210.	154426 BAWANA-G 400.00 154427 BAWANA 400.00 1	OPEN LINE FROM BUS 154426 [BAWANA-G 400.00] TO BUS 154427 [BAWANA 400.00] CKT 2	778.16	857	90.8	SC-6
211.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	1837.31	857	214.39	SC-7
212.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	1611.93	857	188.09	SC-7
213.	164774 KHETRI 400.00 164921 BHIWADI 400.00 1	OPEN LINE FROM BUS 164774 [KHETRI 400.00] TO BUS 164921 [BHIWADI 400.00] CKT 2	1515.19	857	176.8	SC-7
214.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1514.53	857	176.72	SC-7
215.	164402 BARMER-4 400.00 164405 BHINMAL 400.00 1	OPEN LINE FROM BUS 164402 [BARMER-4 400.00] TO BUS 164405 [BHINMAL 400.00] CKT 2	1496.35	857	174.6	SC-7
216.	374012 PADGH4 400.00 374052 KUDUS 400.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 374052 [KUDUS 400.00] CKT 2	1464.61	857	170.9	SC-7
217.	374029 CHAKAN 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374003 [LONIKAND I 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	1369.56	857	159.81	SC-7
218.	374003 LONIKAND I 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	1308.22	857	152.65	SC-7
219.	164419 RAPS_C4 400.00 364021 SHUJALPR-4 400.00 1	OPEN LINE FROM BUS 164419 [RAPS_C4 400.00] TO BUS 364021 [SHUJALPR-4 400.00] CKT 2	1275.61	857	148.85	SC-7
220.	364005 NAGDA-4 400.00 364039 MANDSAUR-4 400.00 1	OPEN LINE FROM BUS 364005 [NAGDA-4 400.00] TO BUS 364039 [MANDSAUR-4 400.00] CKT 2	1219.8	857	142.33	SC-7
221.	154496 GOPAL PUR 400.00 154501 NARELA ISTS 400.00 1	OPEN LINE FROM BUS 154496 [GOPAL PUR 400.00] TO BUS 154501 [NARELA ISTS 400.00] CKT 2	1194.1	857	139.33	SC-7
222.	164445 NEEMR-PG 400.00 164497 SIKAR NEW 400.00 1	OPEN LINE FROM BUS 164445 [NEEMR-PG 400.00] TO BUS 164497 [SIKAR NEW 400.00] CKT 2	1172.18	857	136.78	SC-7
223.	164110 JAISALMER-2 400.00 164402 BARMER-4 400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164402 [BARMER-4 400.00] CKT 2	1138.88	857	132.89	SC-7
224.	364009 JABALPUR-4 400.00 364026 JABALPR-POOL 400.00 1	OPEN LINE FROM BUS 364009 [JABALPUR-4 400.00] TO BUS 364026 [JABALPR-POOL 400.00] CKT 2	1073.2	857	125.23	SC-7
225.	214010 MISA-PG 400.00 214030 BALIPARA-PG 400.00 1	OPEN LINE FROM BUS 214010 [MISA-PG 400.00] TO BUS 214030 [BALIPARA-PG 400.00] CKT 2	1052.44	850	123.82	SC-7
226.	164418 KANKROLI 400.00 354019 ZERDA 400.00 1	OPEN LINE FROM BUS 164405 [BHINMAL 400.00] TO BUS 354019 [ZERDA 400.00] CKT 2	1035.57	857	120.84	SC-7
227.	164480 FATEHG-2 400.00 164484 BHADLA-3 400.00 1	OPEN LINE FROM BUS 164480 [FATEHG-2 400.00] TO BUS 164484 [BHADLA-3 400.00] CKT 2	1021.39	857	119.18	SC-7

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
228.	174000 MEJA 400.00 174474 ALLAHABA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 2	1016.6	857	118.62	SC-7
229.	504007 CUDP 400.00 504024 CHITOR 400.00 1	OPEN LINE FROM BUS 544084 [TIRUVLM SE-B400.00] TO BUS 544087 [TIRUVLM SE-A400.00] CKT 1	1008.42	852	118.36	SC-7
230.	164418 KANKROLI 400.00 164433 JODH SURPURA400.00 1	OPEN LINE FROM BUS 164405 [BHINMAL 400.00] TO BUS 164418 [KANKROLI 400.00] CKT 1	1009.98	857	117.85	SC-7
231.	374002 KHARGAR 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	1007	857	117.5	SC-7
232.	164110 JAISALMER-2 400.00 164434 JODH KANKANI400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164434 [JODH KANKANI400.00] CKT 2	1001.05	857	116.81	SC-7
233.	524001 SMNH 400.00 524077 BIDADI 400.00 1	OPEN LINE FROM BUS 524001 [SMNH 400.00] TO BUS 524077 [BIDADI 400.00] CKT 2	995.08	852	116.79	SC-7
234.	164110 JAISALMER-2 400.00 164401 AKAL-4 400.00 1	OPEN LINE FROM BUS 164110 [JAISALMER-2 400.00] TO BUS 164402 [BARMER-4 400.00] CKT 1	969.47	857	113.12	SC-7
235.	354052 FEDRA 400.00 354150 DHOLERASP 400.00 1	OPEN LINE FROM BUS 354052 [FEDRA 400.00] TO BUS 354150 [DHOLERASP 400.00] CKT 2	959.08	857	111.91	SC-7
236.	374002 KHARGAR 400.00 374051 PADGHEGIS 400.00 1	OPEN LINE FROM BUS 374051 [PADGHEGIS 400.00] TO BUS 374217 [NAVI-MUM 400.00] CKT 1	1865.88	1714	108.86	SC-7
237.	354002 GANCS4 400.00 354003 DEHGM4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 2	927.62	857	108.24	SC-7
238.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	924.73	857	107.9	SC-7
239.	374051 PADGHEGIS 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	1832.54	1714	106.92	SC-7
240.	354002 GANCS4 400.00 354009 GPEC4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 1	905.78	857	105.69	SC-7
241.	354009 GPEC4 400.00 354021 KASOR4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354003 [DEHGM4 400.00] CKT 1	905.75	857	105.69	SC-7
242.	364039 MANDSAUR-4 400.00 364097 NEEMUCH PS 400.00 1	OPEN LINE FROM BUS 364039 [MANDSAUR-4 400.00] TO BUS 364097 [NEEMUCH PS 400.00] CKT 2	1811.05	1714	105.66	SC-7
243.	354003 DEHGM4 400.00 354005 SOJA4 400.00 1	OPEN LINE FROM BUS 354003 [DEHGM4 400.00] TO BUS 354005 [SOJA4 400.00] CKT 2	877.35	857	102.37	SC-7
244.	504082 MAILAVARAM 400.00 504132 KONDRM 400.00 1	OPEN LINE FROM BUS 504082 [MAILAVARAM 400.00] TO BUS 504132 [KONDRM 400.00] CKT 2	874.68	857	102.06	SC-7
245.	164458 BIKANER-NW 400.00 164495 BIKANER-II 400.00 1	OPEN LINE FROM BUS 164458 [BIKANER-NW 400.00] TO BUS 164495 [BIKANER-II 400.00] CKT 2	861.12	857	100.48	SC-7
246.	354050 PRANTIJ 400.00 354137 SANKHARI 400.00 1	OPEN LINE FROM BUS 354050 [PRANTIJ 400.00] TO BUS 354137 [SANKHARI 400.00] CKT 2	859.67	857	100.31	SC-7

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
247.	164481 FATEHG-3 400.00 164482 FATEHG-4 400.00 1	OPEN LINE FROM BUS 164481 [FATEHG-3 400.00] TO BUS 164482 [FATEHG-4 400.00] CKT 2	2145.86	2186	98.16	SC-7
248.	414010 KAHALGAON-B 400.00 444019 FARAKKA 400.00 1	OPEN LINE FROM BUS 414010 [KAHALGAON-B 400.00] TO BUS 444019 [FARAKKA 400.00] CKT 2	835.93	852	98.11	SC-7
249.	374042 PUNE-PG-AIS 400.00 374045 PUNE-PG-GIS 400.00 1	OPEN LINE FROM BUS 374042 [PUNE-PG-AIS 400.00] TO BUS 374045 [PUNE-PG-GIS 400.00] CKT 3	840.56	857	98.08	SC-7
250.	3 ASOJ-BYP-KOS400.00 354029 KOSAMBA 400.00 1	OPEN LINE FROM BUS 358044 [AHMDABAD PG 765.00] TO BUS 358208 [NAVSARI-NEW 765.00] CKT 2	837.43	857	97.72	SC-7
251.	164405 BHINMAL 400.00 164418 KANKROLI 400.00 1	OPEN LINE FROM BUS 164405 [BHINMAL 400.00] TO BUS 354019 [ZERDA 400.00] CKT 2	828.7	857	96.7	SC-7
252.	164495 BIKANER-II 400.00 164774 KHETRI 400.00 1	OPEN LINE FROM BUS 164495 [BIKANER-II 400.00] TO BUS 164774 [KHETRI 400.00] CKT 2	807.02	857	94.17	SC-7
253.	374001 KALWA4 400.00 374012 PADGH4 400.00 1	OPEN LINE FROM BUS 374001 [KALWA4 400.00] TO BUS 374012 [PADGH4 400.00] CKT 2	801.23	857	93.49	SC-7
254.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	794.15	852	93.21	SC-7
255.	444010 SAGARDIGHI 4400.00 444019 FARAKKA 400.00 1	OPEN LINE FROM BUS 444010 [SAGARDIGHI 4400.00] TO BUS 444019 [FARAKKA 400.00] CKT 2	1018.16	1093	93.15	SC-7
256.	354029 KOSAMBA 400.00 354047 VAV4 400.00 1	OPEN LINE FROM BUS 354002 [GANCS4 400.00] TO BUS 354047 [VAV4 400.00] CKT 2	796.19	857	92.9	SC-7
257.	174424 DADR-NCR 400.00 174454 DADR-HVD 400.00 1	OPEN LINE FROM BUS 174424 [DADR-NCR 400.00] TO BUS 174454 [DADR-HVD 400.00] CKT 2	1701.92	857	198.59	SC-8
258.	174417 RIHAND-G 400.00 174433 RIHAN-HV 400.00 1	OPEN LINE FROM BUS 174417 [RIHAND-G 400.00] TO BUS 174433 [RIHAN-HV 400.00] CKT 2	1516.99	857	177.01	SC-8
259.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	1279.36	857	149.28	SC-8
260.	174000 MEJA 400.00 174474 ALLAHABA 400.00 1	OPEN LINE FROM BUS 174000 [MEJA 400.00] TO BUS 174474 [ALLAHABA 400.00] CKT 2	1180.86	857	137.79	SC-8
261.	314023 KWPC 400.00 314029 RAIGARH POOL400.00 1	OPEN LINE FROM BUS 314023 [KWPC 400.00] TO BUS 314029 [RAIGARH POOL400.00] CKT 2	1093.44	857	127.59	SC-8
262.	374029 CHAKAN 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374003 [LONIKAND I 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	1074.5	857	125.38	SC-8
263.	314019 BALCO-CPP 400.00 314032 DHARAMJAIGAR400.00 1	OPEN LINE FROM BUS 314019 [BALCO-CPP 400.00] TO BUS 314032 [DHARAMJAIGAR400.00] CKT 2	1063.28	857	124.07	SC-8
264.	374003 LONIKAND I 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	1008.34	857	117.66	SC-8
265.	174468 ANPARA4 400.00 174923 SINGRL4 400.00 1	OPEN LINE FROM BUS 174465 [FATEH-PG 400.00] TO BUS 174923 [SINGRL4 400.00] CKT 1	978.81	857	114.21	SC-8

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
266.	374024 RGPPL 400.00 374025 NKOY4 400.00 1	OPEN LINE FROM BUS 374024 [RGPPL 400.00] TO BUS 374025 [NKOY4 400.00] CKT 2	952.67	857	111.16	SC-8
267.	524016 GULBRG 400.00 524083 YERAMRS TPP 400.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 524083 [YERAMRS TPP 400.00] CKT 3	1039.56	948	109.66	SC-8
268.	364009 JABALPUR-4 400.00 364026 JABALPR-POOL400.00 1	OPEN LINE FROM BUS 364009 [JABALPUR-4 400.00] TO BUS 364026 [JABALPR-POOL400.00] CKT 2	933.17	857	108.89	SC-8
269.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	932.58	857	108.82	SC-8
270.	134406 RAJPURA TH 400.00 134407 RAJPURA 400.00 1	OPEN LINE FROM BUS 134406 [RAJPURA TH 400.00] TO BUS 134407 [RAJPURA 400.00] CKT 2	922.07	857	107.59	SC-8
271.	374012 PADGH4 400.00 374052 KUDUS 400.00 1	OPEN LINE FROM BUS 374012 [PADGH4 400.00] TO BUS 374052 [KUDUS 400.00] CKT 2	878.98	857	102.56	SC-8
272.	164420 KOTA 400.00 164463 ANTA-4 400.00 1	OPEN LINE FROM BUS 167761 [ANTA-7 765.00] TO BUS 167773 [JAIPUR 765.00] CKT 1	868.67	857	101.36	SC-8
273.	144404 JHAJAR_N 400.00 144408 DHANONDA 400.00 1	OPEN LINE FROM BUS 144404 [JHAJAR_N 400.00] TO BUS 144408 [DHANONDA 400.00] CKT 2	841.05	857	98.14	SC-8
274.	174264 KARCHNA 400.00 174265 REWA 400.00 1	OPEN LINE FROM BUS 174264 [KARCHNA 400.00] TO BUS 174265 [REWA 400.00] CKT 2	834.82	857	97.41	SC-8
275.	364030 MALWA 400.00 364099 MALWA II 400.00 1	OPEN LINE FROM BUS 364031 [PITHAMPUR-4 400.00] TO BUS 364099 [MALWA II 400.00] CKT 1	829.16	857	96.75	SC-8
276.	374002 KHARGAR 400.00 374217 NAVI-MUM 400.00 1	OPEN LINE FROM BUS 374002 [KHARGAR 400.00] TO BUS 374051 [PADGHEGIS 400.00] CKT 1	809.57	857	94.47	SC-8
277.	154426 BAWANA-G 400.00 154427 BAWANA 400.00 1	OPEN LINE FROM BUS 154426 [BAWANA-G 400.00] TO BUS 154427 [BAWANA 400.00] CKT 2	807.17	857	94.19	SC-8
278.	354013 PIRANA T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	799.62	857	93.3	SC-8
279.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	793.81	852	93.17	SC-8
280.	144401 KHEDAR 400.00 144403 KIRORI 400.00 1	OPEN LINE FROM BUS 144401 [KHEDAR 400.00] TO BUS 144403 [KIRORI 400.00] CKT 2	788.89	857	92.05	SC-8
281.	374001 KALWA4 400.00 374012 PADGH4 400.00 1	OPEN LINE FROM BUS 374001 [KALWA4 400.00] TO BUS 374012 [PADGH4 400.00] CKT 2	787.09	857	91.84	SC-8
282.	174468 ANPARA4 400.00 174923 SINGRL4 400.00 1	OPEN LINE FROM BUS 174465 [FATEH-PG 400.00] TO BUS 174923 [SINGRL4 400.00] CKT 1	1325.81	857	154.7	SC-9
283.	314023 KWPCl 400.00 314029 RAIGARH POOL400.00 1	OPEN LINE FROM BUS 314023 [KWPCl 400.00] TO BUS 314029 [RAIGARH POOL400.00] CKT 2	1086.57	857	126.79	SC-9
284.	374029 CHAKAN 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374003 [LONIKAND I 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	1020.01	857	119.02	SC-9

S.No	Monitored Element	Contingency	Flow under Contingency	Rate	% loading	Scenario
285.	514001 RAMGUNDM STP400.00 514009 CHANDRAPR-SR400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514009 [CHANDRAPR-SR400.00] CKT 2	998.26	852	117.17	SC-9
286.	374003 LONIKAND I 400.00 374042 PUNE-PG-AIS 400.00 1	OPEN LINE FROM BUS 374029 [CHAKAN 400.00] TO BUS 374042 [PUNE-PG-AIS 400.00] CKT 1	975.68	857	113.85	SC-9
287.	354013 PIRANA_T 400.00 354044 AHMDABAD PG 400.00 1	OPEN LINE FROM BUS 354013 [PIRANA_T 400.00] TO BUS 354044 [AHMDABAD PG 400.00] CKT 2	955.39	857	111.48	SC-9
288.	524016 GULBRG 400.00 524083 YERAMRS TPP 400.00 1	OPEN LINE FROM BUS 524016 [GULBRG 400.00] TO BUS 524083 [YERAMRS TPP 400.00] CKT 3	1002.05	948	105.7	SC-9
289.	544084 TIRUVLM SE-B400.00 544087 TIRUVLM SE-A400.00 1	OPEN LINE FROM BUS 504007 [CUDP 400.00] TO BUS 504024 [CHITOR 400.00] CKT 1	864.41	857	100.86	SC-9
290.	174438 LUCK4-PG 400.00 174451 LUCK74-P 400.00 1	OPEN LINE FROM BUS 174438 [LUCK4-PG 400.00] TO BUS 174451 [LUCK74-P 400.00] CKT 2	817.96	857	95.44	SC-9
291.	174468 ANPARA4 400.00 174472 OBRA4 400.00 1	OPEN LINE FROM BUS 177406 [ANPARA-D 765.00] TO BUS 177712 [OBRAC 765.00] CKT 1	812.96	857	94.86	SC-9
292.	514002 HYDERABAD 400.00 514022 GAJWEL4 400.00 1	OPEN LINE FROM BUS 514001 [RAMGUNDM STP400.00] TO BUS 514022 [GAJWEL4 400.00] CKT 1	794.74	852	93.28	SC-9
293.	314001 KNTPC 400.00 314003 KORBA-WEST 400.00 1	OPEN LINE FROM BUS 314001 [KNTPC 400.00] TO BUS 314005 [BHATP4 400.00] CKT 1	772.16	857	90.1	SC-9

Page intentionally left blank.

Annex-7.5

Over Voltage Nodes

765kV Bus Voltage ≥ 1.05 PU

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
NORTH	MOGA-PG	0.95	1.05	1.01	0.94	1.03	1.00	0.96	1.06	1.02	1.06
NORTH	AJMER-NW	0.97	1.08	1.05	0.97	1.03	1.03	0.97	1.07	1.06	1.08
NORTH	RAMGARH-I	0.95	1.00	1.03	0.95	0.96	1.06	0.96	1.00	1.05	1.06
NORTH	CHIT-NEW	0.98	1.04	1.03	0.97	1.00	1.01	0.94	1.05	1.04	1.05
NORTH	BIKANER-NW	0.95	1.07	1.03	0.95	1.03	1.02	0.96	1.06	1.04	1.07
NORTH	BHADLA PG	0.97	1.08	1.03	0.96	1.03	1.02	0.98	1.07	1.05	1.08
NORTH	FATEH-2	0.97	1.06	1.02	0.97	1.01	1.01	0.98	1.06	1.04	1.06
NORTH	FATEHG-3	0.95	1.05	1.03	0.95	1.01	1.02	0.93	1.05	1.04	1.05
NORTH	BHADLA-3	0.93	1.03	1.03	0.93	0.99	1.06	0.94	1.03	1.05	1.06
NORTH	SIKAR NEW	0.91	1.05	1.03	0.90	1.02	1.02	0.93	1.05	1.04	1.05
NORTH	BHADLA-2	0.95	1.06	1.02	0.95	1.02	1.01	0.96	1.06	1.04	1.06
NORTH	BEAWAR	0.96	1.07	1.05	0.96	1.02	1.03	0.94	1.07	1.05	1.07
NORTH	JAIPUR	0.98	1.08	1.05	0.97	1.03	1.03	0.98	1.07	1.05	1.08
NORTH	JODH KANKANI	0.97	1.11	1.06	0.97	1.03	1.03	0.98	1.09	1.07	1.11
NORTH	DAUSA	0.97	1.06	1.04	0.97	1.03	1.02	0.97	1.06	1.04	1.06
NORTH	BARA	1.00	1.05	1.00	1.00	1.05	0.99	0.99	1.05	0.99	1.05
NORTH	ANPARAC	1.00	1.07	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	ANPARA-D	1.00	1.07	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	LALITPUR	1.03	1.03	1.03	1.03	1.05	1.02	0.99	0.99	0.98	1.05
NORTH	OBRAC	1.00	1.06	1.00	1.00	1.06	1.00	1.00	1.07	1.00	1.07
NORTH	JAKHORA765	1.03	1.03	1.03	1.03	1.05	1.02	0.99	0.99	0.99	1.05
NORTH	GURUSARAI765	1.03	1.02	1.03	1.02	1.06	1.01	0.99	1.01	1.00	1.06

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
NRTHEAST	BORNAGAR	1.02	1.05	1.04	1.03	0.97	1.04	1.03	1.01	1.05	1.05
WEST	SASAN	1.00	1.06	1.00	1.00	1.06	1.00	1.00	1.06	1.00	1.06
WEST	VIN-POOL	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.00	1.05
WEST	JABALPR-POOL	1.02	1.06	1.04	1.01	1.05	1.02	1.01	1.05	1.03	1.06
WEST	GADARWARA	1.02	1.05	1.03	1.00	1.05	1.02	1.00	1.05	1.01	1.05
WEST	BHOPAL_STER	1.00	1.06	1.05	1.00	1.05	1.03	1.01	1.03	1.03	1.06
EAST	KATIHAR8	1.00	1.06	1.06	1.03	0.98	1.05	1.01	1.01	1.07	1.07
EAST	MEDINIPUR7	0.94	0.94	0.96	0.91	0.96	0.95	1.02	1.03	1.09	1.09
EAST	JEERAT7	0.93	0.92	0.94	0.89	0.95	0.94	1.02	1.02	1.09	1.09
EAST	RANCHI-NEW	0.98	0.99	0.98	0.96	0.99	0.97	1.00	1.03	1.06	1.06
SOUTH	HYDR_800	1.03	1.04	1.03	1.03	1.04	1.03	1.03	1.05	1.04	1.05
SOUTH	BIDAR PS SZ	1.03	1.04	1.03	1.02	1.04	1.04	1.02	1.05	1.04	1.05
SOUTH	UPPUR	1.02	1.06	1.00	1.02	1.06	1.00	1.02	1.06	1.00	1.06

* Note: Highlighted cell indicates 765kV Bus Voltage ≥ 1.05 P.U.

400kV Bus Voltage ≥ 1.05 PU

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
WEST	ASOJBY_SS-CH	1.00	1.02	1.05	0.99	1.02	1.03	1.00	1.03	1.02	1.05
NORTH	JAISALMER-2	1.00	1.12	1.04	1.00	1.01	1.02	1.00	1.09	1.08	1.12
NORTH	MERTA	0.97	1.08	1.04	0.97	1.01	1.01	0.98	1.06	1.04	1.08
NORTH	AKAL-4	1.00	1.15	1.04	0.99	1.01	1.02	1.00	1.11	1.08	1.15
NORTH	BARMER-4	0.99	1.13	1.05	0.98	1.01	1.01	0.98	1.09	1.08	1.13
NORTH	RAMGARH	0.99	1.14	1.02	0.99	1.00	1.01	1.00	1.10	1.07	1.14
NORTH	BHADLA	0.98	1.09	1.03	0.98	1.02	1.01	0.99	1.07	1.05	1.09
NORTH	BHINMAL	0.97	1.10	1.05	0.96	1.00	1.00	0.94	1.07	1.06	1.10
NORTH	HERAPU-4	0.99	1.06	1.04	0.97	1.01	1.00	1.00	1.05	1.03	1.06

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
NORTH	RATANGAR	0.99	1.07	1.05	0.97	1.01	1.01	1.00	1.04	1.02	1.07
NORTH	BHILWA-4	1.00	1.08	1.06	1.00	1.02	1.01	0.99	1.06	1.03	1.08
NORTH	RAJWEST	0.99	1.12	1.05	0.98	1.00	1.01	1.00	1.09	1.07	1.12
NORTH	DEEDWANA	0.99	1.09	1.06	0.98	1.02	1.01	0.99	1.06	1.04	1.09
NORTH	AJMER	0.99	1.09	1.06	0.98	1.03	1.02	0.99	1.07	1.05	1.09
NORTH	AJMER-NW	0.98	1.09	1.05	0.98	1.03	1.02	0.98	1.07	1.05	1.09
NORTH	KANKROLI	1.00	1.08	1.05	1.00	1.00	1.00	1.00	1.05	1.03	1.08
NORTH	RAMG-I	0.97	0.99	1.03	0.97	0.96	1.06	0.98	0.99	1.05	1.06
NORTH	CHITTOR4	1.00	1.08	1.06	0.99	1.01	1.01	0.98	1.05	1.03	1.08
NORTH	CHIT-NEW	0.99	1.07	1.05	0.99	1.01	1.01	0.97	1.06	1.03	1.07
NORTH	PACHPADRA	0.99	1.13	1.06	0.98	1.01	1.02	0.99	1.10	1.08	1.13
NORTH	BASSI	0.99	1.06	1.03	0.98	1.01	1.00	1.00	1.04	1.02	1.06
NORTH	JODH SURPURA	0.98	1.12	1.06	0.98	1.02	1.02	0.99	1.09	1.08	1.12
NORTH	JODH KANKANI	0.97	1.12	1.06	0.97	1.03	1.03	0.98	1.10	1.08	1.12
NORTH	SIKAR	0.98	1.06	1.04	0.97	1.02	1.01	0.99	1.04	1.03	1.06
NORTH	JAIPUR_RS	0.99	1.07	1.04	0.98	1.02	1.01	0.99	1.06	1.04	1.07
NORTH	BIKANE-4	0.98	1.09	1.05	0.97	1.02	1.01	0.99	1.06	1.04	1.09
NORTH	SURATG-4	0.99	1.08	1.05	0.97	1.00	1.00	1.00	1.02	1.00	1.08
NORTH	BIKANER-NW	0.98	1.05	1.02	0.98	1.02	1.01	0.99	1.05	1.03	1.05
NORTH	BHADLA PG	0.98	1.08	1.02	0.98	1.02	1.01	0.98	1.07	1.05	1.08
NORTH	FATEHGARH	1.00	1.05	1.00	0.99	1.00	1.00	1.00	1.04	1.03	1.05
NORTH	FATEHG-3 SPL	0.99	1.08	1.02	0.99	1.00	1.00	1.00	1.06	1.05	1.08
NORTH	SHRECEM	0.98	1.06	1.03	0.97	1.00	0.99	0.98	1.03	1.03	1.06
NORTH	FATEHG-2	0.99	1.05	1.00	0.98	1.00	1.00	0.99	1.04	1.03	1.05
NORTH	BHADLA-2	0.98	1.05	1.01	0.98	1.00	1.00	0.99	1.05	1.03	1.05
NORTH	BEAWAR	0.97	1.06	1.04	0.96	1.01	1.01	0.95	1.05	1.04	1.06
NORTH	NAGAU	0.99	1.10	1.05	0.98	1.00	0.99	0.99	1.06	1.03	1.10

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
NORTH	LALSOT	1.00	1.07	1.05	0.98	0.99	0.98	1.02	1.03	1.00	1.07
NORTH	HANUMAN	0.99	1.10	1.07	0.98	1.02	1.01	1.01	1.04	1.02	1.10
NORTH	POKARAN	0.98	1.14	1.06	0.98	1.02	1.02	0.99	1.10	1.08	1.14
NORTH	MEJA	1.00	1.06	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	UNCHAHAAR	0.99	1.04	1.00	0.98	1.05	1.00	1.00	1.05	1.00	1.05
NORTH	BARA	1.00	1.07	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	KARCHNA	1.00	1.07	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	REWA	1.00	1.06	1.00	1.00	1.06	1.00	1.00	1.07	1.00	1.07
NORTH	GONDA	1.01	1.04	1.00	1.00	1.04	1.00	1.01	1.07	1.01	1.07
NORTH	MASALI	1.00	1.06	1.00	1.00	1.06	1.00	1.01	1.06	1.01	1.06
NORTH	SHAHJ-PG	1.00	1.04	1.00	1.00	1.04	1.00	1.01	1.06	1.01	1.06
NORTH	ANPARA4	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.00	1.05
NORTH	ANPARA-D	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.00	1.05
NORTH	ANPARAC	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.00	1.05
NORTH	ROSA-TP2	1.01	1.04	1.00	1.00	1.04	1.00	1.01	1.06	1.01	1.06
NORTH	OBRA4	1.00	1.07	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	SULTANP4	1.01	1.03	0.99	1.00	1.03	0.99	1.01	1.05	1.01	1.05
NORTH	BASTI	1.00	1.03	1.00	1.00	1.02	1.00	1.01	1.05	1.01	1.05
NORTH	TANDA2	1.00	1.05	1.00	1.00	1.04	1.00	1.00	1.07	1.01	1.07
NORTH	OBRA-C	1.00	1.07	1.00	1.00	1.07	1.00	1.00	1.07	1.00	1.07
NORTH	BADAUN	1.01	1.03	1.00	1.00	1.03	1.00	1.01	1.05	1.02	1.05
NORTH	JAKHORA400	1.02	1.03	1.03	1.02	1.05	1.02	0.99	0.99	0.98	1.05
NRTHEAST	MISA-PG	1.06	1.01	1.00	1.07	1.00	0.99	1.11	1.01	1.01	1.11
NRTHEAST	MARIANI-PG	1.11	1.03	1.01	1.12	1.02	0.99	1.18	1.02	1.01	1.18
NRTHEAST	BON-BAL-FSC1	0.99	1.01	0.98	1.01	1.06	0.98	1.01	1.01	0.98	1.06
NRTHEAST	BON-BAL-FSC2	0.99	1.01	0.98	1.01	1.06	0.98	1.01	1.01	0.98	1.06
NRTHEAST	AZARA	1.06	1.01	1.00	1.05	0.97	0.99	1.10	1.00	1.02	1.10

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
NRTHEAST	SONAPUR	1.07	1.01	1.01	1.07	0.98	1.00	1.12	1.01	1.03	1.12
NRTHEAST	SILCHAR-PG	1.12	0.99	1.00	1.13	1.01	0.98	1.19	1.01	1.02	1.19
NRTHEAST	BYRNIHAT	1.07	1.02	1.01	1.06	0.98	1.00	1.11	1.01	1.03	1.11
NRTHEAST	NEW KOHIMA	1.13	1.03	1.02	1.14	1.03	0.98	1.20	1.03	1.02	1.20
NRTHEAST	IMPHAL-PG	1.14	1.02	1.02	1.15	1.03	0.99	1.22	1.03	1.03	1.22
MYANMAR	TAMU	1.14	1.02	1.02	1.15	1.03	0.99	1.22	1.03	1.03	1.22
NRTHEAST	THOUBAL	1.14	1.02	1.02	1.15	1.03	0.99	1.22	1.03	1.03	1.22
NRTHEAST	PKBARI-ISTS	1.13	0.98	1.00	1.14	1.01	0.96	1.22	1.00	0.99	1.22
NRTHEAST	SURAJMANI NG	1.13	0.99	1.00	1.14	1.02	0.96	1.22	1.01	0.99	1.22
NRTHEAST	PALATANA	1.13	1.00	1.00	1.14	1.03	0.98	1.22	1.03	1.00	1.22
NRTHEAST	PURBANOAGAON	1.13	0.99	1.00	1.15	1.02	0.96	1.22	1.01	0.99	1.22
WEST	RAJG-FS1	1.01	1.06	1.07	1.01	1.03	1.03	0.99	1.02	1.00	1.07
WEST	RAJG-FS2	1.01	1.06	1.07	1.01	1.03	1.03	0.99	1.02	1.00	1.07
WEST	BHACHAUNDA	1.04	1.05	1.06	1.02	1.05	1.04	1.04	1.05	1.06	1.06
WEST	SHIVLAKHAPS	1.04	1.06	1.08	1.02	1.06	1.06	1.04	1.07	1.08	1.08
WEST	INDORE-4	0.99	1.04	1.05	0.98	1.03	1.02	0.99	1.02	1.01	1.05
WEST	BHOPAL-4	1.01	1.06	1.06	1.00	1.05	1.03	1.00	1.03	1.02	1.06
WEST	NAGDA-4	1.00	1.06	1.06	0.99	1.03	1.03	0.98	1.03	1.02	1.06
WEST	ITARSI-4	1.00	1.05	1.05	1.00	1.04	1.02	1.00	1.02	1.02	1.05
WEST	KHANDWA-4	1.01	1.06	1.06	1.00	1.04	1.03	1.00	1.03	1.02	1.06
WEST	RAJGARH-4	1.01	1.05	1.06	1.00	1.03	1.03	1.00	1.03	1.02	1.06
WEST	DAMOHPG-4	1.01	1.06	1.06	1.01	1.04	1.03	1.00	1.01	1.02	1.06
WEST	BIRSINGPR-4	1.03	1.06	1.05	1.02	1.05	1.03	1.01	1.03	1.03	1.06
WEST	KATNI-4	1.03	1.06	1.06	1.02	1.05	1.04	1.01	1.03	1.03	1.06
WEST	KHACS1	0.99	1.05	1.06	0.98	1.03	1.02	0.99	1.03	1.01	1.06
WEST	KHAC2	0.99	1.05	1.06	0.98	1.03	1.02	0.99	1.03	1.01	1.06
WEST	SHUJALPR-4	1.00	1.06	1.06	0.99	1.04	1.03	0.98	1.02	1.02	1.06

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
WEST	INDORE-74	1.00	1.06	1.06	0.99	1.03	1.03	1.00	1.02	1.02	1.06
WEST	CHEGAON	1.01	1.06	1.07	1.00	1.04	1.03	1.00	1.03	1.01	1.07
WEST	MALWA	1.01	1.07	1.07	1.01	1.04	1.03	1.01	1.04	1.00	1.07
WEST	PITHAMPUR-4	1.01	1.06	1.07	1.00	1.04	1.03	1.00	1.03	1.02	1.07
WEST	JULWNIA-4	1.00	1.05	1.06	0.99	1.02	1.02	1.00	1.01	1.00	1.06
WEST	BHOPAL_STER	1.00	1.06	1.06	1.00	1.05	1.03	1.00	1.03	1.03	1.06
WEST	MANDSAUR-4	1.00	1.07	1.07	0.99	1.03	1.03	0.97	1.04	1.03	1.07
WEST	UJJAIN-4	1.00	1.06	1.06	0.99	1.03	1.03	0.99	1.03	1.02	1.06
WEST	ASHTA-4	1.01	1.06	1.07	1.00	1.04	1.03	1.00	1.03	1.02	1.07
WEST	GUNA4_TBCB	1.02	1.06	1.05	1.01	1.05	1.03	1.00	1.03	1.03	1.06
WEST	MANDIDEEP-4	1.00	1.06	1.06	1.00	1.04	1.03	1.00	1.02	1.02	1.06
WEST	BETULGIS-4	1.01	1.05	1.06	1.01	1.04	1.03	1.00	1.03	1.02	1.06
WEST	PACHORASP	1.00	1.07	1.06	1.00	1.05	1.03	1.00	1.03	1.03	1.07
WEST	NEEMUCH_PS	1.00	1.07	1.06	1.00	1.03	1.02	0.97	1.05	1.04	1.07
WEST	MALWA_II	1.01	1.07	1.07	1.01	1.04	1.03	1.01	1.04	1.00	1.07
WEST	BADNAWAR-4	1.00	1.05	1.06	0.99	1.03	1.03	1.00	1.03	1.02	1.06
WEST	KHARGONE	1.01	1.05	1.05	1.00	1.05	1.02	1.00	1.05	1.01	1.05
WEST	MAUDA	1.03	1.06	1.06	1.02	1.05	1.04	1.02	1.04	1.03	1.06
WEST	JAIGAD II	1.07	0.96	0.94	1.00	0.96	0.95	0.98	0.96	0.96	1.07
WEST	DOLVI	1.06	0.93	0.91	1.00	0.92	0.92	0.97	0.92	0.94	1.06
EAST	PATNA	1.00	1.01	1.03	1.00	1.05	1.02	1.00	1.05	1.01	1.05
EAST	GAYA-PG	1.00	1.03	1.01	1.01	1.04	1.01	1.01	1.06	1.02	1.06
EAST	NABINAGAR-II	1.00	1.02	1.02	1.01	1.07	1.02	1.00	1.07	1.00	1.07
EAST	BARH-I	1.00	1.02	1.03	1.01	1.08	1.03	1.00	1.08	1.00	1.08
EAST	BAKHTIYR-NEW	1.00	1.02	1.03	1.00	1.06	1.03	1.00	1.06	1.00	1.06
EAST	BARH-II	1.00	1.02	1.03	1.01	1.08	1.03	1.00	1.08	1.00	1.08
EAST	JAKKANPUR-NW	1.00	1.01	1.03	1.00	1.05	1.02	1.00	1.05	1.01	1.05

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
EAST	CHANDAUTI NW	1.00	1.03	1.01	1.01	1.04	1.01	1.01	1.06	1.02	1.06
EAST	KATIHAR4	1.00	1.04	1.04	1.02	0.99	1.04	1.01	1.02	1.05	1.05
EAST	CHAPRA NEW	1.01	1.02	1.04	1.01	1.05	1.04	1.02	1.06	1.03	1.06
EAST	BIHARSHARF-B	1.02	1.04	1.04	1.02	1.05	1.04	1.03	1.06	1.05	1.06
EAST	KAHALGAON-A	1.03	1.07	1.03	1.03	1.07	1.03	1.01	1.07	1.06	1.07
EAST	SASARAM-NR	1.02	1.06	1.01	1.02	1.06	1.01	1.02	1.07	1.02	1.07
EAST	DUBURI	0.98	0.97	0.96	0.98	0.98	1.00	1.03	1.01	1.08	1.08
EAST	MENDHASAL	0.99	0.97	0.97	0.99	0.99	1.01	1.03	1.01	1.07	1.07
EAST	PARADEEP4	0.96	0.95	0.93	0.96	0.96	0.99	1.01	1.00	1.08	1.08
EAST	KEONJHAR	0.96	0.99	0.99	0.98	0.99	1.00	0.99	0.99	1.05	1.05
EAST	PANDIABILI	0.99	0.98	0.97	0.99	0.99	1.01	1.03	1.02	1.07	1.07
EAST	BEGUNIA	1.00	0.99	0.98	1.00	1.00	1.01	1.03	1.03	1.06	1.06
EAST	MERAMNDLI-B	0.99	0.98	0.97	0.99	0.99	1.01	1.03	1.02	1.07	1.07
EAST	BARIPADA	0.97	0.98	0.99	0.97	0.99	1.00	1.02	1.02	1.10	1.10
EAST	KHUNTUNI4	0.99	0.98	0.97	0.99	0.99	1.01	1.03	1.01	1.07	1.07
EAST	GMR-OD	0.99	0.98	0.97	0.99	0.99	1.01	1.03	1.02	1.07	1.07
EAST	BHADRAK-NEW	0.98	0.98	0.98	0.98	0.99	1.01	1.03	1.02	1.10	1.10
EAST	DURGAPUR TPS	1.01	1.06	1.04	1.01	1.06	1.04	1.00	1.06	1.08	1.08
EAST	MEJIA-B	1.03	1.06	1.04	1.03	1.07	1.04	1.02	1.07	1.08	1.08
EAST	JAMSHEDPR-PG	1.00	1.03	1.01	1.00	1.03	1.02	1.01	1.05	1.09	1.09
EAST	KODERMA-DVC	1.02	1.05	1.04	1.03	1.06	1.04	1.03	1.07	1.05	1.07
EAST	RAGHUNATHTPS	1.01	1.05	1.04	1.02	1.05	1.04	1.00	1.06	1.08	1.08
EAST	MAITHON-A	1.01	1.05	1.04	1.02	1.04	1.04	1.01	1.05	1.08	1.08
EAST	BIDHAN NGR	1.00	1.00	1.00	1.00	1.01	1.00	1.00	1.03	1.08	1.08
EAST	DURGAPUR-B	1.02	1.06	1.05	1.02	1.05	1.05	1.01	1.06	1.09	1.09
EAST	BOKARO-A	1.03	1.05	1.05	1.03	1.07	1.05	1.03	1.08	1.06	1.08
EAST	MAITHON-RB	1.00	1.05	1.04	1.01	1.04	1.04	1.00	1.05	1.08	1.08

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
EAST	JMSDPR-DVC	0.99	1.03	1.01	0.99	1.02	1.01	1.01	1.04	1.09	1.09
EAST	MAITHON-B	1.03	1.06	1.04	1.03	1.07	1.04	1.02	1.07	1.08	1.08
EAST	DURGAPUR-A	1.00	1.01	1.00	1.00	1.02	1.00	1.00	1.04	1.08	1.08
EAST	MEDINIPUR4	0.95	0.95	0.96	0.92	0.97	0.96	1.03	1.03	1.10	1.10
EAST	RAJARHAT	0.90	0.89	0.93	0.86	0.94	0.93	1.01	1.00	1.09	1.09
EAST	JEERAT	0.91	0.90	0.94	0.87	0.95	0.94	1.02	1.01	1.09	1.09
EAST	SUBHASGRAM	0.89	0.88	0.93	0.85	0.94	0.93	1.02	1.00	1.09	1.09
EAST	KOLAGHAT	0.94	0.92	0.95	0.91	0.96	0.96	1.03	1.02	1.12	1.12
EAST	HALDIA-TPS	0.89	0.92	0.96	0.84	0.98	0.96	1.02	1.02	1.09	1.09
EAST	CHANDITALA_N	0.94	0.93	0.96	0.91	0.96	0.96	1.03	1.02	1.11	1.11
EAST	KHARAGPR-WB	0.96	0.96	0.97	0.93	0.98	0.97	1.03	1.03	1.11	1.11
EAST	BAKRASWR	0.95	0.92	0.96	0.91	0.97	0.96	1.02	1.02	1.11	1.11
EAST	GOKARNA	0.97	0.98	0.99	0.95	0.99	0.99	1.01	1.02	1.06	1.06
EAST	ARAMBAGH	0.94	0.93	0.96	0.91	0.97	0.96	1.03	1.02	1.11	1.11
EAST	NEW LAXMKTNP	0.89	0.89	0.94	0.84	0.95	0.94	1.02	1.01	1.09	1.09
EAST	PPSP_NEW	1.00	1.03	1.00	1.00	1.03	1.00	1.00	1.03	1.07	1.07
EAST	PURULIAPS	1.00	1.03	1.00	1.00	1.03	1.00	1.00	1.03	1.07	1.07
EAST	JEERAT-NEW	0.91	0.90	0.94	0.87	0.95	0.94	1.02	1.01	1.09	1.09
EAST	KATWA-TPS	0.96	0.97	0.98	0.95	0.99	0.99	1.02	1.03	1.08	1.08
EAST	TURGA_PSP	1.00	1.03	1.00	1.00	1.03	1.00	1.00	1.03	1.07	1.07
EAST	FAR_K-A_D-B	1.03	1.08	1.05	1.04	1.08	1.05	1.02	1.08	1.08	1.08
EAST	FAR_K-A_D-A	1.02	1.05	1.02	1.02	1.05	1.02	1.01	1.06	1.07	1.07
EAST	LATEHAR-NEW	1.00	1.04	1.01	1.01	1.04	1.01	1.00	1.05	1.03	1.05
EAST	PATRATU	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.03	1.05
EAST	ESSAR-BYPASS	1.00	1.04	1.01	1.01	1.03	1.01	1.00	1.06	1.03	1.06
EAST	ADHUNIK	1.00	1.03	1.01	1.00	1.03	1.02	1.01	1.05	1.09	1.09
EAST	JHARKND-POOL	1.00	1.04	1.01	1.01	1.03	1.01	1.00	1.06	1.03	1.06

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
EAST	DHANBAD_4	1.00	1.05	1.04	1.01	1.03	1.04	1.00	1.04	1.08	1.08
EAST	RANCHI	1.01	1.04	1.02	1.01	1.03	1.02	1.01	1.05	1.06	1.06
EAST	RNC-SIPT FSC	1.02	1.08	1.06	1.04	1.07	1.07	0.98	1.04	1.06	1.08
EAST	RNC-SIPT FSC	1.02	1.08	1.06	1.04	1.07	1.07	0.98	1.04	1.06	1.08
EAST	NORTHKARNPRA	1.01	1.04	1.01	1.01	1.03	1.01	1.00	1.07	1.02	1.07
EAST	PVUNL	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.03	1.05
EAST	NEW CHANDIL	1.00	1.05	1.01	1.00	1.03	1.01	1.01	1.03	1.05	1.05
EAST	CHAIBASA	0.99	1.01	1.00	0.99	1.01	1.01	1.01	1.03	1.08	1.08
EAST	RR1	1.01	1.04	1.02	1.01	1.03	1.02	1.01	1.05	1.06	1.06
EAST	RR2	1.01	1.04	1.02	1.01	1.03	1.02	1.01	1.05	1.06	1.06
SOUTH	MUDN400	1.04	1.06	1.04	1.03	1.06	1.00	1.05	1.06	1.00	1.06
SOUTH	JAGALUR4	1.02	1.05	1.03	1.01	1.04	1.01	1.00	1.04	1.01	1.05
SOUTH	TORNG4	1.02	1.04	1.02	1.00	1.05	1.00	1.00	1.05	1.00	1.05
SOUTH	BELLARY TPP	1.01	1.06	1.00	1.01	1.06	1.00	1.00	1.06	1.00	1.06
SOUTH	YERAMRS TPP	1.02	1.05	1.00	1.01	1.05	1.00	1.00	1.05	1.00	1.05
SOUTH	BELLARY-POOL	1.02	1.04	1.02	1.00	1.05	1.00	1.00	1.05	1.00	1.05
SOUTH	NEY 2 EXT2ND	1.00	1.05	1.01	1.00	1.04	1.00	1.00	1.05	1.01	1.05
SOUTH	NAGAPTNM4	1.00	1.05	1.01	1.00	1.05	1.00	1.00	1.05	1.01	1.05
SOUTH	KARAIK	1.01	1.05	1.03	1.01	1.03	1.01	1.02	1.04	1.03	1.05
SOUTH	OPG400KV	1.06	0.99	1.00	1.06	0.99	1.00	1.00	0.99	1.00	1.06
SOUTH	VIRUDHNAGAR	1.01	1.05	1.02	1.01	1.04	1.00	1.01	1.04	1.01	1.05
SOUTH	MANALMEDU4	1.00	1.05	1.02	1.00	1.05	1.01	1.01	1.05	1.01	1.05
SOUTH	ALAGARKOIL	1.02	1.05	1.03	1.01	1.04	1.01	1.02	1.04	1.02	1.05
SOUTH	VELALVIDU	1.01	1.06	1.04	1.00	1.03	1.01	1.02	1.04	1.03	1.06
SOUTH	UDNGDI4	1.01	1.05	1.02	1.01	1.05	1.00	1.00	1.05	1.00	1.05
SOUTH	ILFS-OA	1.00	1.05	1.00	1.00	1.05	1.00	1.00	1.05	1.00	1.05
SOUTH	ETPSEXP4	1.06	0.99	1.00	1.06	0.99	1.00	1.00	0.99	1.00	1.06

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Max
SOUTH	NORTH CHEN P	1.06	0.99	1.00	1.06	0.99	1.00	1.00	0.99	1.00	1.06
SOUTH	ENNORE-SEZ	1.06	0.99	1.00	1.06	0.99	1.00	1.00	0.99	1.00	1.06
SOUTH	SAMUGARANGAP	1.01	1.05	1.02	1.01	1.05	1.00	1.00	1.05	1.00	1.05

Note: Highlighted cell indicates 400 kV Bus Voltage ≥ 1.05 P.U.

Under Voltage Nodes

765kV Bus Voltage ≤ 0.95 PU

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Min
NORTH	MOGA-PG	0.95	1.05	1.01	0.94	1.03	1.00	0.96	1.06	1.02	0.94
NORTH	BHIWN-PG	0.95	1.03	1.01	0.94	1.01	1.00	0.97	1.03	1.02	0.94
NORTH	NARELA ISTS	0.93	1.02	1.00	0.92	1.00	1.00	0.95	1.03	1.02	0.92
NORTH	JHATI-PG	0.94	1.02	1.00	0.93	1.00	0.99	0.96	1.02	1.02	0.93
NORTH	CHIT-NEW	0.98	1.04	1.03	0.97	1.00	1.01	0.94	1.05	1.04	0.94
NORTH	BIKANER-NW	0.95	1.07	1.03	0.95	1.03	1.02	0.96	1.06	1.04	0.95
NORTH	FATEHG-3	0.95	1.05	1.03	0.95	1.01	1.02	0.93	1.05	1.04	0.93
NORTH	BHADLA-3	0.93	1.03	1.03	0.93	0.99	1.06	0.94	1.03	1.05	0.93
NORTH	SIKAR NEW	0.91	1.05	1.03	0.90	1.02	1.02	0.93	1.05	1.04	0.90
NORTH	BHADLA-2	0.95	1.06	1.02	0.95	1.02	1.01	0.96	1.06	1.04	0.95
NORTH	BEAWAR	0.96	1.07	1.05	0.96	1.02	1.03	0.94	1.07	1.05	0.94
NORTH	KHETRI	0.93	1.05	1.02	0.92	1.02	1.01	0.95	1.05	1.04	0.92
NORTH	MEERTFS1	0.96	1.01	0.99	0.95	1.00	0.99	0.96	1.02	1.01	0.95
NORTH	MEERTFS2	0.96	1.01	0.99	0.95	1.00	0.99	0.96	1.02	1.01	0.95
WEST	VADODARA	0.95	1.01	1.03	0.92	1.01	1.01	0.97	1.03	1.02	0.92
WEST	AHMDABAD PG	0.93	0.99	1.01	0.89	0.99	0.99	0.92	1.02	1.01	0.89

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Min
WEST	BANASKANTHA	0.97	1.00	1.02	0.94	1.00	1.01	0.95	1.03	1.03	0.94
WEST	LAKADIA 765	0.96	0.99	1.02	0.95	1.00	1.01	0.96	1.03	1.03	0.95
WEST	NAVSARI-NEW	0.93	0.97	0.98	0.88	0.96	0.98	0.92	0.99	0.99	0.88
WEST	PUNE-PG-GIS	0.98	0.99	0.99	0.95	0.98	0.99	0.96	0.99	0.99	0.95
WEST	PADGHEGIS	0.96	0.98	0.99	0.93	0.97	0.98	0.95	0.99	0.99	0.93
EAST	MEDINIPUR7	0.94	0.94	0.96	0.91	0.96	0.95	1.02	1.03	1.09	0.91
EAST	JEERAT7	0.93	0.92	0.94	0.89	0.95	0.94	1.02	1.02	1.09	0.89

Note: Highlighted cell indicates 765kV Bus Voltage ≤ 0.95 P.U.

400kV Bus Voltage ≤ 0.95 PU

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Min
WEST	ASOJ-BYP-KOS	0.96	1.00	1.03	0.90	0.99	1.00	0.96	1.00	1.01	0.90
WEST	DGM-BYP-NICL	0.95	0.99	1.02	0.90	0.98	0.99	0.95	1.00	1.01	0.90
WEST	DGM-BYP-PIR	0.96	1.00	1.02	0.92	0.99	1.00	0.96	1.02	1.02	0.92
NORTH	K-B-FSC2	0.95	0.98	0.97	0.95	0.98	0.97	0.98	1.00	1.01	0.95
NORTH	K-B-FSC3	0.95	0.98	0.97	0.95	0.98	0.97	0.98	1.00	1.01	0.95
NORTH	BAMNAULI4	0.94	1.00	0.98	0.93	0.98	0.97	0.97	1.02	1.02	0.93
NORTH	MUNDKA	0.95	1.01	1.00	0.94	1.00	0.99	0.98	1.02	1.01	0.94
NORTH	JHATIKALA-PG	0.95	1.01	1.00	0.94	1.00	0.99	0.98	1.02	1.01	0.94
NORTH	TUGHLAKABAD	0.95	0.99	0.98	0.94	0.98	0.97	0.98	1.01	1.01	0.94
NORTH	GOPAL PUR	0.95	1.00	0.99	0.94	0.99	0.98	0.97	1.01	1.01	0.94
NORTH	DWARKA	0.94	1.00	0.99	0.93	0.98	0.98	0.97	1.02	1.02	0.93
NORTH	NARELA ISTS	0.94	1.01	0.99	0.94	0.99	0.99	0.97	1.01	1.01	0.94
NORTH	JHATIKARASP	0.94	1.00	0.99	0.93	0.99	0.98	0.97	1.02	1.02	0.93
NORTH	MAHARANIBAGH	0.95	1.00	0.99	0.94	0.99	0.98	0.98	1.01	1.01	0.94

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Min
NORTH	BHINMAL	0.97	1.10	1.05	0.96	1.00	1.00	0.94	1.07	1.06	0.94
NORTH	SIKAR NEW	0.93	1.04	1.03	0.92	1.02	1.02	0.94	1.05	1.04	0.92
WEST	MAGARWADA-DD	0.96	0.97	0.99	0.90	0.97	0.98	0.96	0.98	0.99	0.90
WEST	KALA DNH	0.96	0.97	0.99	0.91	0.96	0.98	0.96	0.98	0.99	0.91
WEST	ASOJ4	0.96	1.00	1.03	0.90	0.99	1.00	0.96	1.00	1.01	0.90
WEST	GANCS4	0.96	0.99	1.01	0.88	0.98	1.00	0.96	0.99	1.00	0.88
WEST	DEHGM4	0.98	1.01	1.04	0.92	1.00	1.01	0.97	1.00	1.01	0.92
WEST	WANAKBORI	0.97	1.01	1.04	0.91	1.00	1.00	0.97	1.00	1.00	0.91
WEST	SOJA4	0.98	1.01	1.04	0.92	1.00	1.01	0.97	1.01	1.02	0.92
WEST	UKAI	0.96	0.98	1.01	0.87	0.97	1.00	0.96	0.98	1.00	0.87
WEST	GPEC4	0.96	0.99	1.02	0.88	0.98	1.00	0.96	0.99	1.01	0.88
WEST	VAPI4	0.96	0.97	0.99	0.91	0.96	0.99	0.97	0.97	0.99	0.91
WEST	SUGEN	0.95	0.98	1.00	0.86	0.98	1.00	0.95	0.98	1.00	0.86
WEST	PIRANA_T	0.93	0.98	1.00	0.88	0.98	0.99	0.92	1.00	1.00	0.88
WEST	PIRANA_P	0.95	0.99	1.01	0.90	0.98	0.99	0.94	1.01	1.01	0.90
WEST	RANCHODPURA	0.98	1.01	1.03	0.94	1.00	1.01	0.98	1.02	1.03	0.94
WEST	KASOR4	0.99	1.02	1.04	0.95	1.01	1.01	0.99	1.02	1.02	0.95
WEST	HAZIRA4	0.93	0.96	1.00	0.83	0.94	0.97	0.94	0.96	0.98	0.83
WEST	SAMI_FSC	0.99	1.01	1.04	0.95	1.01	1.01	0.98	1.01	1.02	0.95
WEST	SAMI-F2	0.99	1.01	1.04	0.95	1.01	1.01	0.98	1.01	1.02	0.95
WEST	KOSAMBA	0.96	0.98	1.01	0.88	0.98	1.00	0.96	0.99	1.01	0.88
WEST	SUGEN-UN	0.95	0.98	1.00	0.86	0.98	1.00	0.95	0.98	1.00	0.86
WEST	DGEN	0.98	1.00	1.00	0.91	1.00	1.00	0.98	1.00	1.00	0.91
WEST	NAVSARI	0.98	0.99	1.00	0.91	0.98	1.00	0.98	0.99	1.00	0.91
WEST	VADODARA	0.95	1.00	1.02	0.91	1.00	1.00	0.96	1.02	1.02	0.91
WEST	AHMDABAD PG	0.94	0.99	1.01	0.89	0.98	0.99	0.93	1.01	1.01	0.89
WEST	VAV4	0.96	0.98	1.00	0.88	0.97	1.00	0.96	0.98	1.00	0.88

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Min
WEST	PRANTIJ	0.98	1.01	1.04	0.92	1.00	1.01	0.97	1.02	1.02	0.92
WEST	VAPI NEW	0.97	0.97	0.99	0.91	0.97	0.99	0.97	0.97	0.99	0.91
WEST	KAKRAPR-3&4	1.00	1.00	1.00	0.94	1.00	1.00	1.00	1.00	1.00	0.94
WEST	NICOL TORREN	0.94	0.98	1.01	0.89	0.97	0.98	0.93	1.00	1.00	0.89
WEST	SAYAKHA	0.97	1.00	1.02	0.89	0.99	1.01	0.97	1.00	1.02	0.89
WEST	NAVSARI-NEW	0.94	0.97	0.99	0.89	0.96	0.98	0.94	0.98	0.99	0.89
WEST	KALWA4	0.96	0.95	0.96	0.92	0.93	0.95	0.95	0.94	0.97	0.92
WEST	KHARGAR	0.96	0.95	0.96	0.92	0.93	0.96	0.95	0.95	0.97	0.92
WEST	LONIKAND I	0.96	0.94	0.95	0.91	0.91	0.93	0.94	0.92	0.97	0.91
WEST	JEJ4	0.96	0.92	0.94	0.90	0.89	0.92	0.94	0.91	0.96	0.89
WEST	TAPS4	0.97	0.97	0.98	0.94	0.96	0.97	0.97	0.97	0.99	0.94
WEST	BOISAR	0.97	0.97	0.98	0.93	0.96	0.98	0.97	0.97	0.99	0.93
WEST	CHAKAN	0.96	0.94	0.96	0.91	0.92	0.94	0.94	0.93	0.97	0.91
WEST	PUNE-PG-AIS	0.97	0.96	0.97	0.92	0.93	0.95	0.95	0.95	0.98	0.92
WEST	PUNE-PG-GIS	0.98	0.98	0.99	0.95	0.96	0.98	0.96	0.97	0.99	0.95
WEST	PADGHEGIS	0.97	0.98	0.98	0.95	0.97	0.98	0.97	0.98	0.99	0.95
WEST	JAIGAD II	1.07	0.96	0.94	1.00	0.96	0.95	0.98	0.96	0.96	0.94
WEST	DOLVI	1.06	0.93	0.91	1.00	0.92	0.92	0.97	0.92	0.94	0.91
WEST	LONIKANDII	0.96	0.94	0.95	0.91	0.91	0.93	0.94	0.92	0.97	0.91
WEST	HINJWD40	0.95	0.92	0.94	0.90	0.89	0.92	0.93	0.91	0.96	0.89
WEST	KESURDI400	0.97	0.94	0.95	0.93	0.91	0.93	0.96	0.93	0.97	0.91
WEST	RETWADI400	0.96	0.94	0.95	0.91	0.91	0.93	0.94	0.93	0.97	0.91
WEST	VIKROLI400	0.96	0.95	0.96	0.92	0.93	0.95	0.95	0.94	0.97	0.92
WEST	VELGAON4	0.97	0.97	0.98	0.94	0.95	0.97	0.96	0.96	0.98	0.94
WEST	NAVI-MUM	0.96	0.95	0.97	0.92	0.93	0.96	0.95	0.95	0.97	0.92
EAST	JEY-BOL_FSC	0.97	0.94	0.96	0.94	0.96	0.96	0.96	0.97	0.96	0.94
EAST	PARADEEP4	0.96	0.95	0.93	0.96	0.96	0.99	1.01	1.00	1.08	0.93

Area Name	Bus Name	V-Sc1	V-Sc2	V-Sc3	V-Sc4	V-Sc5	V-Sc6	V-Sc7	V-Sc8	V-Sc9	Min
EAST	MEDINIPUR4	0.95	0.95	0.96	0.92	0.97	0.96	1.03	1.03	1.10	0.92
EAST	RAJARHAT	0.90	0.89	0.93	0.86	0.94	0.93	1.01	1.00	1.09	0.86
EAST	JEERAT	0.91	0.90	0.94	0.87	0.95	0.94	1.02	1.01	1.09	0.87
EAST	SUBHASGRAM	0.89	0.88	0.93	0.85	0.94	0.93	1.02	1.00	1.09	0.85
EAST	KOLAGHAT	0.94	0.92	0.95	0.91	0.96	0.96	1.03	1.02	1.12	0.91
EAST	HALDIA-TPS	0.89	0.92	0.96	0.84	0.98	0.96	1.02	1.02	1.09	0.84
EAST	CHANDITALA_N	0.94	0.93	0.96	0.91	0.96	0.96	1.03	1.02	1.11	0.91
EAST	KHARAGPR-WB	0.96	0.96	0.97	0.93	0.98	0.97	1.03	1.03	1.11	0.93
EAST	BAKRASWR	0.95	0.92	0.96	0.91	0.97	0.96	1.02	1.02	1.11	0.91
EAST	ARAMBAGH	0.94	0.93	0.96	0.91	0.97	0.96	1.03	1.02	1.11	0.91
EAST	NEW LAXMKTNP	0.89	0.89	0.94	0.84	0.95	0.94	1.02	1.01	1.09	0.84
EAST	JEERAT-NEW	0.91	0.90	0.94	0.87	0.95	0.94	1.02	1.01	1.09	0.87
EAST	KATWA-TPS	0.96	0.97	0.98	0.95	0.99	0.99	1.02	1.03	1.08	0.95
SOUTH	ANNARAM-LI	0.93	1.03	0.97	0.94	1.04	1.00	0.99	1.04	1.00	0.93
SOUTH	SINGARENI	0.93	1.04	0.98	0.95	1.05	1.00	1.00	1.05	1.00	0.93
SOUTH	RAMADAGU LI	0.95	1.01	0.96	0.96	1.02	0.99	0.99	1.02	0.98	0.95
SOUTH	MYDARAM LI	0.94	1.00	0.95	0.95	1.02	0.98	0.98	1.01	0.97	0.94
SOUTH	YELLAMPALLI	0.94	1.03	0.97	0.95	1.04	1.00	1.00	1.04	1.00	0.94

Note: Highlighted cell indicates 400kV Bus Voltage ≤ 0.95 P.U.

Annex 7.6.1

765kV Buses Exceeding Design Fault Current

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
NORTH	JAIPUR 765.00	kA	36	36	36	39	38	38	41	38	38	41	40	STU
WEST	BLPSR WR 765.00	kA	38	41	41	42	43	43	44	44	44	44	40	ISTS
WEST	BINA-PG-7 765.00	kA	39	40	40	40	41	41	41	41	41	41	40	ISTS
WEST	JABALPR-POOL765.00	kA	45	48	48	48	51	51	51	51	51	51	50	ISTS
WEST	WARDHA 765.00	kA	37	39	39	39	40	40	41	40	40	41	40	ISTS
WEST	AURANG-CHTPM765.00	kA	37	39	39	38	40	40	41	40	40	41	40	ISTS

Note: Highlighted cell indicates 765 kV Bus Fault Current greater than Design level

400kV Buses Exceeding Design Fault Current

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
NORTH	PATIALA 400.00	kA	41	45	45	42	45	45	44	45	45	45	40	ISTS
NORTH	JALANDHA 400.00	kA	38	43	43	39	43	43	42	43	43	43	40	ISTS
NORTH	SONAROAD 400.00	kA	38	42	42	39	43	43	41	43	43	43	40	STU
NORTH	DAULATABAD4 400.00	kA	37	43	43	38	43	44	40	43	43	44	40	STU
NORTH	JHAJAR_N 400.00	kA	32	40	40	32	40	40	39	40	40	40	40	GEN
NORTH	DHANONDA 400.00	kA	42	49	49	42	50	50	48	50	50	50	40	STU
NORTH	PANCH-PG 400.00	kA	39	43	43	40	43	43	41	43	43	43	40	ISTS
NORTH	ABDULLAP 400.00	kA	44	49	49	45	49	49	46	49	49	49	40	ISTS
NORTH	BAWANA-G 400.00	kA	40	50	50	40	51	51	43	51	51	51	40	STU

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
NORTH	BAWANA 400.00	kA	40	50	51	41	51	51	43	51	51	51	40	STU
NORTH	MANDOLA 400.00	kA	38	41	41	38	42	42	39	41	41	42	40	ISTS
NORTH	MUNDKA 400.00	kA	36	42	42	36	42	42	38	42	42	42	40	STU
NORTH	MANDOLASP2 400.00	kA	38	41	41	38	42	42	39	41	41	42	40	ISTS
NORTH	MANDOLASP3 400.00	kA	38	41	41	38	42	42	39	41	41	42	40	ISTS
NORTH	GOPAL PUR 400.00	kA	39	41	42	39	42	42	41	42	42	42	40	STU
NORTH	BHADLA 400.00	kA	42	34	35	42	35	36	44	35	35	44	40	STU
NORTH	BASSI 400.00	kA	44	44	44	45	45	46	47	45	45	47	40	ISTS
NORTH	NEEMR-PG 400.00	kA	44	48	48	45	49	49	49	49	49	49	40	ISTS
NORTH	SIKAR 400.00	kA	39	38	38	39	41	41	42	41	41	42	40	ISTS
NORTH	JAIPUR_RS 400.00	kA	46	46	46	48	47	47	50	47	47	50	40	STU
NORTH	BHADLA PG 400.00	kA	50	38	38	50	39	39	51	39	39	51	50	ISTS
NORTH	ANTA-4 400.00	kA	24	37	37	33	41	41	41	41	41	41	40	STU
NORTH	FATEHG-2 400.00	kA	51	36	36	52	36	37	53	36	36	53	50	ISTS
NORTH	BHADLA-2 400.00	kA	52	39	39	52	40	40	53	39	39	53	50	ISTS
NORTH	BHIWADI 400.00	kA	44	45	45	44	47	47	47	46	46	47	40	ISTS
NORTH	MEJA 400.00	kA	41	42	42	42	49	49	48	48	48	49	40	GEN
NORTH	BAGPAT 400.00	kA	41	43	43	41	44	44	42	43	43	44	40	STU
NORTH	BARA 400.00	kA	40	41	41	41	45	45	44	44	44	45	40	STU
NORTH	REWA 400.00	kA	36	37	37	37	40	40	40	40	40	40	40	STU
NORTH	GNOIDAUP 400.00	kA	47	50	50	48	54	54	49	51	51	54	40	STU
NORTH	GAZIABAD 400.00	kA	38	40	40	39	42	41	40	40	40	42	40	STU
NORTH	UNNAO4 400.00	kA	37	39	39	38	41	41	39	39	39	41	40	STU
NORTH	DADR-NCR 400.00	kA	44	51	51	44	53	53	46	52	52	53	40	GEN
NORTH	KANPUR 400.00	kA	45	47	47	46	48	48	47	48	48	48	40	ISTS

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
NORTH	GNOIDA4 400.00	kA	46	51	51	46	53	53	48	51	51	53	40	STU
NORTH	LUCK4-PG 400.00	kA	45	48	48	46	50	49	49	49	49	50	40	ISTS
NORTH	LUCK74-P 400.00	kA	43	46	46	45	48	47	47	47	47	48	40	ISTS
NORTH	DADR-HVD 400.00	kA	43	50	50	44	52	52	45	51	51	52	40	GEN
NORTH	ANPARA4 400.00	kA	49	51	51	51	52	52	52	52	52	52	40	GEN
NORTH	ANPARA-D 400.00	kA	43	45	45	45	46	45	45	46	46	46	40	GEN
NORTH	ANPARAC 400.00	kA	48	50	50	50	51	50	51	51	51	51	40	GEN
NORTH	ALLAHABA 400.00	kA	45	47	47	46	50	50	49	50	50	50	40	ISTS
NORTH	BAL74-PG 400.00	kA	41	43	43	41	47	44	46	46	46	47	40	ISTS
NORTH	SARNATH4 400.00	kA	40	42	42	41	42	42	43	43	43	43	40	STU
NORTH	KANPRNEW 400.00	kA	47	49	49	48	50	50	50	50	50	50	50	ISTS
NORTH	MEERUT 400.00	kA	58	62	62	58	63	63	61	62	62	63	40	ISTS
NORTH	AGRA 400.00	kA	50	50	50	50	52	52	52	51	51	52	40	STU
NORTH	SINGRL4 400.00	kA	43	43	43	43	44	44	44	44	44	44	40	GEN
NORTH	TIKRI KHURD 400.00	kA	37	45	45	37	45	45	39	45	45	45	40	STU
WEST	KNTPC 400.00	kA	45	44	44	46	44	44	47	44	44	47	40	GEN
WEST	BHI4 400.00	kA	43	45	45	45	46	46	47	46	46	47	40	GEN
WEST	JINDAL_EX 400.00	kA	39	42	42	42	42	42	43	43	43	43	40	GEN
WEST	BIL-POOL 400.00	kA	37	43	43	46	47	47	47	47	47	47	40	ISTS
WEST	RAIPUR SPLT 400.00	kA	40	41	41	41	42	42	43	42	42	43	40	ISTS
WEST	CHORN4 400.00	kA	40	42	42	40	43	43	42	44	44	44	40	STU
WEST	RANCHODPURA 400.00	kA	37	38	38	37	39	39	39	40	40	40	40	STU
WEST	CGPL 400.00	kA	44	44	44	44	44	44	44	44	44	44	40	GEN
WEST	VADODARA 400.00	kA	38	40	40	39	41	41	39	41	41	41	40	ISTS
WEST	BHUJ POOL 400.00	kA	43	40	41	43	40	42	43	41	41	43	40	ISTS

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
WEST	SANKHARI 400.00	kA	42	42	42	42	44	44	45	46	46	46	40	STU
WEST	NAVSARI-NEW 400.00	kA	38	41	41	38	41	41	39	41	41	41	40	ISTS
WEST	BHOPAL-4 400.00	kA	40	40	40	41	41	41	42	41	41	42	40	STU
WEST	BINA-4 400.00	kA	37	39	39	40	39	39	40	39	39	40	40	ISTS
WEST	NAGDA-4 400.00	kA	40	39	40	40	41	41	41	42	42	42	40	STU
WEST	JABALPUR-4 400.00	kA	36	37	37	36	40	40	41	40	40	41	40	ISTS
WEST	ITARSI-4 400.00	kA	38	39	39	39	40	40	41	41	41	41	0	ISTS
WEST	KHANDWA-4 400.00	kA	40	42	42	43	45	45	43	46	46	46	40	ISTS
WEST	BINA-PG-74 400.00	kA	37	39	39	40	39	40	41	40	40	41	40	ISTS
WEST	PARLI-GIRWAL 400.00	kA	40	40	40	41	40	41	43	41	41	43	40	STU
WEST	CHANDRAPUR I 400.00	kA	24	39	39	24	44	44	45	44	44	45	40	STU
WEST	BHADRA 400.00	kA	23	34	34	23	40	40	41	40	40	41	40	ISTS
WEST	AURANGBD-I 400.00	kA	44	45	45	45	45	45	46	46	46	46	40	STU
WEST	CHANDRPR-II 400.00	kA	24	39	39	24	44	44	45	44	44	45	40	STU
WEST	PARLI-PG 400.00	kA	41	41	41	42	41	41	44	41	41	44	0	ISTS
WEST	AURANGABD-II 400.00	kA	44	45	45	45	46	46	47	46	46	47	40	STU
WEST	AURANGBD-III 400.00	kA	44	45	45	45	46	46	47	46	46	47	40	STU
WEST	PARLI NEW 400.00	kA	39	38	38	39	39	39	41	39	39	41	40	ISTS
WEST	PADGHEGIS 400.00	kA	49	53	53	50	53	53	51	53	53	53	50	ISTS
WEST	KUDUS 400.00	kA	51	54	55	52	55	55	53	55	55	55	40	STU
WEST	CHNDPUR_SW 400.00	kA	23	37	37	23	42	42	43	42	42	43	40	STU
EAST	PATNA 400.00	kA	30	32	32	31	41	33	40	40	40	41	40	ISTS
EAST	GAYA-PG 400.00	kA	43	46	46	44	50	46	54	54	54	54	40	ISTS
EAST	BARH-I 400.00	kA	28	31	31	28	47	31	47	47	47	47	40	GEN
EAST	BARH-II 400.00	kA	28	31	31	28	47	31	47	47	47	47	40	GEN

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
EAST	PURNEA-NW-PG400.00	kA	38	40	40	38	41	40	40	41	41	41	40	ISTS
EAST	JHARSUGUDA-A400.00	kA	50	51	51	51	52	52	52	52	52	52	40	ISTS
EAST	STERLITE 400.00	kA	50	51	51	51	51	51	52	52	52	52	50	STU
EAST	JHARSUGUDA-B400.00	kA	40	41	41	41	43	41	42	42	42	43	40	ISTS
EAST	GAZUWAKA-ER 400.00	kA	52	51	51	51	51	51	51	51	51	52	40	ISTS
EAST	SAGARDIGHI_4400.00	kA	30	40	40	30	40	40	32	40	40	40	40	GEN
EAST	FARAKKA 400.00	kA	38	44	44	38	45	44	41	45	45	45	40	ISTS
EAST	ESSAR-BYPASS400.00	kA	35	36	36	35	37	36	43	43	43	43	40	GEN
EAST	JHARKND-POOL400.00	kA	36	37	37	36	38	37	44	44	44	44	40	ISTS
EAST	RANCHI 400.00	kA	41	43	43	42	43	43	47	47	47	47	40	ISTS
EAST	RANCHNEW 400.00	kA	48	50	50	48	50	50	54	54	54	54	40	ISTS
SOUTH	KURNOOL4 400.00	kA	44	43	43	44	43	43	43	44	41	44	40	STU
SOUTH	VII-AP 400.00	kA	37	41	41	38	41	41	40	42	41	42	40	STU
SOUTH	RAMGUNDM STP400.00	kA	38	40	40	38	40	40	40	40	40	40	40	GEN
SOUTH	HYDERABAD-TS400.00	kA	42	47	47	42	44	44	47	47	47	47	40	STU
SOUTH	DICHPAL4 400.00	kA	36	40	40	36	40	40	41	40	40	41	40	STU
SOUTH	NIZAMABAD 400.00	kA	38	42	42	38	42	42	43	43	42	43	40	ISTS
SOUTH	MAHESWRM 400.00	kA	56	62	63	56	59	59	63	63	62	63	63	ISTS
SOUTH	MAHESH-TS 400.00	kA	56	63	63	56	59	59	63	63	62	63	50	STU
SOUTH	TIPPAPUR LI 400.00	kA	33	41	41	33	39	39	41	41	41	41	40	STU
SOUTH	CHANDULAPUR 400.00	kA	34	42	42	34	40	40	42	42	42	42	40	STU
SOUTH	DINDI 400.00	kA	41	47	47	41	43	43	47	47	46	47	40	STU
SOUTH	NELMANG4 400.00	kA	39	40	40	40	41	41	42	42	41	42	40	STU
SOUTH	MADHUGI4 400.00	kA	42	42	42	44	44	44	45	44	43	45	40	ISTS
SOUTH	UDMP 400.00	kA	41	44	45	43	46	46	40	46	42	46	40	ISTS

Area	Bus Name	Unit	Sc-1	Sc-2	Sc-3	Sc-4	Sc-5	Sc-6	Sc-7	Sc-8	Sc-9	Max	Design Level	Remark
SOUTH	PUGALUR4 400.00	kA	36	38	38	37	39	40	34	40	35	40	40	ISTS
SOUTH	TIRUNEL4 400.00	kA	37	38	38	39	42	42	38	42	38	42	40	ISTS
SOUTH	TUTI-POOL 400.00	kA	30	30	31	39	40	41	35	40	35	41	40	ISTS
SOUTH	ARIYALUR4 400.00	kA	36	40	40	37	41	41	38	41	40	41	40	STU

Note: Highlighted cell indicates 400 kV Bus Fault Current greater than Design level



**Prepared by
Central Transmission Utility (CTU)**

December 2021

