

**Additional Agenda for 51st NR constituents meeting regarding Connectivity/LTA Applications in NR to be held on
28.10.2021**

1.0 Proposal for Part Operationalization of LTA for 100 MW out of 350 MW granted to Avaada Energy Private Ltd.

- LTA (Application No. 1200002185) was granted to M/s Avaada Energy Pvt. Ltd. at Bikaner PS through Part of Rajasthan SEZ Phase-I & Transmission scheme for controlling high loading and high short circuit level at Moga substation vide intimation dated 10/10/2019
- The meeting regarding early operationalization of LTAs granted at Fatehgarh PS, Fatehgarh-II PS, Bhadla (PG) S/s, Bhadla-II PS & Bikaner PS utilizing available margins was held through VC on 17.09.2021 amongst CEA, CTU, POSOCO, SECI and various LTA Grantees in Bhadla/Fatehgarh/Bikaner Complex associated with Transmission System for Solar Energy Zones in Rajasthan (8.9GW) under Phase-I (Rajasthan SEZ Phase-I) and Transmission scheme for controlling high loading and high short circuit level at Moga substation (Moga Bus Splitting).
- During this meeting it was deliberated that margin of 1000 MW is available at Bikaner PS for part operationalization of LTA. Based on available margins, it was agreed to operationalize the following LTAs at Bikaner PS:

Sl. No.	Name of Applicant	Application No.	LTA Quantum (MW)	Start Date of LTA* as per intimation	LTA to be Operationalized (MW)	Remarks
Bikaner PS						
1	ReNew Solar Power Pvt. Ltd.	1200001640	250	26.06.2020	250	
2	Azure Power India Pvt. Ltd.	1200001650	300	15.06.2021	300	
3	Azure Power India Pvt. Ltd.	1200001655	300	15.06.2021	100*	Part generation (100MW) Commissioned

**Based on Azure Request dated 21/09/2021*

- Accordingly, out of 1000 MW available margin at Bikaner PS, 650 MW LTA has been operationalized and margin of 350 MW is available for next LTA grantee.
- Next in priority for LTA operationalization is M/s Avaada Energy Pvt. Ltd. In above meeting M/s Avaada informed that 100MW generation is expected to be commissioned progressively from 10.10.2021 and after commissioning of generation they shall submit separate request for LTA operationalization.
- Now, M/s Avaada has requested for Part Operationalization of LTA for 100 MW out of 350 MW generation vide their letter dated 27/10/2021.
- Accordingly, in view of above, it is proposed to part Operationalize LTA for 100 MW capacity out of 350 MW granted to M/s Avaada Energy Pvt. Ltd. at Bikaner PS.

Members may deliberate.