



सेंट्रल ट्रांसमिशन यूटिलिटी ऑफ इंडिया लिमिटेड

(पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड के स्वामित्व में)

(भारत सरकार का उद्यम)

CENTRAL TRANSMISSION UTILITY OF INDIA LTD.
(A wholly owned subsidiary of Power Grid Corporation of India Limited)
(A Government of India Enterprise)

संदर्भ/Ref: CTU/E/00/14th CMETS-ER/Corrigendum

दिनांक/Date: 25-10-2023

वितरण सूची के अनुसार/ As per Distribution List

विषय/ Subject: पूर्वी क्षेत्र में पारेषण योजनाओं के विकास के लिए 14^{वीं} परामर्श बैठक के कार्यवृत्त (सीएमईटीएस-ईआर) जिसे दिनांक 18-01-2023 को जारी किया गया था उसका शुद्धिपत्र/ Corrigendum to the Minutes of 14th Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER) issued on 18-01-2023.


महोदय/महोदया/ Sir/ Ma'am,

पूर्वी क्षेत्र में पारेषण योजनाओं के विकास के लिए 14^{वीं} परामर्श बैठक 29 दिसम्बर, 2022 को वीडियो कॉन्फ्रेंस के माध्यम से आयोजित की गई थी। उक्त बैठक का कार्यवृत्त दिनांक 18-01-2023 को जारी किया गया। तत्पश्चात, 27-01-2023 को आयोजित 15^{वीं} सीएमईटीएस-ईआर में उपरोक्त 14^{वीं} सीएमईटीएस-ईआर के जारी कार्यवृत्त पर टिप्पणियाँ पर चर्चा के उपरांत अनुलग्नक **Annexure-I** पर सहमति व्यक्त की गई थी। अतः इस संबंध में 14^{वीं} सीएमईटीएस-ईआर बैठक के कार्यवृत्त का शुद्धिपत्र संलग्न है। यही CTUIL की वेबसाइट (www.ctuil.in >> [ISTS Planning and Coordination](#) >> [Consultation Meeting for ISTS >> Eastern Region](#)) पर भी उपलब्ध है। यह शुद्धिपत्र 14^{वीं} सीएमईटीएस-ईआर के जारी कार्यवृत्त का एक अभिन्न अंग माना जाएगा।

The 14th Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER) was held on 29th December 2022 through video conferencing. The minutes of the said meeting was issued on 18-01-2023. However, in the 15th CMETS-ER held on 27-01-2023, comments on above issued minutes were discussed and agreed as detailed at **Annexure-I**. Accordingly, please find enclosed corrigendum to the minutes of the 14th CMETS-ER. The same is available on CTUIL website (www.ctuil.in >> [ISTS Planning and Coordination](#) >> [Consultation Meeting for ISTS >> Eastern Region](#)). This corrigendum shall be an integral part of the earlier issued Minutes 14th CMETS-ER.

धन्यवाद/ Thanking you,

भवदीय / Yours faithfully,


25/10/2023

(राजेश कुमार) / (Rajesh Kumar)

वरिष्ठ महाप्रबंधक/ Sr. General Manager

Encl.: as above

A. वितरण सूची / Distribution List:

1.	Chief Engineer (PSP&A-II) Central Electricity Authority Sewa Bhawan, R.K.Puram New Delhi-110066	2.	Member Secretary Eastern Regional Power Committee 14, Golf Club Road, Tollygunge Kolkata-700033
3.	Director (SO) Power System Operation Corporation Ltd. (POSOCO) 9 th Floor, IFCI Towers, 61, Nehru Place, New Delhi-110016	4.	Executive Director Eastern Regional Load Despatch Centre 14, Golf Club Road, Jubilee Park, Golf Gardens, Tollygunge, Kolkata, West Bengal - 700095
5.	CMD Damodar Valley Corporation DVC Towers, VIP Road Kolkata-700054	6.	CMD Odisha Power Transmission Corporation Ltd. (OPTCL) Bhoinagar Post Office, Jan path Bhubaneshwar-751022
7.	CMD Bihar State Power Transmission Company Ltd. (BSPTCL) Vidyut Bhavan, 4 th floor, Bailey Road Patna-800021	8.	CMD Jharkhand Urja Sancharan Nigam Limited (JUSNL) Engineering Building, HEC, Dhurwa Ranchi -834004
9.	Principal Chief Engineer cum Secretary Power Department Government of Sikkim Gangtok, Sikkim	10.	Managing Director West Bengal State Electricity Transmission Company Ltd. (WBSETCL) Vidyut Bhavan, 8 th Floor, A-Block Salt Lake City, Kolkata-700091
11.	Director (Projects) Power Grid Corporation of India Ltd. "Saudamini", Plot No. 2, Sec-29, Gurugram Haryana-122001	12.	Managing Director Haldia Energy Limited (HEL) 2A, Lord Sinha Road, First Floor, Kolkata, West Bengal - 700 071, Email: rabi.chowdhury@rpsg.in ; kakali@rpsg.in ;
13.	Chairman CESC Limited CESC House, Chowringhee Square Kolkata – 700001 Email: kakali@rpsg.in ; rabi.chowdhury@rpsg.in		

Corrigendum to the Minutes of 14th CMETS-ER issued on 18-01-2023

1. In the 15th CMETS-ER held on 27-01-2023, the paras 4.2 (c) and 4.9 of the minutes of the 14th CMETS-ER were agreed to be modified as detailed under:

Original	Revised
Para 4.2 (c)	
<i>“Subsequently, the LILO of one circuit of Haldia-Subhasgram 400kV D/c line would be withdrawn and LILO of second circuit of Subhasgram-Jeerat New 400kV (Quad) D/c may be taken up.”</i>	<i>“Subsequently, the LILO of one circuit of Haldia-Subhasgram 400kV D/c line may be withdrawn if HEL/CESC wants to withdraw the temporary arrangement and LILO of second circuit of Subhasgram-Jeerat New 400kV (Quad) D/c may be taken up.”</i>
Para 4.9	
<i>“WBSETCL mentioned that after LILO of one or both circuits of Subhasgram – Jeerat New 400kV D/c (Quad) line at New Laxmikantpur, LILO of one circuit of Haldia – Subhasgram 400kV D/c line would be withdrawn. They further proposed that a member from CTU may be co-opted in the committee so as to finalise implementation modalities for New Laxmikantpur S/s. It was also informed that next meeting of committee is schedule in Jan 2023.”</i>	<i>“WBSETCL mentioned that after LILO of one or both circuits of Subhasgram – Jeerat New 400kV D/c (Quad) line at New Laxmikantpur, LILO of one circuit of Haldia – Subhasgram 400kV D/c line may be withdrawn if HEL/CESC wants to withdraw the arrangement. They further proposed that a member from CTU may be co-opted in the committee so as to finalise implementation modalities for New Laxmikantpur S/s. It was also informed that next meeting of committee is schedule in Jan 2023.”</i>

