

# सेंट्रल ट्रांसमिशन यूटिलिटी ऑफ इंडिया लिमिटेड

(पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड के स्वामित्व में)

(भारत सरकार का उद्यम)

## CENTRAL TRANSMISSION UTILITY OF INDIA LTD.

(A wholly owned subsidiary of Power Grid Corporation of India Limited)

(A Government of India Enterprise)

संदर्भ/Ref: CTU/E/00/5<sup>th</sup> CMETS-ER

दिनांक/Date: 22-04-2022

वितरण सूची के अनुसार/ As per Distribution List

विषय/ Subject: पूर्वी क्षेत्र में पारेषण योजनाओं के विकास के लिए 5<sup>वीं</sup> परामर्श बैठक के कार्यवृत्त (सीएमईटीएस-ईआर) / Minutes of 5<sup>th</sup> Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER)

महोदय/महोदया/ Sir/ Ma'am,

पूर्वी क्षेत्र में पारेषण योजनाओं के विकास के लिए 5<sup>वीं</sup> परामर्श बैठक 30<sup>th</sup> मार्च, 2022 को वीडियो कॉन्फ्रेंस के माध्यम से आयोजित की गई थी। इस संबंध में बैठक के कार्यवृत्त संलग्न है। यही CTUIL की वेबसाइट ([www.ctuil.in](http://www.ctuil.in) >> [ISTS Planning and Coordination](#) >> [Consultation Meeting for ISTS](#) >> [Eastern Region](#)) पर भी उपलब्ध है।

The 5<sup>th</sup> Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER) was held on 30<sup>th</sup> March, 2022 through video conferencing. In this regard, please find enclosed minutes of the meeting. The same is available on CTUIL website ([www.ctuil.in](http://www.ctuil.in) >> [ISTS Planning and Coordination](#) >> [Consultation Meeting for ISTS](#) >> [Eastern Region](#))

धन्यवाद/ Thanking you,

भवदीय / Yours faithfully,



(राजेश कुमार) / (Rajesh Kumar) 22/4/2022  
महाप्रबंधक/ General Manager

**A. वितरण सूची / Distribution List:**

|  |  |
|--|--|
| <b>1.</b> <b>Chief Engineer (PSP&amp;A-II)</b><br>Central Electricity Authority<br>Sewa Bhawan, R.K.Puram<br>New Delhi-110066                        | <b>2.</b> <b>Director (SO)</b><br>Power System Operation Corporation Ltd.<br>9 <sup>th</sup> Floor, IFCI Towers,<br>61, Nehru Place, New Delhi-110 016   |
| <b>3.</b> <b>Member Secretary</b><br>Eastern Regional Power Committee<br>14, Golf Club Road, Tollygunge<br>Kolkata-700033                            | <b>4.</b> <b>Executive Director</b><br>Eastern Regional Load Despatch Centre<br>14, Golf Club Road, Jubilee Park, Golf<br>Gardens, Tollygunge, Kolkata,<br>West Bengal - 700095                |
| <b>5.</b> <b>CMD</b><br>Damodar Valley Corporation<br>DVC Towers, VIP Road<br>Kolkata-700054   | <b>6.</b> <b>CMD</b><br>Odisha Power Transmission Corporation<br>Ltd. (OPTCL)<br>Bhoinagar Post Office, Jan path<br>Bhubaneswar-751022   |
| <b>7.</b> <b>CMD</b><br>Bihar State Power Transmission<br>Company Ltd. (BSPTCL)<br>Vidyut Bhavan, 4 <sup>th</sup> floor, Bailey Road<br>Patna-800021 | <b>8.</b> <b>CMD</b><br>Jharkhand Urja Sancharan Nigam Limited<br>(JUSNL)<br>Engineering Building, HEC, Dhurwa<br>Ranchi -834004   |
| <b>9.</b> <b>Principal Chief Engineer cum<br/>Secretary</b><br>Power Department<br>Government of Sikkim<br>Gangtok, Sikkim                           | <b>10.</b> <b>Managing Director</b><br>West Bengal State Electricity Transmission<br>Company Ltd. (WBSETCL)<br>Vidyut Bhavan, 8 <sup>th</sup> Floor, A-Block<br>Salt Lake City, Kolkata-700091 |

**B. विशेष आमंत्रित / Special invitee:**

**Director (Projects)**  
Power Grid Corporation of India Ltd.  
"Saudamini", Plot No. 2, Sec-29, Gurugram  
Haryana-122001

## Minutes of 5<sup>th</sup> Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER)

CGM (CTU) welcomed the participants in the meeting. List of the participants is enclosed at **Annexure-I**.

CTU gave a presentation (copy enclosed at **Annexure-IV**) on the overview of ER grid for 2026-27 time-frame. It was mentioned that installed capacity and peak demand of ER is expected to grow to about 57GW and 35.7GW respectively. Despatch factors for different type of generation for nine different load-generation scenarios was presented. Accordingly, Load-Generation Balance (LGB) for nine scenarios including surplus/deficit in each scenario was also presented. It was noted that to meet the power import/export requirement of ER till 2026-27, the existing and under implementation ISTS strengthening systems shall be adequate.

WBSETCL also gave a presentation (copy enclosed at **Annexure-V**) regarding the future load generation of West Bengal grid. Further, details regarding upcoming strengthening in state grid in order to meet future demand was also presented. Expected timeline of commissioning of under construction intra-state schemes was also updated by the state.

All the stakeholders appreciated the initiative of sharing of future plan details of ISTS and intra-state schemes in CMETS as the same shall help in better transmission system planning due to availability of updated data and coordination among states, CTU, ERPC, ERLDC & other stakeholders. It was agreed that this shall be a continuous practice. Accordingly, it was agreed that BSPTCL and OPTCL would present regarding load-generation balance and upcoming intra-state schemes of Bihar and Odisha respectively for 2026-27 time-frame in the next CMETS-ER.

Agenda wise deliberations and decisions are given below:

### 1. Confirmation of minutes of the previous meeting

CTU informed that the minutes of the 4<sup>th</sup> meeting of CMETS-ER held on 25-02-2022 were issued vide letter dated 10-03-2022. As no comments have been received, the minutes were confirmed as circulated.

### A. Application related matters in Eastern Region (ER)

### 2. LTA applications with injection in another region and drawl in ER

2.1. CTU informed that following LTA applications have been received from generation developer in NR and WR with drawl in ER in the month of Feb 2022:

| Sl. No. | Applica tion No. | Applicant Name                | Applic ation Date | Location of Generating Station | Type of Fuel | Start Date | End Date   | Drawl Point   |
|---------|------------------|-------------------------------|-------------------|--------------------------------|--------------|------------|------------|---|
| 1       | 120000 3712      | NTPC Renewable Energy Limited | 27-02-2022        | Khavda-II PS, Gujarat          | Solar        | 03-04-2024 | 02-04-2049 | TSNPDCL/SR: 78.04 MW<br>TSSPDCL/SR: 186.96 MW<br>DVC/ER: 100 MW |

| Sl. No. | Applica tion No. | Applicant Name                                | Applic ation Date | Location of Generating Station | Type of Fuel | Start Date | End Date   | Drawl Point      |
|---------|------------------|---|-------------------|--------------------------------|--------------|------------|------------|------------------|
| 2       | 120000 3764      | Adani Renewable Energy Park Rajasthan Limited | 28-02-2022        | Fathegarh-II PS, Rajasthan     | Solar        | 18-12-2023 | 18-12-2048 | Target ER: 150MW |

2.2. CTU informed that the above LTAs are proposed to be granted with transmission system expansion in WR and NR. These LTAs involves power transfer from NR and WR to ER, and no constraints are envisaged in above transfer of power to ER.

2.3. After deliberations, the above LTAs were agreed for grant along with identified system expansion in WR and NR.

**3. Requirement of STU NoC from OPTCL for LTA Application no. 1200003586 from M/s Azure Power India Pvt. Ltd. (at Bhadla-II PS, Rajasthan) for transfer of 100MW power to GRIDCO, Odisha (ER)**

3.1. CTU informed that LTA application (267MW) of M/s Azure Power India Pvt. Ltd. was discussed in 3<sup>rd</sup> CMETS-NR held on 28-01-2022 with beneficiaries as 100MW: WR (Target) & 167MW: ER (Target). The LTA application was also discussed in 3<sup>rd</sup> CMETS of SR, ER & WR for grant with target beneficiary in Eastern Region.

3.2. Now, M/s Azure vide their letter dated 17-02-2022 has requested to firm up their LTA on submission of PPA & PSA (without NoC). PPA/PSA (without NoC) has been submitted by M/s Azure for transfer of 167MW power to GRIDCO in ER. Request for NoC to OPTCL from CTU has already been sent on 16-03-2022.

3.3. OPTCL confirmed that they shall be issuing the STU NoC for the subject power transfer of 167MW from M/s Azure to GRIDCO w.e.f. 01<sup>st</sup> Dec 2023. M/s Azure, mentioned that they require NoC from 11<sup>th</sup> Nov 2023. Towards this, OPTCL mentioned that they will take up the matter with GRIDCO regarding issuance of NoC and also requested M/s Azure to take up the matter with GRIDCO.


3.4. After detailed deliberation, it was noted that OPTCL is agreeable to issuance of STU NoC for the subject power transfer. It was further also agreed that M/s Azure needs to take up the matter with GRIDCO and OPTCL regarding expeditious issuance of NoC from OPTCL.

**B. ISTS expansion schemes in Eastern Region**

**4. 2 no. of 220kV line bays at Maithon (POWERGRID) S/s for connecting Maithon (POWERGRID) – Asansol (WBSETCL) 220kV D/c line – Agenda by WBSETCL**

4.1. CTU mentioned that WBSETCL has informed following in regard to the subject proposal:

- (a) The load growth in Asansol area in west Burdwan district is taking place rapidly. Presently, power supply in the area is met from Asansol 220/132/33kV sub-station having transformation capacity of 2x160MVA + 4x50MVA. Maximum demand of the sub-station has already been reached over 150 MVA. One 220/33kV sub-station is under construction at Mongalpur in West Burdwan district to meet up-coming new loads, which is expected to be commissioned by 2022-23.



- (b) Main source of power in this area is Santaldih TPS (STPS) and Durgapur (Bidhannagar) 400/220kV sub-station. 400/220kV, 315MVA (3<sup>rd</sup>) ICT at Durgapur (Bidhannagar) is expected to be commissioned by 2022-23. Two nos. 220kV sub-station namely Asansol & JK Nagar are already connected with STPS & Durgapur (Bidhannagar) through STPS – Durgapur (Bidhannagar) 220kV D/c line (213MVA). Upcoming Mongalpur 220kV sub-station would be connected in the same line due to non-availability of corridor in the area.
- (c) Presently, maximum demand of Asansol and JK Nagar 220kV sub-stations is around 150MVA and 130MVA respectively. Expected demand of Mongalpur 220kV sub-station is around 80MVA.
- (d) Considering future load growth, for reliable operation of the grid in compliance of N-1 contingency, one new 220kV connectivity from a strong source at Asansol 220kV sub-station is required. Accordingly, Maithon (POWERGRID) – Asansol (WBSETCL) 220kV D/c line has been proposed under intra-state

4.2. CTU further mentioned that studies have been carried out for the proposed interconnection and following has been observed:

- (a) Under normal operating condition in peak load scenario, about 150MW per circuit power flow is observed on the newly proposed Maithon (POWERGRID) – Asansol (WBSETCL) 220kV D/c line. Under N-1, about 270MW power flow is observed. Therefore, it is suggested to implement this line with high capacity conductor, such as Twin ACSR Moose or Single HTLS of 1600A rating.

- (b) Upon implementation of the proposed line, power flow on Asansol – Mongalpur and Asansol – JK Nagar 220kV line sections increases and it is observed that under N-1 of any of the said two line sections, the other section gets critically loaded. Further, in case of low generation at DPL or Bakreswar the condition aggravates resulting in much higher loading in normal operating condition itself. Accordingly, it is proposed that along with implementation of Maithon (POWERGRID) – Asansol (WBSETCL) 220kV D/c line, reconductoring of Asansol – Mongalpur and Asansol – JK Nagar 220kV line sections with HTLS may also be taken up (HTLS of about 1600A).
- 4.3. CTU informed that POWERGRID has confirmed regarding availability of space for implementation of 2 no. 220kV new line bays at Maithon (POWERGRID) S/s.
- 4.4. In view of the above, following is proposed:
- (a) Space allocation at Maithon (POWERGRID) ISTS S/s to WBSETCL: Space for implementation of 2 no. 220kV line bays would be provided at Maithon (POWERGRID) ISTS S/s for termination of Maithon (POWERGRID) – Asansol (WBSETCL) 220kV D/c intra-state line (Twin ACSR Moose or Single HTLS of 1600A rating) of WBSETCL.
- 4.5. WBSETCL informed that they planning to establish a new 220kV substation at Koylapur through LILO of Santaldih TPS – Asansol 220kV D/c line, and accordingly in case of space constraint at Asansol, the 220kV line from Maithon can be terminated at Koylapur. They further mentioned that, they shall be able to confirm regarding termination of line either at Asansol or Koylapur within a month.
- 4.6. ERLDC enquired about availability of transformation capacity at Maithon (POWERGRID) S/s for additional drawl by WBSETCL, as already DVC and JUSNL are having substantial drawls at Maithon (POWERGRID) S/s. CTU informed that considering the future demand projection of states and planned systems in ISTS & Intra-state, no constraint is envisaged in transformation capacity at Maithon (POWERGRID) S/s with additional 220kV line to Asansol.
- 4.7. CTU mentioned that implementation of Koylapur 220kV substation may require revised studies, as Koylapur to Asansol may also get critically loaded. Accordingly, it was proposed that upon confirmation from WBSETCL regarding availability of space at Asansol for termination of new 220kV D/c line, the proposal may be finalized.
- 4.8. After detailed deliberation, following was agreed:
- (a) Within one month WBSETCL will confirm regarding availability of space at Asansol for implementation of Maithon (POWERGRID) – Asansol 220kV D/c line.
- (b) If space is not available at Asansol, WBSETCL will provide the details such as line length of – new sections formed after LILO of Santaldih TPS – Asansol 220kV D/c line at Koylapur, Koylapur – Maithon etc. for carrying out revised system studies.

- (c) The scheme would be again taken up for deliberation in CMETS-ER after receipt of inputs from WBSETCL and revised studies.

## 5. Establishment of 400/220kV substation at Joda – Agenda by OPTCL

- 5.1. CTU informed that the OPTCL vide letter no. Dir.(P)/BBSR/2021-22/Tech.22/154 dated 21-02-2022 has mentioned that a large number of industries are coming up in Joda area in Odisha. The major bulk loads as provided by Odisha are as follows:

| Sl. No. | Load Centre         | Load (MW)  |
|---------|---------------------|------------|
| 1       | Essar Minment       | 40         |
| 2       | JSW Steel           | 75         |
| 3       | Rungta Mines        | 148        |
| 4       | Narbheram           | 20         |
| 5       | Tata                | 40         |
| 6       | Arcelor Mittal      | 38         |
| 7       | JSPL                | 50         |
| 8       | Triveni Earth Mover | 100        |
|         | <b>Total</b>        | <b>481</b> |

- 5.2. It was further informed that:

(a) New 220kV switching station at Tikarpada along with Keonjhar - Tikarpada 220kV D/c line and LILO of TTPS - Joda 220kV line at Tikarpada was approved in 1<sup>st</sup> meeting of CMETS of Eastern Region held on 29-11-2021.

(b) Due to addition of about 480MW new load in Joda area, OPTCL has proposed for establishment of new 400/220kV S/s at Joda New and requested for ISTS connectivity from Rourkela 400/220kV and Keonjhar 400/220kV S/s alongwith LILO of Tikarpada – Joda 220kV line and Keonjhar – Joda 220kV line at Joda New.

- 5.3. CTU mentioned that out of two ISTS connectivity requested at para above, Rourkela is strongly connected to various parts in the grid viz. Talcher, Sundargarh, Ranchi, Chaibasa/Jamshedpur. However, Keonjhar is connected to the grid through LILO of Baripada – Rengali 400kV S/c line only. Considering 400/220kV Rourkela substation as a strong source, the ISTS connectivity to new 400/220kV Joda substation may preferably be provided through Rourkela substation. Further, as the loads at Joda New are major industrial loads, 400kV feed to Joda New substation may be provided from two sources. Accordingly, LILO of 400kV Talcher - Rourkela 400kV D/c line at Joda New would be a better solution.

- 5.4. It was mentioned that studies have been carried out for three different alternatives and following has been observed in the studies:

### (a) Alternative-1: Rourkela – Joda New 400kV D/c line

Under the normal condition, the power flow is about 484MW per circuit with the proposed interconnection. However, under N-1 contingency of this line the loading is about 790MW, which is under the thermal limits.

**(b) Alternative-2:** Keonjhar – Joda New 400kV D/c line

Under the normal condition, the power flow is about 233MW per circuit with the proposed interconnection. However, under N-1 contingency of Keonjhar – Rengali 400kV S/c line, very low voltage and overloading in the 220kV lines emanating from Joda New substation have been observed. Accordingly, the proposal seems to be technically non-feasible.

**(c) Alternative-3:** Connectivity with proposed LILO of Rourkela (POWERGRID) – Talcher (NTPC) 400kV D/c line at Joda New substation

Under normal operating condition in peak load scenario about 460MW per circuit power flow is observed from Rourkela to Joda New 400kV section & about 41MW per circuit is observed from Talcher to Joda New 400kV section formed after proposed LILO. Under N-1 contingency of the either 400kV section power flow is observed to be under the thermal limits. However, it may be noted that 3x500MVA, 400/220kV ICTs are required to be installed by OPTCL to meet the N-1 contingency criteria under ICT outages.

**(d)** OPTCL may install 420kV, 2x125MVAr bus reactor at Joda New S/s for voltage control.

- 5.5. CTU informed that as the loads are industrial in nature, so dual source may be provided to the 400/220kV Joda new substation for reliable power supply. Accordingly, connectivity to Joda New 400/220kV substation may be provided through **Alternative-3** mentioned above viz. LILO of Rourkela (POWERGRID) – Talcher (NTPC) 400kV D/c line at Joda New substation. Regarding installation of ICTs, it was suggested that initially 2x500MVA ICTs may be installed and with progressive demand growth additional 500MVA ICT(s) may be installed for which adequate space provision may be kept at substation planning phase.
- 5.6. ERLDC mentioned that studies may also be carried out for case involving outage of Talcher – Kolar HVDC and off-peak demand condition, so that there is no power evacuation constraint. It was further clarified that with tripping of Talcher – Kolar HVDC, there is SPS which brings down generation at Talcher St-1 (4x500MW) till thermal limit of Talcher – Meramundali line is not violated. CTU mentioned that with implementation of Joda New substation, only additional load is added into the system and power evacuation constraint accordingly is not envisaged. Nevertheless, ERLDC requested to carry out a case for off-peak demand condition and considering HVDC outage.
- 5.7. DVC mentioned that with low generation at Talcher and additional demand at Joda New, the Joda – Jindal – Jamshedpur 220kV line may get critically loaded, and accordingly the same may also need to be studied. Further, ERLDC also mentioned about loop flows and critical loading in OPTCL network near Joda.
- 5.8. After detailed deliberation, it was agreed that in view of latest observations given by ERLDC and DVC, OPTCL would review the study file and revised joint studies may be carried out for implementation of new 400kV substation at Joda. The agenda may be again deliberated in CMETS-ER after joint studies.

**6. Status of downstream 220kV or 132kV network by STUs from the various commissioned and under-construction ISTS substations in ER**

- 6.1. CTU informed that numbers of ISTS sub-stations have been commissioned and some are under construction for which the downstream system is being implemented by the STUs.
- 6.2. Based on the information provided by the states, updated information on planned/under-construction downstream system is given at **Annexure-II**.

**7. Status of 400kV substations being implemented by STUs in ER under intra-state schemes to be connected through ISTS**

- 7.1. CTU informed that various 400kV substations have been approved in the intra-state strengthening schemes in ER having interconnection with ISTS grid involving LILO of ISTS lines or direct connection to ISTS substations.
- 7.2. Status of intra-state substations and associated lines as updated by STUs in the meeting is given at **Annexure-III**.

– x – x – x –

## Annexure-I

List of participants of 4<sup>th</sup> Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER)

| Sl. No. | Name                      | Designation      | Organization | Email id   |
|---------|---------------------------|------------------|--------------|--|
| 1.      | Sh. Jasbir Singh          | CGM              | CTU          | <a href="mailto:jasbir@powergrid.in">jasbir@powergrid.in</a>                 |
| 2.      | Sh. Rajesh Kumar          | GM               | CTU          | <a href="mailto:rajeshkumar@powergrid.in">rajeshkumar@powergrid.in</a>       |
| 3.      | Sh. Manish Ranjan Keshari | Manager          | CTU          | <a href="mailto:manish.keshari@powergrid.in">manish.keshari@powergrid.in</a> |
| 4.      | Sh. Shyam Sunder Goyal    | Manager          | CTU          |  |
| 5.      | Sh. Anupam Kumar          | Dy. Manager      | CTU          | <a href="mailto:i.anupamk@powergrid.in">i.anupamk@powergrid.in</a>           |
| 6.      | Sh. Abhilash Thakur       | Engineer         | CTU          | <a href="mailto:abhilash.28@powergrid.in">abhilash.28@powergrid.in</a>       |
| 7.      | Sh. Amit Kumar            | Engineer         | CTU          | <a href="mailto:emailamit0014@gmail.com">emailamit0014@gmail.com</a>         |
| 8.      | Sh. P.P. Jena             | EE               | ERPC         | <a href="mailto:ppjena.erpc@gov.in">ppjena.erpc@gov.in</a>                   |
| 9.      | Sh. Amaresh Mallick       | CGM              | ERLDC        | <a href="mailto:amareshmallick@posoco.in">amareshmallick@posoco.in</a>       |
| 10.     | Sh. Saurav Kr Sahay       | Chief Manager    | ERLDC        | <a href="mailto:saurav.sahay@posoco.in">saurav.sahay@posoco.in</a>           |
| 11.     | Sh. Shabari Pramanick     | Manager          | ERLDC        | <a href="mailto:shabari.pramanick@posoco.in">shabari.pramanick@posoco.in</a> |
| 12.     | Sh. Chandan Kumar         | Manager          | ERLDC        | <a href="mailto:chandan@posoco.in">chandan@posoco.in</a>                     |
| 13.     | Sh. Jayanta Dutta         | Chief Engineer   | DVC          | <a href="mailto:jayanta.dutta@dvc.gov.in">jayanta.dutta@dvc.gov.in</a>       |
| 14.     | Sh. Swarup Kumar Pal      | Sr. Div. Engg    | DVC          | <a href="mailto:swarup.pal@dvc.gov.in">swarup.pal@dvc.gov.in</a>             |
| 15.     | Sh. Preetosh Ghosh        | EE, SLDC         | DVC          | <a href="mailto:Preetosh.ghosh@dvc.gov.in">Preetosh.ghosh@dvc.gov.in</a>     |
| 16.     | Sh. Ranjan Das            | Addl. CE         | WBSETCL      | <a href="mailto:cpd.wbsetcl@gmail.com">cpd.wbsetcl@gmail.com</a>             |
| 17.     | Sh. R. L. Panda           | Director project | OPTCL        |  |
| 18.     | Sh. C. R. Mishra          | DGM              | OPTCL        |  |
| 19.     | Sh. A. K. Banerjee        | DGM              | OPTCL        | <a href="mailto:ele.akbanerjee@optcl.co.in">ele.akbanerjee@optcl.co.in</a>   |
| 20.     | Sh. Ajit Kumar Bhagat     | Sr Manager       | JUSNL        | <a href="mailto:cetjusnl@gmail.com">cetjusnl@gmail.com</a>                   |

| Sl. No. | Name                      | Designation         | Organization       | Email id   |
|---------|---------------------------|---------------------|--------------------|--|
| 21.     | Sh. Rajdeep Bhattacharjee | ESE, RE Kolkata     | BSPHCL             | <a href="mailto:rekolbsphcl@gmail.com">rekolbsphcl@gmail.com</a>                 |
| 22.     | Sh. H R Panday            | Director (Projects) | BSPTCL             | <a href="mailto:dir.proj.bsptcl@gmail.com">dir.proj.bsptcl@gmail.com</a>         |
| 23.     | Sh. Ratan Kumar           | CE (P1)             | BSPTCL             |  |
| 24.     | Sh. D K Jha               | CE(P&E)             | BSPTCL             | <a href="mailto:ceplanningengg@gmail.com">ceplanningengg@gmail.com</a>           |
| 25.     | Sh. R S Prasad            | ESE(P&E)            | BSPTCL             | <a href="mailto:eeebpsgcl@gmail.com">eeebpsgcl@gmail.com</a>                     |
| 26.     | Sh. Abhishek Kumar        | EEE(P&E)            | BSPTCL             | <a href="mailto:abhishek.bsptcl@hotmail.com">abhishek.bsptcl@hotmail.com</a>     |
| 27.     | Sh. Praveen Kumar         | EEE(STU)            | BSPTCL             | <a href="mailto:stubsptcl2019@gmail.com">stubsptcl2019@gmail.com</a>             |
| 28.     | Sh. Shankar Kumar         | CE(P2)              | BSPTCL             |  |
| 29.     | Sh. Sanjai Kumar Singh    | Manager             | Bihar Grid Co. Ltd | <a href="mailto:Sanjai.singh@powergrid.in">Sanjai.singh@powergrid.in</a>         |
| 30.     | Sh. Naseem Iqbal          | SGM                 | Bihar Grid Co. Ltd |  |
| 31.     | Sh. Shashank Gupta        | Senior engineer     | Azure Power        | <a href="mailto:Shashank.gupta@azurepower.com">Shashank.gupta@azurepower.com</a> |

## Annexure-II

## Status of Downstream Transmission Network in ER

| Sl. No. | ISTS S/s        | State       | Voltage ratio, Trans. Cap          | Downstream Voltage level (kV) | Unutilised bays | Status of ISTS bay | STU lines for unutilised bays   | Status of Lines  |  |
|---------|-----------------|-------------|------------------------------------|-------------------------------|-----------------|--------------------|---|--|--|
|         |                 |             |                                    |                               |                 |                    |   | Date of Award  | Completion schedule                                      |
| 1.      | Chaibasa        | Jharkhand   | 400/220kV, 2x315MVA                | 220                           | 2               | Existing bay       | Chaibasa (POWERGRID) – Jadugoda (JUSNL) 220kV D/c                                     |  | Will be taken up in future. No firm plan as of now.      |
| 2.      | Daltonganj      | Jharkhand   | 400/220/132kV, 2x315MVA+ 2x160MVA  | 132                           | 2               | Existing bay       | Daltonganj (POWERGRID) – Chatarpur 132kV D/c  | 22-10-2019   | Expected by 21-10-2022.                                  |
| 3.      | Dhanbad         | Jharkhand   | 400/220kV                          | 220                           | 4               | Existing bay       | LILO of 1 <sup>st</sup> circuit of 220kV Dumka – Govindpur D/c line at Dhanbad (23km) | Tender has been floated.   | Dec 2023   |
|         |                 |             |                                    |                               |                 |                    | LILO of 2 <sup>nd</sup> circuit of 220kV Dumka – Govindpur D/c line at Dhanbad        | Survey and estimation are being taken up. Thereafter, funding will be tied up. |  |
| 4.      | Bolangir        | Odisha      | 400/220kV, 2x315MVA                | 220                           | 2               | Existing bay       | LILO of one ckt. of Sadeipalli – Kesinga 220kV D/c at Bolangir                        |  | Charged on 5 <sup>th</sup> Mar'22.                       |
| 5.      | Keonjhar        | Odisha      | 400/220kV, 2x315MVA                | 220                           | 2               | Existing bay       | Keonjhar (POWERGRID) – Turumunga (OPTCL) 220kV D/c                                    |  | Expected by Jun'22.                                      |
| 6.      | Pandiabil       | Odisha      | 400/220kV, 2x500MVA                | 220                           | 2               | Existing bay       | Pratapsasan (OPTCL) – Pandiabil (POWERGRID) 220kV D/c                                 |  | Expected by April'22.                                    |
| 7.      | Subashgram      | West Bengal | 400/220kV, 3x315MVA                | 220                           | 2               | Existing bay       | Subashgram (POWERGRID) – Baraipur 220kV D/c line                                      |  | Testing is going on. Expected by Apr'22.                 |
| 8.      | Rajarhat        | West Bengal | 400/220kV, 2x500MVA                | 220                           | 4               | Existing bay       | Rajarhat (POWERGRID) – New Town AA2C 220kV D/c  |  | Severe ROW (12km) in cable laying. Expected by Oct 2022. |
|         |                 |             |                                    |                               |                 |                    | Rajarhat (POWERGRID) – Barasat/Jeerat 220kV D/c                                       |  | Expected by June'22.                                     |
| 9.      | Sitamarhi (New) | Bihar       | 400/220/132kV, 2x500MVA + 2x200MVA | 132                           | 2               | Existing bay       | LILO of Benipatti - Pupri 132kV S/c at Sitamarhi (New)                                |  | Expected by May'22.                                      |

| Sl. No. | ISTS S/s      | State | Voltage ratio, Trans. Cap                  | Downstream Voltage level (kV) | Unutilised bays           | Status of ISTS bay | STU lines for unutilised bays  | Status of Lines                               |  |
|---------|---------------|-------|--|-------------------------------|---------------------------|--------------------|--|---|--|
|         |               |       |  |                               |                           |                    |  | Date of Award                                 | Completion schedule  |
| 10.     | Saharsa (New) | Bihar | 400/220/132kV, 2x500MVA + 2x200MVA         | 220                           | 4                         | Existing bay       | Saharsa (New) - Khagaria 220kV D/c line  |   | Charging process going on. Expected to be charged by April'22.                         |
|         |               |       |  |                               |                           |                    | Saharsa (New) - Begusarai 220kV D/c line   |   | Expected by April'22.  |
|         |               |       |  | 132                           | 2-ISTS (addln.4 by state) |                    | Saharsa (New) - Saharsa 132kV D/c line formed by LILO of Saharsa - Banmankhi and Saharsa - Uda Kishanganj 132kV S/c line |   | 04 nos. of bays are under construction by BSPTCL at Saharsa (New). Expected by Aug'22. |
| 11.     | Banka         | Bihar | 400/220/132kV, 2x500MVA + 2x200 & 1x315MVA | 220                           | 2                         | Under Bidding      | Banka (POWERGRID) – Goradih (Sabour New) 220kV D/c line  | Funds tied up. Tendering is expected shortly. | 18 months from award.  |

## Annexure-III

**Status of 400kV substations being implemented by STUs in ER under  
intra-state schemes to be connected to ISTS**

| Sl. No.   | Substation/Location   | Transformation Capacity/ Element                                     | Date of Award            | Completion Schedule   |
|---|---|--|--------------------------|---|
| <b>A Bihar (to be implemented by BSPTCL/BGCL)</b> |   |  |                          |   |
| I   | <b>Naubatpur GIS</b>  | 400/220/132/33kV,<br>2x500MVA + 2x160MVA +<br>2x80MVA                | 26.04.2018               | Charged on 17 <sup>th</sup><br>Mar 2022.                          |
| a)  | LILO of circuits 3 & 4 of Patna (PG)-Balua 400 kV D/c (Quad) line at Naubatpur 400 kV 2x D/C    | 400kV 2x D/C   | 26.04.2018               | Charged on 17 <sup>th</sup><br>Mar 2022.                          |
| b)  | LILO of both circuits of Ara (PG) – Khagaul (BSPTCL) line at Naubatpur (New) 220 kV 2xD/C       | 220kV 2xD/C  | 26.04.2018               | Expected in<br>Apr'22.  |
| II  | <b>Bakhtiyarpur GIS</b>   | 400/220/132kV, 2x500MVA<br>+ 2x160MVA                                | 26.11.2019               | Progressively<br>from Aug'22 to<br>Dec'22.                        |
| a)  | LILO of both circuits of Barh – Patna (PG) 400kV D/c (Quad) line-1 at Bakhtiyarpur 400 kV 2xD/C | 400kV 2xD/c  | 26.11.2019               | Line ready to be<br>charged<br>matching with<br>Bakhtiyarpur S/s. |
| III   | <b>Jakkanpur GIS</b>  | 400/220/132/33kV,<br>2x500MVA + 3x160MVA +<br>4x80MVA                | 26.04.2018               | Expected in<br>Apr'22.  |
| a)  | LILO of both circuits of Nabinagar-II – Patna (PG) 400kV D/c at Jakkanpur                       | 400kV 2xD/c  | 26.04.2018               | Expected in<br>Apr'22   |
| IV  | <b>Chappra (New)</b>  | 400/220/132kV, 2x500MVA<br>+ 2x200MVA                                | Funds not yet<br>tied up | State Govt<br>approval under<br>process.                          |
| a)  | LILO of 400 kV Barh (NTPC) - Motihari (DMTCL) D/C (Quad) transmission line at Chappra           | 400kV 2xD/c  | Funds not yet<br>tied up | State Govt<br>approval under<br>process.                          |
| <b>B Odisha (to be implemented by OPTCL)</b>      |   |  |                          |   |
| I   | <b>Meramundali-B</b>  | 400/220kV, 2x500MVA  | -                        | ICT-1 charged &<br>ICT-2 on 23 <sup>rd</sup><br>Mar'22.           |
| II  | <b>Digapahandi</b>  | 400/220kV, 2x500MVA  | Survey in<br>progress    | 2025-26   |
| a)  | Digapahandi – Therubali – Jeypore 400kV D/c line  | 400kV D/c  | Survey in<br>progress    | 2025-26   |
| III   | <b>Therubali</b>  | 400kV switching station<br>along with 420kV,<br>1x125MVA bus reactor | Survey in<br>progress    | 2025-26   |
| IV  | <b>Bhadrak</b>  | 400/220kV, 2x500MVA  | Tendering in<br>progress | 2024-25   |
| a)  | LILO of Baripada – Duburi and Baripada – Pandiabili 400kV line sections at Bhadrak              | 400kV D/c  | Tendering in<br>progress | 2024-25   |

| Sl. No.    | Substation/Location  | Transformation Capacity/Element                 | Date of Award  | Completion Schedule                         |
|------------|--|---|--|---|
| <b>V</b>   | <b>Paradeep*</b>   |   |  |   |
| a)         | Paradeep   | 400kV   | Line package awarded and substation awarded in May'22            | 24 months                                   |
| b)         | Paradeep   | 765kV   |  | 2025-26                                     |
| c)         | Angul (POWERGRID) – Paradeep (OPTCL) 765kV D/c line        | 765kV D/c                                       | Survey in progress   | 2025-26                                     |
| <b>VI</b>  | <b>Begunia</b>   | 765/400kV, 2x1500MVA                            | Kept in abeyance   | Kept in abeyance                            |
| a)         | Angul – Begunia 765kV D/c line                             | 765kV D/c                                       | Kept in abeyance   | Kept in abeyance                            |
| b)         | LILO of Pandiabil – Digapahandi 400kV D/c line at Begunia  | 400kV D/c                                       | Kept in abeyance   | Kept in abeyance                            |
| <b>C</b>   | <b>Jharkhand (to be implemented by JUSNL)</b>              |   |  |   |
| <b>I</b>   | <b>Jasidih</b>   | 400/220kV, 2x500MVA                             | -  | No firm plan now. To be taken up in future. |
| <b>II</b>  | <b>Chandil (New)</b>                                       | 400/220kV, 2x500MVA                             | NIT has been floated on 05-03-2022. Bid opening in Apr'22.       | 24 months                                   |
| a)         | Chandil – Chaibasa (POWERGRID) 400kV D/c line              | 400kV D/c                                       |  |   |
| <b>III</b> | <b>Koderma</b>   | 400/220/132/33kV, 2x500MVA + 2x200MVA + 2x80MVA |  |   |
| <b>IV</b>  | <b>Mander</b>  | 400/220kV, 2x500MVA                             | -  | No firm plan now. To be taken up in future. |
| a)         | LILO of Patratu – Ranchi (New) 400kV D/c line at Mander    | 400kV 2xD/c                                     | -  | No firm plan now. To be taken up in future. |
| <b>V</b>   | <b>Dumka (New)</b>   | 400/220kV, 2x500MVA                             | -  | No firm plan now. To be taken up in future. |
| a)         | Dumka (New) – Dhanbad (ISTS) 400kV D/c line                | 400kV D/c                                       | -  | No firm plan now. To be taken up in future. |
| <b>D</b>   | <b>West Bengal (to be implemented by WBSETCL)</b>          |   |  |   |
| <b>I</b>   | <b>Laxmikantpur GIS</b>                                    | 400/132kV, 2x315MVA                             | Land identified. In process of acquisition. Expected by Dec 2024 |   |
| a)         | LILO of Haldia – Subhasgram 400kV D/c line at Laxmikantpur | 400kV D/c                                       | -  | Expected by Dec 2024                        |

\* OPTCL informed that Paradeep 765/400kV is different that of already under-construction Paradeep 400/220kV S/s, accordingly, they are planning 400kV 2xD/c line between two substations.

# Load Generation balance of Eastern Region – 2026-27



# Installed Capacity & Peak Demand 2026-27

| State        | Thermal      | Hydro        | Solar       | Total        | EPS Peak Demand |
|--------------|--------------|--------------|-------------|--------------|-----------------|
| Bihar        | 1820         | 45           | 700         | <b>2565</b>  | 9308            |
| Jharkhand    | 2400         | 130          | 0           | <b>2530</b>  | 6626            |
| Odisha       | 2490         | 2193         | 403         | <b>5086</b>  | 6273            |
| West Bengal  | 6065         | 1474         | 0           | <b>7539</b>  | 15680           |
| Sikkim       | 0            | 14           | 0           | <b>14</b>    | 216             |
| Central      | 24440        | 5819         | 0           | <b>30259</b> |                 |
| IPP          | 4150         | 5012         | 0           | <b>9162</b>  |                 |
| <b>Total</b> | <b>41365</b> | <b>14686</b> | <b>1103</b> | <b>57154</b> | <b>35674</b>    |

# Scenario wise generation despatch and Demand factor

| Scenario No & Name   | Generation Dispatch Factors |       | Demand Factor |
|----------------------|-----------------------------|-------|---------------|
|                      | Hydro                       | Solar |               |
| 1-Aug Solar Max      | 70%                         | 80%   | 83%           |
| 2-Aug Peak Load      | 90%                         | 0%    | 97%           |
| 3-Aug Night Off Peak | 70%                         | 0%    | 88%           |
| 4-Jun Solar Max      | 70%                         | 85%   | 84%           |
| 5-Jun Peak Load      | 90%                         | 0%    | 99%           |
| 6-Jun Night Off Peak | 70%                         | 0%    | 84%           |
| 7-Feb Solar Max      | 30%                         | 90%   | 69%           |
| 8-Feb Peak Load      | 60%                         | 0%    | 81%           |
| 9-Feb Night Off Peak | 30%                         | 0%    | 54%           |

Thermal generations dispatch have been considered based on Merit order data

# Scenario wise Demand Considered

| States/Scenario | 1            | 2            | 3            | 4            | 5            | 6            | 7            | 8            | 9            |
|-----------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Bihar           | 7065         | 8311         | 3138         | 6618         | 7861         | 4450         | 5295         | 6286         | 3230         |
| Jharkhand       | 1552         | 1826         | 1413         | 1562         | 1856         | 1258         | 1584         | 1880         | 1158         |
| DVC-JH          | 2354         | 2769         | 3538         | 2605         | 3095         | 3597         | 2561         | 3040         | 2412         |
| DVC-WB          | 1339         | 1575         | 2012         | 1482         | 1760         | 2046         | 1457         | 1729         | 1372         |
| Odisha          | 6094         | 7169         | 8299         | 6238         | 7410         | 5914         | 5249         | 6232         | 3867         |
| West Bengal     | 10785        | 12687        | 12905        | 11157        | 13253        | 12749        | 8031         | 9534         | 7119         |
| Sikkim          | 119          | 140          | 19           | 116          | 138          | 57           | 185          | 220          | 120          |
| <b>Total</b>    | <b>29308</b> | <b>34477</b> | <b>31324</b> | <b>29778</b> | <b>35373</b> | <b>30071</b> | <b>24362</b> | <b>28921</b> | <b>19278</b> |

# State wise drawl from ISTS

| Drawl from ISTS | Aug'26       |             |             | Jun'26      |            |              | Feb'27      |               |              |
|-----------------|--------------|-------------|-------------|-------------|------------|--------------|-------------|---------------|--------------|
| Scenario No     | 1            | 2           | 3           | 4           | 5          | 6            | 7           | 8             | 9            |
| State           | Solar Max    | Peak Load   | Off Peak    | Solar Max   | Peak Load  | Off Peak     | Solar Max   | Peak Load     | Off Peak     |
| Bihar           | 6474         | 6724        | 2106        | 5991        | 6699       | 4537         | 4651        | 4712          | 2215         |
| Jharkhand       | 439          | -331        | 2           | 151         | -301       | 173          | 225         | -238          | -201         |
| DVC             | 3693         | 4344        | 5550        | 4087        | 4855       | 4017         | 4017        | 4769          | 3785         |
| Odisha          | 3423         | 3937        | 5507        | 3546        | 4179       | 2839         | 3222        | 3361          | 2203         |
| West Bengal     | 9753         | 9312        | 9825        | 10125       | 9878       | 5111         | 6577        | 6601          | 4964         |
| Sikkim          | 109          | 128         | 9           | 106         | 125        | 175          | 181         | 212           | 116          |
| Central         | -6603        | -12073      | -11366      | -9821       | -17925     | -15845       | -14044      | -24266        | -16568       |
| IPP             | -4916        | -6687       | -5684       | -4916       | -6687      | -5684        | -3786       | -6535         | -4554        |
| <b>Total</b>    | <b>12370</b> | <b>5354</b> | <b>5948</b> | <b>9270</b> | <b>824</b> | <b>-4677</b> | <b>1043</b> | <b>-11383</b> | <b>-8040</b> |


# Region wise Surplus/ Deficit and IR flows

| Surplus(+)/Deficit(-) |             | Aug'26    |           |          | Jun'26    |           |          | Feb'27    |           |          |
|-----------------------|-------------|-----------|-----------|----------|-----------|-----------|----------|-----------|-----------|----------|
| Scenario No           |             | 1         | 2         | 3        | 4         | 5         | 6        | 7         | 8         | 9        |
| Region                | Demand      | Solar Max | Peak Load | Off Peak | Solar Max | Peak Load | Off Peak | Solar Max | Peak Load | Off Peak |
| NR                    | 91294       | 17317     | -18302    | -17347   | 14106     | -28391    | -20707   | 28432     | -10390    | -2738    |
| WR                    | 89080       | -2053     | 17079     | 15612    | -3278     | 21428     | 17606    | -10740    | 7989      | 8598     |
| SR                    | 78584       | -1263     | 6922      | 6477     | 1228      | 7441      | 3700     | -13709    | -8521     | -13337   |
| ER                    | 33513       | -12370    | -5354     | -5948    | -9270     | -824      | -1034    | -1043     | 11383     | 8040     |
| NER                   | 6303        | -1020     | -346      | 91       | -668      | 345       | 434      | -1827     | -461      | -563     |
|                       |             | 610       | 0         | -1115    | 2116      | 0         | 0        | 1113      | 0         | 0        |
|                       |             |           |           |          |           |           |          |           |           |          |
| IR Flows              |             | Aug'26    |           |          | Jun'26    |           |          | Feb'27    |           |          |
| Scenario No           |             | 1         | 2         | 3        | 4         | 5         | 6        | 7         | 8         | 9        |
| Corridor              | TTC(Apr'23) | Solar Max | Peak Load | Off Peak | Solar Max | Peak Load | Off Peak | Solar Max | Peak Load | Off Peak |
| WR-NR                 | 25500       | -4993     | 18628     | 16980    | -4505     | 24235     | 17642    | -19915    | 4007      | 662      |
| ER-NR                 | 6900        | -8876     | -949      | -645     | -5268     | 3114      | 1995     | -5592     | 5412      | 1697     |
| ER-WR                 | -           | -4628     | -4650     | -6229    | -4034     | -5639     | -5404    | -417      | 2354      | 2116     |
| ER-SR                 | 5450        | 3183      | 2692      | 2537     | 3379      | 2815      | 3386     | 5007      | 4107      | 4546     |
| WR-SR                 | 16000       | -1505     | -8250     | -8556    | -3391     | -9851     | -6546    | 8466      | 4759      | 8730     |
| NER-ER                | -2000       | 272       | -996      | -501     | 574       | -219      | -148     | -498      | -1073     | -1164    |

# 5th Consultation Meeting for Evolving Transmission Schemes in Eastern Region (CMETS-ER)

30<sup>th</sup> March 2022

*Presented by*




***West Bengal State Electricity Transmission Company Limited***

## 1. Maithon(PG)-Asansol (WBSETCL) 220 KV D/C connectivity (Agenda - B.4):


### ► Reasons for the proposal:

- ✓ **Maximum demand of Asansol and JK Nagar 220kV sub-stations are around 150MVA and 130MVA respectively. Expected demand of upcoming Mongalpur 220kV sub-station will be around 80MVA.**
- ✓ **Main source of power in this area is Santaldihi TPS (STPS) and Durgapur (Bidhannagar) 400/220kV sub-station.**
- ✓ **WBSEDCL and IPCL have a landscape of huge load growth in and around Kulapur, Mangalpur and for some megacity projects by BAPL.**
- ✓ **Considering above and for reliable operation of the grid in compliance of N-1 contingency, one new 220kV connectivity from a strong source at Asansol 220kV sub-station has been found essential. Accordingly, Maithon (POWERGRID) – Asansol (WBSETCL) 220kV D/C line has been proposed by WBSETCL under intra-state.**

# Maithon(PG)-Asansol (WBSETCL) connectivity (contd....):




# Maithon(PG)-Asansol (WBSETCL) connectivity (contd....):





# Maithon(PG)-Asansol (WBSETCL) connectivity (contd....):



## 2. Status of Works in Progress of 220 KV and downstream networks (Agenda - B.6):

| SL | DISTRICT           | VOLTAGE (KV) | NAME OF SS          | TRF MVA | TARGET YEAR |
|----|--------------------|--------------|---------------------|---------|-------------|
| 1  | Hooghly            | 220          | Belmuri 220 KV SS   | 320     | 2022-2023   |
| 2  | Howrah             | 220          | Jangalpur 220 KV SS | 420     | 2022-2023   |
| 3  | North 24 Paraganas | 220          | NT AA-IIC 220 KV SS | 520     | Oct-22      |
| 4  | South 24 Paraganas | 220          | Baruipur 220 KV SS  | 420     | Apr-22      |
| 5  | Alipurduar         | 220          | Falakata 220 KV SS  | 420     | 2023-2024   |
| 6  | Howrah             | 220          | Food Park 220 KV SS | 100     | 2023-2024   |
| 7  | Paschim Bardhaman  | 220          | Mangalpur 220 KV SS | 200     | 2023-2024   |
| 8  | Paschim Bardhaman  | 220          | AB-Zone 220 KV SS   | 320     | 2023-2024   |
|    |                    |              | Total MVA=          | 2720    |             |

- ▶ Works for 15 Nos. of 132 KV Sub-station are also in progress. After completion of the 23 Nos of Sub-stations, 4196 MVA of Transformation capacity and nearly 1500 CKM of Transmission lines of different voltage level will be added to the system.

### 3. Status of 400 KV SS being implemented by STU, West Bengal (Agenda - B.7) :

| SL | DISTRICT        | VOLTAGE (KV) | NAME OF SS                   | TRF MVA           | TARGET YEAR | REMARKS   |
|----|-----------------|--------------|------------------------------|-------------------|-------------|---|
| 1  | 24 Paraganas(S) | 400/132/33   | New Laxmikantapur 400 KV GIS | 2X 315 + 2X50=730 | 2024-2025   | <p>12.72 acres of Land for the SS is identified and is in the process of acquisition. As per plan and as approved in the 2<sup>nd</sup> ERSCT in 2019, 400 KV D/C LILO of Haldia(HEL)-Subhasgram line was considered.</p> <p>WBSETCL is also submitting a proposal to make S/C LILO of Jeerat(PG)-Subhasgram(PG) 400 KV D/C Line (Under const) at proposed New Laxmikantapur (LILO RL=50 KM approx) for strengthening the power network and supply of quality power in south 24 PGN district and the coastal areas.</p> |

#### 4. Sub-stations planned by STU upto 2026-27:

| SL | NAME OF DIST       | VOLTAGE(KV) | NAME OF SS                  | PROPOSED MVA | TARGET YEAR |
|----|--------------------|-------------|-----------------------------|--------------|-------------|
| 1  | Purba Bardhaman    | 400         | Satgachia 400 KV SS         | 1000         | 2024-2025   |
| 2  | South 24 Paraganas | 400         | New Laxmikantapur 400 KV SS | 730          | 2024-2025   |
| 3  | Purulia            | 400         | New PPSP 400/132 KV SS      | 200          | 2025-2026   |
| 4  | Hooghly            | 220         | Khanakul 220 KV SS          | 100          | 2023-2024   |
| 5  | Purulia            | 220         | Raghunathpur 220 KV SS      | 320          | 2023-2024   |
| 6  | Birbhum            | 220         | Kotasur 220 KV SS           | 320          | 2025-2026   |
| 7  | Howrah             | 220         | Jagadishpur 220 KV SS       | 420          | 2025-2026   |
| 8  | North 24 Paraganas | 220         | Deganga 220 KV SS           | 420          | 2025-2026   |
| 9  | Paschim Medinipur  | 220         | CK Road 220 KV SS           | 320          | 2025-2026   |
| 10 | Purba Bardhaman    | 220         | Mahachanda 220 KV SS        | 320          | 2026-2027   |
|    |                    |             | <b>Total MVA=</b>           | <b>4150</b>  |             |

- ▶ There are plan for 16 Nos. of 132 KV Sub-station and 01 No. 66 KV SS upto 2026-27. After completion of the 27 Nos of Sub-stations, 5809 MVA of Transformation capacity and nearly 3500 CKM of Transmission lines of different voltage level will be added to the system.

## 5. LGBR Data iro WBSETCL :

|  |   | 2026-27     |              |             |             |              |             |             |              |             |
|--|---|-------------|--------------|-------------|-------------|--------------|-------------|-------------|--------------|-------------|
|  |   | Jun-26      |              |             | Aug-26      |              |             | Feb-27      |              |             |
|  |   | Late night  | evening peak | afternoon   | Late night  | evening peak | afternoon   | Late night  | evening peak | afternoon   |
| Demand Side                                  | Consumer Demand                           | 6345        | 8990         | 7495        | 6345        | 8750         | 7010        | 3865        | 5610         | 5150        |
|  | PPSP (pump load)                          | 1000        | 0            | 0           | 1000        | 0            | 0           | 1000        | 0            | 0           |
|  | <b>Total Demand (A)</b>                   | <b>7345</b> | <b>8990</b>  | <b>7495</b> | <b>7345</b> | <b>8750</b>  | <b>7010</b> | <b>4865</b> | <b>5610</b>  | <b>5150</b> |
| Availability side                            | BTPS                                      | 105         | 105          | 105         | 105         | 105          | 105         | 150         | 150          | 150         |
|  | BKTPP                                     | 800         | 800          | 800         | 800         | 800          | 750         | 670         | 680          | 670         |
|  | KTPP                                      | 315         | 315          | 315         | 315         | 315          | 315         | 500         | 500          | 500         |
|  | SGTPP                                     | 1730        | 1730         | 1730        | 1730        | 1730         | 1450        | 1150        | 1200         | 1150        |
|  | STPS                                      | 385         | 385          | 385         | 385         | 385          | 385         | 370         | 370          | 370         |
|  | Sub- Total WBPDCCL (a)                    | <b>3335</b> | <b>3335</b>  | <b>3335</b> | <b>3335</b> | <b>3335</b>  | <b>3005</b> | <b>2840</b> | <b>2900</b>  | <b>2840</b> |
|  | DPL Generation                            | 370         | 370          | 370         | 370         | 370          | 370         | 210         | 220          | 220         |
|  | Hiranmoyee Energy                         | 200         | 200          | 200         | 200         | 200          | 200         | 200         | 200          | 200         |
|  | Sub-Total other state generation (b)      | <b>570</b>  | <b>570</b>   | <b>570</b>  | <b>570</b>  | <b>570</b>   | <b>570</b>  | <b>410</b>  | <b>420</b>   | <b>420</b>  |
|  | WBSEDCL Hydel                             | 100         | 100          | 100         | 100         | 100          | 100         | 45          | 50           | 50          |
|  | PPSP                                      | 0           | 900          | 0           | 0           | 900          | 0           | 0           | 445          | 0           |
|  | Sub total WBSEDCL generation ( c )        | <b>100</b>  | <b>1000</b>  | <b>100</b>  | <b>100</b>  | <b>1000</b>  | <b>100</b>  | <b>45</b>   | <b>495</b>   | <b>50</b>   |
|  | TLDP 3                                    | 110         | 130          | 100         | 130         | 130          | 130         | 0           | 50           | 0           |
|  | TLDP 4                                    | 130         | 160          | 125         | 160         | 160          | 160         | 0           | 60           | 0           |
|  | Sub-Total TLDP Generation (d)             | <b>240</b>  | <b>290</b>   | <b>225</b>  | <b>290</b>  | <b>290</b>   | <b>290</b>  | <b>0</b>    | <b>110</b>   | <b>0</b>    |
|  | ISGS + LTOA of WBSEDCL ( e )              | <b>2450</b> | <b>2450</b>  | <b>2406</b> | <b>2570</b> | <b>2570</b>  | <b>2200</b> | <b>1380</b> | <b>1475</b>  | <b>1380</b> |
|  | state internal Solar & other renewable    | 0           | 0            | 300         | 0           | 0            | 300         | 0           | 0            | 125         |
|  | state internal non Solar renewable        | 110         | 110          | 110         | 110         | 110          | 110         | 100         | 110          | 100         |
|  | Mandarmoni Solar                          |             |              |             |             |              |             |             |              |             |
|  | NVVNL Bundle Power (Solar)                | 0           | 0            | 50          | 0           | 0            | 50          | 0           | 0            | 50          |
|  | Non Solar renewable from outside state    | 300         | 300          | 300         | 300         | 300          | 286         | 90          | 100          | 90          |
|  | solar renewable energy from outside state | 0           | 0            | 99          | 0           | 0            | 99          | 0           | 0            | 95          |
|  | Sub-total Renewable (f)                   | <b>410</b>  | <b>410</b>   | <b>859</b>  | <b>410</b>  | <b>410</b>   | <b>845</b>  | <b>190</b>  | <b>210</b>   | <b>460</b>  |
| STOA (g)                                     | <b>240</b>                                | <b>935</b>  | <b>0</b>     | <b>70</b>   | <b>575</b>  | <b>0</b>     | <b>0</b>    | <b>0</b>    | <b>0</b>     |             |
| <b>Total Availability B =(a+b+c+d+e+f+g)</b> | <b>7345</b>                               | <b>8990</b> | <b>7495</b>  | <b>7345</b> | <b>8750</b> | <b>7010</b>  | <b>4865</b> | <b>5610</b> | <b>5150</b>  |             |

*Thank  
you*

